Aeration control by monitoring the microbiological activity using fuzzy logic diagnosis and control. Application to a complete autotrophic nitrogen removal reactor

Boiocchi, Riccardo; Mauricio Iglesias, Miguel; Vangsgaard, Anna Katrine; Gernaey, Krist; Sin, Gürkan

Published in:
Journal of Process Control

Link to article, DOI:
[10.1016/j.jprocont.2014.10.011](https://doi.org/10.1016/j.jprocont.2014.10.011)

Publication date:
2015

Document Version
Peer reviewed version

[Link back to DTU Orbit](#)

Citation (APA):
Boiocchi, R., Mauricio Iglesias, M., Vangsgaard, A. K., Gernaey, K., & Sin, G. (2015). Aeration control by monitoring the microbiological activity using fuzzy logic diagnosis and control. Application to a complete autotrophic nitrogen removal reactor. *Journal of Process Control*, 30, 22-33.
<https://doi.org/10.1016/j.jprocont.2014.10.011>

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Aeration control by monitoring the microbiological activity using fuzzy logic diagnosis and control. Application to a complete autotrophic nitrogen removal reactor

R. Boiocchi, M. Mauricio-Iglesias, A.K. Vangsgaard, K.V. Gernaey, G. Sin

CAPEC-PROCESS, DTU Chemical Engineering, Technical University of Denmark, DK-2800 Lyngby, Denmark,

(e-mail: ricca@kt.dtu.dk; mmmi@kt.dtu.dk; akv@kruger.dk; kvg@kt.dtu.dk; gsi@kt.dtu.dk)

ABSTRACT

Complete Autotrophic Nitrogen Removal (CANR) is a novel process where ammonia is converted to nitrogen gas by different microbial groups. The performance of the process can be compromised by an unbalanced activity of the biomass caused by disturbances or non-optimal operational conditions. This contribution describes the development of a fuzzy-logic based system for both diagnosis and control of a CANR reactor. Based on a combination of measurements of the nitrogen species concentration in the influent and in the effluent on the one hand, and insights into the activities of three distinctive microbial groups on the other hand, the diagnosis provides information on: nitrification, denitrification, anaerobic ammonium oxidation and overall autotrophic nitrogen removal. These four results give insight into the state of the process and are used as inputs for the controller that manipulates the aeration to the reactor.

The diagnosis tool was first evaluated using 100 days of real process operation data obtained from a lab-scale single-stage autotrophic nitrogen removing reactor. This evaluation revealed that the fuzzy logic diagnosis is able to provide a realistic description of the microbiological state of the reactor with process engineering insight analysis. An evaluation of both the diagnosis tool and the controller was done by simulating a disturbance in the influent concentration. High and steady nitrogen removal efficiency was achieved thanks to the diagnosis and control system. Finally, development of the diagnosis and control as two independent systems provided further insight into the operation performance, gives transparency towards the operator and makes the system flexible for future maintenance or improvements.

Keywords: Fuzzy-logic; bioreactor control; bioprocess diagnosis; anammox; inference system; nitrogen removal.

ABBREVIATIONS

AOB	Ammonia-Oxidizing Bacteria
AnAOB	Anaerobic Ammonia-Oxidizing Bacteria
CANR	Complete Autotrophic Nitrogen Removal
ER	Exchange Ratio
FIS	Fuzzy Inference System
FLC	Fuzzy-Logic Control
FLD	Fuzzy-Logic Diagnosis
HB	Heterotrophic Bacteria
MF	Membership Function
MV	Manipulated Variable
NOB	Nitrite-Oxidizing Bacteria
SBR	Sequencing Batch Reactor
TN	Total Nitrogen

1. INTRODUCTION

Monitoring microbial activity is essential for achieving high control performances in biological reactors. Advances in molecular tools based on omics technology (genomics, metabolomics, etc...) provide a qualitative assessment of the activated sludge microbial community structure with its diverse functions [1]. These measurements are however off-line, tedious, time-intensive, expensive and not able to fulfil the actual needs of most monitoring and control applications. In addition, due to the presence of interacting microbial groups many challenges arise when trying to estimate the microbial activity in a mixed-

culture bioreactor. Hence the information given by the few sensors usually implemented in a bioreactor needs to be expanded with observers or other state-estimation tools in order to infer the state of the microbial groups. When first principle models of the microbial kinetics are not available or mismatch significantly with the reality, expert-knowledge about a process system can represent a useful alternative for the development of control strategies. The so-called “fuzzy-logic inference system” (FIS) is a means to exploit this knowledge for control strategy development [2,3]. Since its control laws are expressed in linguistic rather than mathematical expressions, FISs are intrinsically easy to understand and to adapt in function of control performance requirements. Moreover, FISs have been shown to enable integrating quantitative mechanistic knowledge with qualitative expert knowledge, making it suitable for processes that are still in the development stage. Previous applications of FISs in wastewater treatment (WWT) include the control of activated sludge processes [4, 13], digesters [11] or improving disturbance rejection [6].

The so-called Complete Autotrophic Nitrogen Removal (CANR) is a novel process that has shown its usefulness for the side-stream treatment of reject water from anaerobically treated sludge dewatering or landfill leachate [4–6]. The CANR process performs the conversion of ammonium (NH_4^+) to dinitrogen (N_2) through the activity of ammonia-oxidizing bacteria (AOB) and anaerobic ammonia-oxidizing bacteria (AnAOB) [4,5]. AOB partially convert NH_4^+ to nitrite (NO_2^-) with oxygen (O_2) as electron acceptor and AnAOB oxidize the remaining fraction of NH_4^+ by reducing the AOB-produced NO_2^- [4,7–9]. In this process, a minor fraction of nitrate (NO_3^-) is produced. Well-known advantages of the CANR process are: reduction of O_2 supply, no need for organic biodegradable carbon addition and negligible sludge production [5]. CANR can be accomplished in a single reactor, where AOB and AnAOB work simultaneously, or in a two-stage configuration designed to have the aerobic AOB-mediated process, namely nitrification, preceding the AnAOB-mediated process. The performance of a single-stage CANR can be seriously compromised due to disturbances as well as operating conditions leading to unbalanced activity of the biomass. For example, a significant activity of nitrite-oxidizing bacteria (NOB), a class of autotrophic microorganisms converting NO_2^- to nitrate (NO_3^-), reduces the total nitrogen (TN) removal efficiency, since NO_3^- requires a significant amount of readily degradable organic carbon and the presence of heterotrophic bacteria (HB) to be converted to N_2 .

Ensuring a balanced microbiological activity during CANR is therefore central in order to achieve a good and steady performance. Since many microbial processes take place simultaneously resulting in dependencies and competition between the microbial groups, linear controllers using constant set point values for dissolved oxygen, O_2 reduction potential, N species or pH alone may not be enough to ensure balanced microbial community activities and therefore performance stability [10–12]. Too high O_2 concentrations inhibit the AnAOB activity and enhance the undesired activity of NOB. On the other hand, too low O_2 supply leads to low aerobic AOB activity [4,8]. Therefore, a diagnosis of the microbiological operation is needed to establish the appropriate control action.

The present work is a comprehensive extension and analysis of the work presented at the CAB/DYCOPS conference in 2013 [13]. The main additions made are: (i) a structured methodology and in-depth description of the work flows underlying the development of a fuzzy-logic diagnosis and fuzzy-logic controller. In addition, the control block diagram indicating the data-flow and information flow hierarchy is presented, (ii) detailed analysis and validation of the diagnosis tool with experimental data and process engineering insights, (iii) control performance evaluation under more challenging disturbances and conditions. The objective of this work is to develop a fuzzy-logic diagnosis (FLD) and a fuzzy-logic control (FLC) with the objective of achieving high and steady TN removal in a single-stage CANR reactor with granular sludge. The FLD will provide information regarding the activity of the biomass as an input to the FLC. Diagnosis and control will be developed independently in order to achieve transparency on the input information given to the controller, and flexibility in case of needed control performance improvement and feasibility for the implementation of the knowledge by the operator.

The paper is organised as follows: first the mathematical model of a lab-scale CANR reactor and the modelling of generic FIS are presented. Afterwards, the development of the FLD and FLC tools is explained. The fuzzy-logic diagnosis performance will first be evaluated on the basis of the consistency of the outputs produced and of their capability of realistically describing the actual situation of the biomass during 100 days of a lab-scale CANR operation. Finally, both the FLD and the FLC are evaluated by simulation of a disturbance in the nitrogen load to the reactor, in the form of a change in the incoming ammonium concentration.

2. MATERIALS AND METHOD

The FLD and FLC system developed were implemented using the fuzzy logic toolbox of MATLAB R2013 (The MathWorks, Natick, MA). The developed FLD and FLC were then coupled to a process model built in Simulink. The process model consists of the description of the physical and biochemical processes occurring in a lab-scale CANR reactor. In this section, first a brief description regarding the mathematical model used and the physical configuration of the reactor are provided. Afterwards an overview of the generic work done by a fuzzy-logic inference system will be shown.

2.1 Mathematical model and physical configuration of the reactor

The mathematical model employed in this work describes a granular based single-stage CANR sequencing batch reactor (SBR) shown in Figure 1. The model developed and described in detail by Vangsgaard *et al.* [14] is shortly described here for the sake of completeness. It consists of mass balance equations for each soluble and particulate compound considered in the model. The main assumptions included are: (a) the transfer of soluble compounds within the granule occurs only by diffusion (equation (1)) and (b) the transport of particulate compounds occurs only by advection (equation (2)). The bulk of the reactor is assumed to be completely mixed, which results in equation (3).

$$\frac{\partial S_i}{\partial t} = D_i \cdot \frac{1}{z^2} \cdot \frac{\partial}{\partial z} \left(z^2 \cdot \frac{\partial S_i}{\partial z} \right) + r_i \quad (1)$$

$$\frac{\partial X_i}{\partial t} = - \frac{\partial (X_i \cdot u_F)}{\partial z} + r_i \quad (2)$$

$$\frac{dC_i}{dt} = \frac{Q_{in} \cdot C_{i,in} - Q_{out} \cdot C_{i,bulk} - j_{bio,i} \cdot A_{bio}}{V} + r_i \quad (3)$$

In equations (1-3) D_i is the diffusivity of compound i , z is the radial direction in spherical coordinates, S_i is the concentration of soluble compound i , r_i is the reaction rate for compound i , X_i is the concentration of particulate compound i , u_F is the biofilm net growth velocity, C_i is the concentration of generic compound i (it applies to both soluble and particulate compounds), Q_{in} and Q_{out} are the in- and outflow respectively, $j_{bio,i}$ is the flux in and out the biofilm and V is the reactor volume. The reaction rate expression is deduced from the Petersen matrix reported in Vangsgaard [15]. The distributed model has 12 state variables, namely: AOB, AnAOB, NOB, heterotrophic bacteria (HB), total ammonia nitrogen, total nitrite nitrogen, dissolved oxygen, nitrate, dinitrogen, readily biodegradable organic carbon, particulate organic material and particulate inert material. The modelled processes are: the growth and decay of AOB, NOB and AnAOB, the aerobic growth of HB and the anoxic growth of HB with both NO_2^- and with NO_3^- as electron acceptor, the decay of HB and the hydrolysis of organic suspended solids.

The operation of the reactor is arranged according to cycles of 8-hour duration. Each cycle is structured according to the following sequence of phases: anoxic feeding phase (10 minutes), alternate oxic/anoxic reaction phase (444 minutes), settling phase (6 minutes), decanting phase (10 minutes) and anoxic idle phase (10 minutes). The four-litre reactor has a cylindrical shape. Perfect control of temperature (30°C) and pH (7.5) are assumed during the operation. A synthetic influent was used characterized by a nominal ammonium concentration of 500 mg N.L⁻¹ while the ratio between the volume leaving the reactor at the end of the cycle and the maximal liquid volume in the reactor, namely the exchange ratio (ER), was maintained constant at 0.5. This resulted in a volumetric loading rate to the system of 750 mg N L⁻¹ d⁻¹.

Figure 1: Reactor configuration [15].

2.2 Fuzzy-logic Inference System Modelling

In this subsection a brief description about the generic operation of a FIS is presented.

Figure 2 shows the procedure according to which a generic FIS deduces the numerical values of its outputs (i.e. crisp outputs) starting from a set of crisp inputs. As can be seen, this procedure can be divided into three main subsequent operations:

- I) Fuzzification: a crisp input (u) is converted into fuzzy inputs (U) by the so-called “Fuzzifier”,
- II) Fuzzy Inference: The “Fuzzy Inference Engine” infers the fuzzy outputs (Y) on the basis of the values of U through the rules from the “Fuzzy rule base”,
- III) Defuzzification: the so-called “Defuzzifier” converts Y into a crisp output (y).

Figure 2: Simplified scheme of a fuzzy system [2].

For in-depth analyses about fuzzy system modelling, the work of Lababidi and Baker [2] should be consulted.

3. DEVELOPMENT OF FUZZY-LOGIC DIAGNOSIS AND CONTROL

As disclosed in the introduction, the aim of the present work is to develop a process-insight based control strategy for a CANR system to achieve a high and steady TN removal efficiency by adjusting the plant operation on the basis of the activity of the biomass. During the development of the control system, transparency and flexibility have also been considered as important features to be achieved. With the term “transparency”, it is meant that the task of describing the microbiological activity of the biomass can be carried out independently from the task of deciding the control actions to be carried out. By delegating these two operations to two different tools it is possible to identify the underlying cause i.e. a bottleneck that compromises the performance of the entire control system. Thus the design of the tool giving a low performance can be changed without conceptually modifying the design of the other tool. For this reason, the following two fuzzy-logic tools have been developed separately: a fuzzy-logic diagnosis (FLD), in charge of diagnosing the current activity of the biomass in the system, and a fuzzy-logic control (FLC), in charge of deciding, on the basis of the diagnosis results, the appropriate control actions to be taken. The procedures adopted are described in subsections 3.1 and 3.2.

3.1 Development of Fuzzy-Logic Diagnosis

Identification of the input and output variables. Based on stoichiometric analysis of CANR performance and on knowledge including a relationship between process performance and the microbiological state of the system, a decision tree for facilitating start-up of single-stage CANR systems was developed by Mutlu *et al.* [16]. As can be seen in Figure 3, the tree provides a screening of the activity of the CANR system on the basis of the values of the following parameters (defined in Figure 3 within rhombus-shaped boxes):

$$\text{Total nitrogen variation:} \quad \Delta \text{TN} = \text{TN}_{\text{eff}} - \text{TN}_{\text{in}} \quad (4)$$

$$\text{Ratio of } \text{NH}_4^+ \text{ consumed to TN removed:} \quad R_{\text{AmmTot}} = \left| \frac{\Delta(\text{NH}_4^+ - \text{N})}{\Delta \text{TN}} \right| \quad (5)$$

$$\text{Ratio of } \text{NO}_2^- \text{ produced to } \text{NH}_4^+ \text{ consumed:} \quad R_{\text{NitAmm}} = \left| \frac{\Delta(\text{NO}_2^- - \text{N})}{\Delta(\text{NH}_4^+ - \text{N})} \right| \quad (6)$$

$$\text{Ratio of } \text{NO}_3^- \text{ produced to TN removed:} \quad R_{\text{NatTot}} = \left| \frac{\Delta(\text{NO}_3^- - \text{N})}{\Delta\text{TN}} \right| \quad (7)$$

$$\text{NH}_4^+ \text{ removal efficiency:} \quad R_{\text{eff}} = 1 - \frac{(\text{NH}_4^+ - \text{N})_{\text{eff}}}{(\text{NH}_4^+ - \text{N})_{\text{in}}} \quad (8)$$

$$\text{Ratio between } \text{NO}_2^- \text{ and } \text{NH}_4^+ \text{ in the effluent:} \quad R_{\text{NitAmm,eff}} = \frac{(\text{NO}_2^- - \text{N})_{\text{eff}}}{(\text{NH}_4^+ - \text{N})_{\text{eff}}} \quad (9)$$

The variations used in the above equations refer to the difference between the specific nitrogen compound concentration in the effluent at the end of the cycle and the one in the influent at the beginning of the same cycle. Total nitrogen (TN) is given by the sum of nitrate, nitrite and ammonium nitrogen. Thus ΔTN in equation (4) is representing the nitrogen gas produced and the nitrogen contained in the biomass in the reactor [16].

An in-depth description of the meaning of the diagnosis variables in equations (5-9) and of their role in diagnosing the activity of the system biomass is provided in Mutlu *et al.* [16]. However, for the sake of completeness, a brief overview is presented:

In equation (5) R_{AmmTot} represents the amount of ammonium consumed with respect to the amount of TN removed.

- 1) In case R_{AmmTot} is low, which means high conversion of ammonium into dinitrogen with respect to the amount of ammonium removed, the balance of the microbial activity is further checked by the value of R_{eff} which enables knowing if there is a fair activity of AOB.
 - a. If R_{eff} is higher than 80%, the activity of the biomass is considered to be balanced.
 - b. Otherwise, a low AOB activity is detected.
- 2) If the value of R_{AmmTot} is too high, i.e. ΔTN is too low with respect to NH_4^+ removed, the activity is defined as unbalanced. As a matter of fact, it is possible that, although NH_4^+ is significantly removed, the activity of AnAOB is compromised and/or excessive NOB concentrations are formed and/or the activity of AOB is too high. Each of these three conditions can be the cause of low ΔTN over ΔNH_4^+ . To discriminate whether the imbalanced activity detected through R_{AmmTot} is given by NOB presence or not, the ratio of NO_3^- produced over ΔTN , represented in equation (7), is used. As a matter of fact, the parameter quantifies the amount of NO_3^- produced over the total nitrogen removed. The higher NOB activity is, the larger R_{NatTot} is. According to the values of R_{NatTot} , two scenarios can be identified:
 - a. if R_{NatTot} is lower than $0.16 \text{ g NO}_3^- \cdot \text{N} \cdot \text{g}^{-1} \text{ N-TN}$ (meaning no significant presence of NOB), R_{NitAmm} is then used to ascertain whether a nitrite accumulation is occurring or not as follows:
 - i. If R_{NitAmm} is low then a limited activity of AOB is diagnosed because the variable represents the ratio between nitrite produced and the ammonium consumed.
 - ii. if R_{NitAmm} is positive, then a problem of nitrite accumulation is detected because in a single-stage CANR reactor the nitrite produced by AOB should be subsequently consumed by AnAOB. In this case either too much nitrification or a limited activity of AnAOB would be the cause. To discriminate between these two situations the value of $R_{\text{NitAmm,eff}}$ (equation (9)), which defines the ratio between the NO_2^- and NH_4^+ in the effluent, is used. In particular, in case (ii.a) $R_{\text{NitAmm,eff}}$ is larger than 1.32, the fault of the imbalance is addressed to an excessive activity of AOB, otherwise (ii.b) to a limitation in the AnAOB activity, being that AOB produce NO_2^- while AnAOB consume it.

Figure 3: Diagnosis tree, adapted from Mutlu *et al.* [16].

Input variable centring and scaling. Before passing the inputs to the fuzzifier, the variables calculated through equations (5-9) were first centred and subsequently scaled. These two variable-handling procedures were performed in order to help defining the membership functions (MFs) shown in the subsequent paragraph more intuitively, thus allowing an easy implementation of the experience-acquired knowledge. As a matter of fact, centring the diagnosis inputs by subtracting their respective cut-off values used in the diagnosis tree (within the rhombus-shaped boxes in Figure 3) switches to “zero” the new cut-off value for all the variables. This is valid expect for R_{eff} , which was not centred in order to preserve its own physical meaning of efficiency. Once centred, each variable was divided by a scaling factor. This served the purpose of making the numerical distributions of the input values uniform. Thus the MFs of the different variables could have been defined symmetrically. As resulted from these two operations, the variation range for all the crisp FIS inputs became [-1 1], apart from R_{eff} whose range remained [0 1].

Fuzzification. The membership functions for the input variables were chosen based on expert knowledge. Following as example the successful applications by Comas *et al.* [17], Garcia *et al.* [18] and Yong *et al.* [19],

trapezoidal and triangular shapes were here chosen for the MFs for the sake of simplicity as can be seen in Figure 4.

In order to illustrate the generic methodology adopted to define the MFs for the diagnosis inputs, the definition of membership functions for the ammonium removal efficiency (R_{eff}) is here shown as an example in Figure 4e.

Relying on process knowledge acquired during experiments, R_{eff} can be considered with 100% probability to belong to the linguistic set:

- “low” for values lower than 0.3
- “medium” when it is equal to 0.5,
- “high” when it is equal to 1.

With 100% probability R_{eff} is considered NOT belonging to the linguistic set:

- “low” when it is equal or higher than 0.5,
- “medium” for values equal or lower than 0.2 and equal or larger than 0.8,
- “high” for values below 0.5.

To all the values of R_{eff} , when 100% is the probability that the variable itself belongs to a linguistic set (i.e. 100% probability the R_{eff} is “low”, “medium” and “high”), then a degree of membership of one (y-axis) is assigned. To all the values of R_{eff} , when 100% is the probability that the variable itself does not belong to a linguistic set (i.e. 100% probability the R_{eff} is “non-low”, “non-medium” and “non-high”), a degree of membership of 0 is assigned. To those values whose probability of membership to a certain fuzzy set is between 0% and 100%, the degree of membership varies linearly between these two values.

The decision of having a more or less soft interchange between two fuzzy sets of an input variable is based on experiences with process operation and understanding as well as on the desired behavior of the controller. In particular, for the definition of the membership functions (MFs) of each input variable the following property was taken into account: the higher the slope of a membership function of a control input variable is, the faster (relatively) the control action will be in response to changes in the input itself. For example, in the case of R_{AmmTot} , (scaled and centered) values with probability to be “Very High” are highly undesired from process operation point of view, while values in the range of “CANR” and/or “High” are considered to be fine. This is because, as can be deduced from the diagnosis tree in Figure 3, too high values of this variable would surely mean an imbalanced activity of the biomass (too high/low AOB activity and/or limited AnAOB activity and/or too much nitrification). This implies that, when R_{AmmTot} grows towards the region of the fuzzy set “Very High”, the control action should be very fast in taking a control action to which a rapid decrease of R_{AmmTot} would correspond. By setting the slopes of MFs steeper in the region between the fuzzy sets “High” and “Very High”, the interchange between these two fuzzy sets is sensitized more and therefore emphasized more. Thus when R_{AmmTot} increases in that region (within the range [0.6 1]), the transition from the fuzzy set “High” to the fuzzy set “Very High” goes more rapidly and, in response to this, the controller will react faster.

Figure 4: Membership functions of FLD inputs: (a) R_{AmmTot} , (b) R_{NatTot} , (c) R_{NitAmm} , (d) $R_{NitAmm,eff}$ and (e) R_{eff} .

Fuzzy inference. The IF-THEN rules were deduced from the diagnosis tree in Figure 3. Look-up tables including these rules are presented altogether in Table 1. The Mamdani-type inference was chosen for the sake of simplicity as the definition of Sugeno-type inference rules requires too specific knowledge for the consequent part of the rule. The rules have the same importance with each other. Hence the same weights were assigned to all the rules. The implication method used when inferring from each rule a degree of membership for the related output variables was the correlation-minimum while disjunctive was the aggregation method chosen in order to sum up all the degrees of membership for the same output variables into one.

As outputs from this module, degrees of membership for each fuzzy set of each output are found.

Table 1: Fuzzy-logic diagnosis rules: (a) Output 1 = CANR performance index, (b) Output 2 = Nitritation, (c) Output 3 = AnAOB activity and (d) Output 4 = Nitratation.

Legend: VH=Very High, H=High, M=Medium, L=Low VL=Very Low, NL=Non-Limited, L=Limited and AZ=Almost Zero.

(a)

$\downarrow R_{eff} / R_{AmmTot} \rightarrow$	L	H	VH
H	VH	H	L
M	OK	OK	L
L	L	L	L

(b)

IF [R_{AmmTot} not Low] AND [R_{NatTot} Low] AND				
$\downarrow R_{NitAmm,eff} / R_{NitAmm} \rightarrow$	VL	L	H	VH
L	VL	L	OK	OK
H	VL	L	H	VH

IF [R _{AmmTot} = Low] AND			
↓R _{AmmTot} / R _{Eff} →	H	F	L
L	OK	L	VL

(c)

IF [R _{AmmTot} not Low] AND [R _{NatTot} = Low] AND				
↓R _{NitAmm,ef} / R _{NitAmm} →	VL	L	H	VH
L	NL	NL	L	L
H	NL	NL	NL	NL

IF [R_{AmmTot} is Low] OR [R_{NatTot} not Low], THEN [AnAOB activity = NL]

(d)

↓R _{NatTot} / R _{AmmTot} →	L	H	VH
L	AZ	AZ	AZ
H	AZ	L	H
VH	AZ	H	VH

Defuzzification. The MFs shown in Figure 5 have been used for the FLD outputs. Similarly to those used for fuzzification, these functions were also defined with trapezoidal and triangular shapes. Theoretically the definition of these MFs could be done arbitrarily since the variables at issue do not have a physical meaning but a quality-descriptive one. However, to check the performance of the FLD, its outputs have to be interpreted easily. For this purpose, low numerical values of CANR performance index, nitrification and nitrataion (x-axis) belong to linguistic sets indicating low performance and/or low activity. On the other hand, high numerical values of the same variables were assigned to linguistic sets indicating high performance and/or high activity. The exception is the variable “AnAOB activity” to which an intrinsic meaning of “AnAOB activity limitation” was attributed. In this case, high numerical values are representative of higher limitation whereas low values represent low limitation. By defining the membership functions for the FLD outputs in this way, the interpretation of the diagnosis performance resulted intuitively.

The conversion of the degrees of membership (y-axis) for each FLD output found through the rules into a single numeric (crisp) value (x-axis) was chosen to be performed according to the Centre-Of-Area method. This choice was made in virtue of its characteristics of continuity and non-ambiguity mentioned in Helledoorn and Thomas [20].

Figure 5: Membership functions for fuzzy-logic diagnosis outputs: CANR performance index (a), Nitritation (b), AnAOB activity (c) and Nitratation (d).

3.2 Development of Fuzzy-Logic Control

Identification of the input and output variables. The fuzzy-logic control input variables correspond to the fuzzy-logic diagnosis output variables as its work is to infer control actions on the basis of the diagnosed biological activity. Thus *the activity of aerobic AOB, AnAOB and NOB and CANR performance index* are identified as inputs. On the basis of their values, the fuzzy-logic control will infer the deviation of the manipulated variables (MVs) chosen from their respective nominal values. In order to identify the MVs a degree of freedom analysis was performed according to Larsson and Skogestad [21]. On the basis of this analysis the following four manipulated variables were considered as potential candidates: the mixer, the electrical heating jacket, the air supply and the exchange ratio (ER). The heating jacket is assumed to perfectly control the temperature. The mixer was not considered as a suitable MV due to a lack of mechanistic knowledge relating the mixing conditions to the process performance. ER was controlled at 0.5. For this reason the only MV chosen to control the process performance metric was the air supply, modelled as the oxygen mass transfer coefficient (k_La). The deviation of this MV (Δk_La) represents therefore the actual output of the FLC.

Fuzzification. The same MFs used for the defuzzification in FLD (shown in Figure 5) were used to find the probability of membership to the fuzzy sets for each input.

Fuzzy inference. Similarly to the FLD, also for this tool the Mamdani-type inference was used. The same importance degree was attributed to all of the IF-THEN rules. Correlation-minimum and disjunction were the methods chosen for the implication and aggregation operations respectively. Since the AnAOB activity is intrinsically linked with balanced nitritation and nitratation, ensuring a balanced activity of AOB and NOB implies ensuring a balanced AnAOB activity. Hence including rules for changes of the k_La in order to have balanced nitritation and nitratation can be considered sufficient to avoid AnAOB limitation. Thus, in order not to overload the control system with additional and superfluous rules, no direct rule linking k_La variation with AnAOB activity was taken into account. In the following look-up table the list of control rules used is presented.

Table 2: Fuzzy-logic control rules.

Legend: Z=zero; PL=Positive Large, P=Positive, N=Negative; NL=Negative Large, VG=Very Good;

↓Nitritation/CANR index →	VG	OK	M	LOW
VL	<i>P</i>	<i>P</i>	<i>PL</i>	<i>PL</i>
L	<i>Z</i>	<i>Z</i>	<i>P</i>	<i>P</i>
M	<i>Z</i>	<i>Z</i>	<i>Z</i>	<i>Z</i>
H	<i>Z</i>	<i>Z</i>	<i>N</i>	<i>N</i>
VH	<i>N</i>	<i>N</i>	<i>NL</i>	<i>NL</i>
↓Nitratation/CANR index→	VG	OK	M	LOW
AZ	<i>Z</i>	<i>Z</i>	<i>Z</i>	<i>Z</i>
L	<i>N</i>	<i>N</i>	<i>N</i>	<i>N</i>
H	<i>N</i>	<i>NL</i>	<i>NL</i>	<i>NL</i>
VH	<i>NL</i>	<i>NL</i>	<i>NL</i>	<i>NL</i>

Defuzzification. The MFs of the k_La deviation were shaped as trapezoidal and triangular as the MFs in the diagnosis. In Figure 6 the MFs of this variable are depicted. Similarly to the FLD, the method used to deduce a crisp value on the basis of the degrees of membership for each fuzzy sets of “ k_La deviation” was the Centre-Of-Area.

Figure 6: Membership functions of fuzzy-logic control output (k_La variation).

Output variable scaling. The crisp values obtained for k_La deviation from defuzzification are then scaled by multiplying the values by 150 d^{-1} .

4. RESULTS AND DISCUSSION

The block diagram of the fuzzy logic diagnosis and control system implementation to control the CANR system is given in Figure 7.

Figure 7: Structure of the fuzzy logic diagnosis and control system (FLD=Fuzzy-Logic Diagnosis, FLC=Fuzzy-Logic Control, S=Sensors).

As can be seen in Figure 7, the concentration of ammonium is measured both in the influent and in the effluent along with the effluent nitrite and nitrate concentrations. The sampling was done at the beginning of each cycle for the compounds in the influent and at the end of each cycle for those in the effluent. In this context, measurement noises were not taken into account assuming their negligible influence in the context of a fuzzy-logic control where the measured (crisp) variables are handled in a fuzzified environment. The measured values obtained were then used to calculate the FLD inputs, namely R_{AmmTot} , R_{NatTot} , R_{NitAmm} , $R_{NitAmm,eff}$ and R_{eff} . These inputs, after preliminary centring and scaling, were then handed over to the FLD tool which inferred the CANR performance index, Nitritation, AnAOB activity and Nitratation. At this point it is worth noting that the FLD outputs are called variables, although they have a quality-descriptive meaning rather than a physical meaning. As a matter of fact, they depict altogether the microbiological activity of the biological system. On the basis of their crisp values deduced by the FLD, the FLC is then able to infer the variations of the manipulated variable (k_La) from their respective nominal values. This control action takes place at the beginning of the reaction phase of the next cycle.

More in detail, the procedure according to which the proper control actions are calculated on the basis of the measurements is summarized in the following sequential steps:

- I. Calculation of the crisp values for the diagnosis input variables: parameters R_{AmmTot} , R_{NatTot} , R_{NitAmm} , $R_{NitAmm,eff}$ and R_{eff} are calculated through equations (5-9) by using the measured concentration of nitrogen species in the liquid phase,
- II. Centring and scaling of the diagnosis input variables: the parameters calculated in I are centred according to their respective cut-off values given in the tree-like scheme of Figure 3 and scaled,
- III. Fuzzy-logic Diagnosis: crisp values for CANR performance index, Nitritation, AnAOB activity and Nitratation are inferred on the basis of the crisp values of the centred and scaled R_{AmmTot} , R_{NatTot} , R_{NitAmm} , $R_{NitAmm,eff}$ and R_{eff} ,
- IV. Fuzzy-logic Control: crisp values for Δk_La are inferred on the basis of crisp values for CANR performance index, Nitritation, AnAOB activity and Nitratation given by III,
- V. Scaling of Fuzzy-logic Control outputs: the crisp values of Δk_La are multiplied by their respective nominal values.

VI. Calculation of the actual k_La as input to the reactor: Addition of the scaled Δk_La to their respective nominal values (i.e. $k_{La}(t) = k_{La0} + \Delta k_{La}$).

Step III, namely fuzzy logic diagnosis, can be further split up into the following sub-steps:

IIIA. Diagnosis fuzzification: the crisp scaled and centred inputs R_{AmmTot} , R_{NatTot} , R_{NitAmm} , $R_{NitAmm,eff}$ and R_{eff} are converted into input fuzzy sets by means of the MFs shown in Figure 4,

IIIB. Diagnosis inference: the fuzzy outputs are generated from the corresponding input fuzzy sets on the basis of the rules in Table 1,

IIIC. Diagnosis defuzzification: the fuzzy outputs (CANR performance index, Nitrification, AnAOB activity and Nitrification) obtained in IIIB are then translated into numerical values for CANR performance index, Nitrification, AnAOB activity and Nitrification through the Centre-of-Area method applied on the MFs shown in Figure 5.

Step IV, namely fuzzy logic control, can be further split up into the following sub-steps:

IVA. Controller fuzzification: the crisp values for CANR performance index, Nitrification, AnAOB activity and Nitrification obtained from sub-step IIIC are converted into input fuzzy sets by means of the same MFs used for IIIC,

IVB. Controller inference: the fuzzy inputs obtained in IVA are transformed into control fuzzy outputs according to the set of rules in Table 2,

IVC. Controller defuzzification: the controller fuzzy outputs (variation of k_La) are converted into their respective crisp values by applying the Centre-of-Area method on the MFs shown in Figure 6.

Table 3 sums up the input and output variables of the diagnosis and control tools.

Table 3: Fuzzy-logic diagnosis inputs (a) and outputs (b) and control outputs (c)..

(a)				
FLD INPUT 1	FLD INPUT 2	FLD INPUT 3	FLD INPUT 4	FLD INPUT 5
R_{AmmTot}	R_{NitAmm}	R_{NatTot}	$R_{NitAmm,eff}$	R_{eff}

(b)			
FLD OUTPUT 1	FLD OUTPUT 2	FLD OUTPUT 3	FLD OUTPUT 4
CANR performance index	Nitrification	AnAOB activity	Nitrification

(c)
FLC OUTPUT
Δk_{La}

Since FLD and FLC are independent tools, it is possible to separately evaluate the performance of each model as will be done in subsection 4.1 and 4.2.

4.1 Evaluation of the diagnosis tool

Since the control actions are based on the FLD outputs, a first check on the reliability of the outputs generated by the FLD is performed. To this end, data obtained from 100-day experimentation on the lab-scale reactor described in subsection 2.1 were used. It is noted that the data were obtained from a period where the system was operated in a manual operating mode following the operation protocol given by Mutlu *et al.* [16]. Hence these data serve for the purpose of evaluating the performance diagnosis module alone. In Figure 8, the effluent concentrations of the three nitrogen species (i.e. ammonium, nitrate and nitrite) collected during the experiments and the related total nitrogen removal efficiency are depicted. By using these data as inputs to the diagnosis module, the FLD outputs plotted in Figure 9 are obtained.

Figure 8: Input data set to FLD module: effluent nitrogen species concentration (on the left: NH₄⁺ (red), NO₃⁻ (green) and NO₂⁻ (blue)) and TN removal efficiency (on the right).

Figure 9: Output from FLD module: results of the fuzzy-logic diagnosis for 100 days.

As can be seen in Figures 8 and 9, the total duration of the experiment can be split up into four subsequent periods identified on the basis of the different behaviours of the biomass: from the beginning of the experiment till day 40, from day 40 till day 60, from day 60 till day 80 and from day 80 till the end.

By looking at Figure 9, the activity of the AnAOB is limited by high nitrataion during the first period. This is because, as revealed in Figure 9d, the NOB activity is so high that the availability of NO₂⁻ for AnAOB is

significantly reduced. As a result of this undesired imbalance (i.e. the $\text{NO}_2^- : \text{NH}_4^+$ ratio), the performance is mostly unsatisfactory, as can be seen from the CANR performance index. By following the operation protocol in manual mode, during the second period the O_2 supply rate to the system was decreased. This operation helped AOB to successfully outcompete or reduce the NOB activity in the system – a desirable condition for promoting AnAOB activity and therefore achieving higher performance [16], as described by the CANR performance index. During the subsequent period of time, as a consequence of low oxygen availability due to a continuous decrease of air supply, NOB activity became negligible which in turn allowed AnAOB activity. However, also AOB activity got compromised and consequently the performance of the system decreased, as diagnosed by the CANR performance index. In the last period, a higher oxygen supply temporarily re-established nitrification to medium levels. In response to a higher ammonium oxidation, the system performance became satisfactory.

In order to evaluate the reliability of the diagnosis results, a comparison is made between the scenario described by the diagnosis outputs on the one hand, and the effluent concentrations of the nitrogen species measured and the calculated TN removal efficiency on the other hand. As can be seen in Figure 8a, NO_2^- in the first period is high (40-100 mg N.L⁻¹) compared to its concentration in the other periods. This is the result of its lacking consumption by AnAOB. As a matter of fact, when the nitrite concentration drops down to negligible values, the AnAOB activity is diagnosed as non-limited. Hence the FLD tool can be said to describe the activity of AnAOB in a realistic way.

The effluent NO_3^- concentrations measured during the first period are low (around 8 mg N.L⁻¹) compared to the concentration of the same compound in the other periods (around 20 mg N.L⁻¹). Although this may appear to be inconsistent with the diagnosed NOB activity, it has to be pointed out that the qualitative description of the different classes of biomass is in function of the purpose of the system, which is to remove a high percentage of nitrogen. Thus the qualitative description of NOB activity is a function of the capability of their interference with the system performance. For this reason, since the diagnosis results regarding AnAOB limitation and NOB activity are consistent with each other (i.e. for high NOB activity, AnAOB are limited and vice versa), nitrification can be considered to be described correctly by the FLD.

Particularly evident is the correlation between effluent ammonium concentrations and the aerobic activity of AOB diagnosed. As can be noted in Figure 9b and Figure 8a, an increase of effluent NH_4^+ concentration corresponds to a decrease in AOB activity. Hence the FLD tool realistically describes the aerobic activity of AOB.

The tool performs reliably, also in terms of overall system performance description, as the CANR performance index follows the TN removal efficiency time dynamics throughout the experimentation period.

Given these considerations, the results of the diagnosis can be considered reliable enough for the FLC to infer proper control actions.

4.2 Evaluation of the control tool

The system shown in Figure 7 was implemented in Simulink in order to test its capability to achieve the control objective, namely high and steady TN removal efficiency. The control performance evaluation was done by simulating the implemented model with a step input disturbance on the ammonium concentration in the feed for a period of 18 days. The change was imposed to occur when the batch cycles were approximately steady, that is after 10 days counting from the beginning of the simulation. The initial conditions were taken from a steady state solution of an equivalent continuous reactor. In Figure 10 the microbiological state of the system biomass diagnosed is screened by plotting the dynamics of the FLD outputs. The difference between the concentrations of total nitrogen fed at the beginning of the cycle and at the end of the same cycle was divided by the concentration of TN fed at the beginning of the cycle to obtain the TN removal efficiency plotted in Figure 11. Since the production of nitrogen gas is indicative of the removal efficiency, the nitrogen gas concentration in the reactor is also shown. Figure 12a depicts the dynamics of the nitrogen species concentration in the reactor effluent at the end of each cycle. The change of the manipulated variable, i.e. oxygen mass transfer coefficient, throughout the simulation period is shown in Figure 12b.

As can be noted in Figure 11, the system gets approximately stabilized within 4 days. The TN removal efficiency prior to the step change was already at a very high level at around 93%. As a result of the immediate increase of ammonium in the feed at the 10th day, the concentration of NH_4^+ in the effluent increases (Figure 12a) and, consequently, the CANR performance index drops down (Figure 10a). Corresponding to this, the TN removal efficiency drops down to a minimum of 86%. The controller reacts to this scenario by increasing the k_1a (Figure 12b) to a value at around 250 d⁻¹. Thus the removal efficiency performance is increased and established at a higher stable value of 89% and returns to the area where the CANR performance index is very good. Given that, according to the diagnosis, the system operates in the desired range, the controller then stops changing the aeration flow.

In order to further increase the removal efficiency, the definition of the linguistic variable “very good CANR performance index” must be restricted to higher values. However, trying to operate at so high removal efficiencies despite disturbances comes with a disadvantage, since it increases the risk of occurrence of nitrataion. Hence, the controller is able to reject the disturbance on the ammonium influent loading while keeping the microbial activity balanced.

Figure 10: Diagnosis outputs from the simulation of a controlled system with a +10%-step-change disturbance in the influent ammonium concentration 10 days after the start of the simulation.

Figure 11: Dynamics of total nitrogen removal efficiency (blue line, red crosses) and N_2 concentration in the reactor (dark-green line, black crosses) with a +10%-step-change disturbance in the influent ammonium concentration at day 10.

Figure 12: (a) Dynamics of nitrogen species concentration in the effluent (left graph: NH_4^+ (green crosses), NO_3^- (red crosses) and NO_2^- (blue crosses)) and (b) dynamic trend of oxygen mass transfer coefficient ($k_L a$) (right graph) with a +10%-step-change disturbance in the influent ammonium concentration at day 10.

5. CONCLUSIONS

During this work, the performance of a granular CANR system has been upgraded through the implementation of a fuzzy-logic control aided by a fuzzy-logic diagnosis. The long term real process data obtained from operation of a lab-scale reactor was used to verify the fuzzy-logic diagnosis module. Next, the fuzzy-logic control module was tested and evaluated using dynamic simulations and has shown to achieve high and stable nitrogen removal efficiency (around 90%). The originality of the proposed control structure is that the fuzzy-logic control uses the valuable information

about the microbiologic state of the system that has been deduced from macro-measurements using process stoichiometry contributions by different microbial groups.

The fact that the fuzzy-logic diagnosis tool is developed and used separately from the fuzzy-logic control augments the value of the present work in terms of transparency and flexibility. Transparency is gained because the user can see the diagnosis output as well as controller outputs. The performance of the FLD can therefore be checked independently from the actions of the FLC. For the users, this in turn allows easy maintenance and further enhancement of the diagnosis and control modules in case the control performance needs improvement.

Future work consider further refinement of fuzzy logic controller tuning as well as extension of the knowledge base and rules for the control of greenhouse gas emissions, in particular N₂O, from CANR systems.

6. ACKNOWLEDGEMENT

This research is funded, in part, by the Danish Agency for Science, Technology and Innovation through the Research Centre for Design of Microbial Communities in Membrane Bioreactors (09-067230). The first author also acknowledge The Danish Council for Strategic Research (Det Strategiske Forskningsråd)

REFERENCES

- [1] A.M. Saunders, P. Larsen, P.H. Nielsen, Comparison of nutrient-removing microbial communities in activated sludge from full-scale MBRs and conventional plants., *Water Sci. Technol.* 68 (2013) 366–371.
- [2] H.M.S. Lababidi, C.G.J. Baker, Fuzzy Modeling, in: *Handb. Food Bioprocess Model. Tech.*, 2006: pp. 451–498.
- [3] Y. Bai, D. Wang, Fundamentals of Fuzzy Logic Control – Fuzzy Sets , Fuzzy Rules and Defuzzifications, in: *Adv. Fuzzy Log. Technol. Ind. Appl.*, 1982: pp. 17–36.
- [4] E.I.P. Volcke, Modelling , analysis and control of partial nitrification in a SHARON reactor, PhD thesis, Ghent University, 2006.
- [5] U. Van Dongen, M.S.M. Jetten, M.C.M. Van Loosdrecht, The SHARON(R)-Anammox(R) process for treatment of ammonium rich wastewater, *Water Sci. Technol.* 44 (2001) 153–160.
- [6] S. Lackner, E.M. Gilbert, S.E. Vlaeminck, A. Joss, H. Horn, M.C.M. van Loosdrecht, Full-scale partial nitrification/anammox experiences - An application survey, *Water Res.* 55 (2014) 292–303.
- [7] E.I.P. Volcke, S.W.H. Van Hulle, M.C.M. Van Loosdrecht, A. Peter, Generation of Anammox-optimal nitrite : ammonium ratio with SHARON process : usefulness of process control ?, in: *9th Spec. Conf. Des. Oper. Econ. Large Wastewater Treat.*, 2003: pp. 1–4.
- [8] H. De Clippeleir, X. Yan, W. Verstraete, S.E. Vlaeminck, OLAND is feasible to treat sewage-like nitrogen concentrations at low hydraulic residence times., *Appl. Microbiol. Biotechnol.* 90 (2011) 1537–1545.
- [9] X. Hao, J.J. Heijnen, M.C.M. Van Loosdrecht, Model-based evaluation of temperature and inflow variations on a partial nitrification-ANAMMOX biofilm process., *Water Res.* 36 (2002) 4839–4849.
- [10] S. Lackner, C. Lindenblatt, H. Horn, “Swinging ORP” as operation strategy for stable reject water treatment by nitrification–anammox in sequencing batch reactors, *Chem. Eng. J.* 180 (2012) 190–196.
- [11] A. Joss, N. Derlon, C. Cyprien, S. Burger, I. Szivak, J. Traber, et al., Combined nitrification-anammox: advances in understanding process stability., *Environ. Sci. Technol.* 45 (2011) 9735–9742.
- [12] H. Bürgmann, S. Jenni, F. Vazquez, K.M. Udert, Regime shift and microbial dynamics in a sequencing batch reactor for nitrification and anammox treatment of urine., *Appl. Environ. Microbiol.* 77 (2011) 5897–5907.

- [13] M. Mauricio-Iglesias, A.K. Vangsgaard, K. V Gernaey, G. Sin, A fuzzy-logic based diagnosis and control of a reactor performing complete autotrophic nitrogen removal, In IFAC Proceedings Volumes (IFAC-PapersOnline) 12 (PART 1), pp. 199-204.
- [14] A.K. Vangsgaard, M. Mauricio-Iglesias, K. V Gernaey, B.F. Smets, G. Sin, Sensitivity analysis of autotrophic N removal by a granule based bioreactor: Influence of mass transfer versus microbial kinetics., *Bioresour. Technol.* 123 (2012) 230–241.
- [15] A.K. Vangsgaard, Modeling , Experimentation , and Control of Autotrophic Nitrogen Removal in Granular Sludge Systems, PhD thesis, Technical University of Denmark, 2013.
- [16] A.G. Mutlu, A.K. Vangsgaard, G. Sin, B.F. Smets, An operational protocol for facilitating start-up of single-stage autotrophic nitrogen-removing reactors based on process stoichiometry, *Water Sci. Technol.* 68 (2013) 514–521.
- [17] J. Comas, I. Rodríguez-Roda, K.V. Gernaey, C. Rosen, U. Jeppsson, M. Poch, Risk assessment modelling of microbiology-related solids separation problems in activated sludge systems, *Environ. Model. Softw.* 23 (2008) 1250–1261.
- [18] C. Garcia, F. Molina, E. Roca, J.M. Lema, Fuzzy-Based Control of an Anaerobic Reactor Treating Wastewaters Containing Ethanol and Carbohydrates, *Ind. Eng. Chem. Res.* 46 (2007) 6707–6715.
- [19] M. Yong, P. Yong-zhen, W. Xiao-lian, W. Shu-ying, Intelligent control aeration and external carbon addition for improving nitrogen removal, *Environ. Model. Softw.* 21 (2006) 821–828.
- [20] H. Hellendoorn, C. Thomas, Defuzzification in Fuzzy Controllers, *J. Intell. Fuzzy Syst.* 1 (1993) 109–123.
- [21] T. Larsson, S. Skogestad, Plantwide control — A review and a new design procedure, *Model. Identification Control.* 21 (2000) 209–240.