

A Helium-Technique Experimental Study of Longitudinal Ventilation Control in Sloped, Small-Scale Tunnels

Alva, Wilson Ulises Rojas; Jomaas, Grunde; Dederichs, Anne

Published in: Proceedings from the Seventh International Symposium on Tunnel Safety and Security

Publication date: 2016

Document Version Publisher's PDF, also known as Version of record

Link back to DTU Orbit

Citation (APA): Alva, W. U. R., Jomaas, G., & Dederichs, A. (2016). A Helium-Technique Experimental Study of Longitudinal Ventilation Control in Sloped, Small-Scale Tunnels. In *Proceedings from the Seventh International Symposium on Tunnel Safety and Security* (pp. 689-690)

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

• Users may download and print one copy of any publication from the public portal for the purpose of private study or research.

- · You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

A Helium-Technique Experimental Study of Longitudinal Ventilation Control in Sloped, Small-Scale Tunnels

<u>W.U. Rojas Alva</u>, Grunde Jomaas & Anne S. Dederichs Department of Civil Engineering, Technical University of Denmark Brovej, Building 118, 2800 Kgs. Lyngby, Denmark E-mail: <u>wura@byg.dtu.dk</u>

KEYWORDS: Critical velocity, longitudinal velocity, confinement velocity, backlayering distance, tunnel slope.

INTRODUCTION

There is limited knowledge on how the slope of a tunnel can affect the smoke movement during a fire and thus how the longitudinal ventilation should be controlled. Only very few of the previous reported studies [1–3] consider the slope of the tunnel and how it affects the critical velocity, the backlayering distance and its corresponding longitudinal velocity. Based on the helium-air technique developed by Mégret & Vauquelin [3–5], several experiments in a small-scale rig (scale 1/30 of a tunnel with a section of 6 m by 9 m in full-scale) were conducted in order to study the critical velocity, backlayering distance and longitudinal velocity (confinement velocity) in a tunnel with slope. Several heat release rates were studied, ranging from 0.42-2.6 MW, under two slopes directions (uphill and downhill), and for several slope degrees.

THEORETICAL BACKGROUND

In order to reproduce several phenomena from a full-scale fire to a densimetric small-scale fire, three stages are required: first, a set of formulae based on a semi-empirical model [6] to quantify the parameters that have to be scaled down; second, the application of two sets of scaling principles based on dynamic similarities (Froude modelling) and thermal/densimetric analogy, and third and last the equivalence of the corresponding scaled smoke flow rate to a gas densimetric buoyant mixture of helium-air [5]. The experimental rig and method was validated against full-scale date for a range of 0.42-31 MW to ensure that the method met the theoretical requirement for high fidelity results.

EXPERIMENTAL PROCEDURE

A 4.7 m long model tunnel was designed to allocate a buoyant source of helium-air mixture into the model tunnel section, see Figure 1, and to allow the quantification of the involved parameters and phenomena. Furthermore the experimental rig allowed a wide range of simulated heat release rates, and it also allows for the presence of vehicular blockage. Finally, the modular wall and ceiling construction permits modification of the tunnel slope and the tunnel geometry, making the set-up ideal for parametric studies.



Figure 1 – Schematic view of the experimental set-up.

The buoyant mixture of helium and air gases are supplied at several flow rates, depending on the heptane pool fire size and hence the fire size. Both gases were supplied from 50 l cylinders and regulated through Bronkhorst mass flow controllers (MFC). In order to overcome the disadvantage of

the colourless buoyant mixture, the flow was seeded in a plenum box with mineral oil particles released from a fog generator. The longitudinal ventilation system was activated when the buoyant plume filled up the small-scale tunnel section, the system consisted in extracting the buoyant mixture with an axial fan (K100M) located at the end of one of the portals. A potentiometer connected to the fan allowed the regulation of the longitudinal flow. Finally an anemometer (VT100E) was used to measure the longitudinal air velocity in the middle of the model tunnel and at several locations; hence an average value was estimated.

THE CASE STUDY

A detailed experimental matrix is shown in Table 1, which contains three sets of experiments; in Set 1 the tunnel had no slope and was aimed to validate the tunnel model and the method, whereas Set 2 and Set 3 had 3% and 6% tunnel slope, respectively. For all sets the tunnel dimensions represented a full-sized tunnel with 9 m width and 6 m height, and the longitudinal ventilation control was studied uphill and downhill. One "X" means that only the critical velocity was measured, whereas "XX" means that the backlayering distance and its corresponding longitudinal velocity were measured in a first experiment, and the critical velocity in a second experiment.

Source diameter (mm)	HRR (MW)	SET 1	SET 2		SET 3	
		0 % tunnel	3 % tunnel slope		6 % tunnel slope	
			Uphill	Downhill	Uphill	Downhill
20.7	0.42	XX	XX	XX	Х	XX
26.0	0.78	XX	XX	XX	XX	XX
28.0	0.96	XX	XX	XX	Х	XX
34.0	1.61	XX	Х	Х	XX	XX
41.0	2.62	XX	Х	Х	XX	XX

	Table 1 – An ov	verview of the	<i>experiments that</i>	were carried out for	or several scenarios.
--	-----------------	----------------	-------------------------	----------------------	-----------------------

CONCLUSION AND FURTHER WORK

The current method and experimental set-up have been able to reproduce several phenomena in a sloped model tunnel with two orientations (uphill and downhill). Moreover the model has been validated against full-scale data for a certain range of heat release rate, from 0.42 to 31 MW. The tunnel slope seems to have an influence on the critical velocity and backlayering distance, depending on the slope direction, uphill or downhill, where the latter affects the backlayering distance to a greater extent. However, further experiments are required to be executed with higher slope and larger HRR.

The experimental set-up has the advantage to allow a great modularity and thus several scenarios can potentially be studied. Further experiments are planned that include three stages: confinement velocity, tunnel slope and transversal ventilation control.

REFERENCES

- G.T. Atkinson, Y. Wu, Smoke Control in Sloping Tunnels, Fire Saf. J. 27 (1996) 335–341. doi:S0379-7112(96)00061-6.
- [2] W.K. Chow, K.Y. Wong, W.Y. Chung, Longitudinal ventilation for smoke control in a tilted tunnel by scale modeling, Tunn. Undergr. Sp. Technol. 25 (2010) 122–128. doi:10.1016/j.tust.2009.10.001.
- [3] O. Vauquelin, Parametrical study of the back flow occurrence in case of a buoyant release into a rectangular channel, Exp. Therm. Fluid Sci. 29 (2005) 725–731. doi:10.1016/j.expthermflusci.2005.01.002.
- [4] O. Megret, O. Vauquelin, A reduced scale tunnel for the study of fire-induced smoke control, 1998.
- [5] O. Megret, Etude expérimentale de la propagation des fumées d'incendie en tunnel pour différents systèmes de ventilation," PhD Thesis, University of Valencienne, France, 1999.
- [6] O. Mégret, O. Vauquelin, A model to evaluate tunnel fire characteristics, Fire Saf. J. 34 (2000) 393–401. doi:10.1016/S0379-7112(00)00010-2.