



Influence of feed composition and membrane fouling on forward osmosis performance

Schneider, Carina; Sathyadev Rajmohan , Rajath ; Zarebska, Agata; Hélix-Nielsen, Claus

Published in:
16th Nordic Filtration Symposium 2016: Book of abstract

Publication date:
2016

Document Version
Publisher's PDF, also known as Version of record

[Link back to DTU Orbit](#)

Citation (APA):
Schneider, C., Sathyadev Rajmohan , R., Zarebska, A., & Hélix-Nielsen, C. (2016). Influence of feed composition and membrane fouling on forward osmosis performance. In *16th Nordic Filtration Symposium 2016: Book of abstract* Lappeenranta University of Technology Press .

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Influence of feed composition and membrane fouling on forward osmosis performance

Carina Schneider^a, Rajath Sathyadev Rajmohan^a, Agata Zarebska^a, Claus Hélix-Nielsen^{a,b}

a Technical University of Denmark, Department of Environmental Engineering, Bygningstorvet, Building 115, 2800 Kgs. Lyngby, Denmark

b University of Maribor, Laboratory for Water Biophysics and Membrane Processes, Faculty of Chemistry and Chemical Engineering, Smetanova ulica 17, 2000 Maribor, Slovenia

Keywords

Forward osmosis, biomimetic membrane, fouling, wastewater treatment

Abstract

Clean water is a basic human need. However, rapid population growth and climate change result in an increase of water demand, whereas the resources of potable water are shrinking. One of the solutions could be to use membrane technology to reclaim clean and safe drinking water from wastewater. Nonetheless, the existing membrane technologies often face fouling problem that lowers the economic viability of the membrane application in industrial scale.

Recent development in the membrane technology indicates that forward osmosis (FO) has a high potential for wastewater treatment, producing high quality water [1]. Compared to other pressure driven membrane processes, forward osmosis (FO) membranes suffered less severe fouling due to the lack of hydraulic pressure [2]. Furthermore, novel biomimetic membranes incorporating Aquaporins, highly selective water channels, became commercially available. These membranes were reported to achieve remarkable results in terms of water flux and solute rejection, though little is known whether they are suitable for wastewater treatment.

The objective of this study is to investigate 1) which types of wastewater can be treated by FO using biomimetic Aquaporin membranes, 2) which draw solution is most suitable for this application and 3) the extent and nature of the fouling.

All experiments were conducted in a bench-scale FO setup using NaCl, MgCl₂, NaOAc as a draw solution and different anaerobic digestion effluents as a feed. The effluents were characterised at the beginning and at the end of each experiment, regarding their total solids (TS), volatile solids (VS), total suspended solids (TSS), particle size distribution, Total Kjeldahl Nitrogen (TKN), Total available nitrogen (TAN), total organic carbon (TOC) and total phosphate (TP). The fouled membranes were analysed by Scanning Electron Microscope with Energy-dispersive X-ray spectroscopy (SEM-EDS), Fourier transform infrared spectroscopy (FTIR), ATP analysis and inductively coupled plasma optical emission spectrometry (ICP-OES). Our preliminary experimental results indicate that there is a correlation between the effluent composition and the fouling potential. Taken together our results can contribute understanding of how fouling can be mitigated by considering various feed pretreatment methods.

[1] K. Lutchmiah,, A.R.D. Verliefde, K. Roest , L.C. Rietveld, E.R. Cornelissen, Forward osmosis for application in wastewater treatment: A review. *Water Research*, 58 (2014) 179-197.

[2] S. Lee, C. Boo, M. Elimelech, and S. Hong, Comparison of fouling behavior in forward osmosis (FO) and reverse osmosis (RO), *Journal of Membrane Science*, 365 (2010) 34-39.