



Copper dosing enhances nitrification in biofilters treating groundwater

Wagner, Florian Benedikt; Borch Nielsen, Peter; Diwan, Vaibhav; Boe-Hansen, Rasmus; Smets, Barth F.; Dechesne, Arnaud; Albrechtsen, Hans-Jørgen

Publication date:
2017

Document Version
Publisher's PDF, also known as Version of record

[Link back to DTU Orbit](#)

Citation (APA):

Wagner, F. B., Borch Nielsen, P., Diwan, V., Boe-Hansen, R., Smets, B. F., Dechesne, A., & Albrechtsen, H-J. (2017). *Copper dosing enhances nitrification in biofilters treating groundwater*. Abstract from Water Quality Technology Conference (WQTC) 2017, Portland, United States.

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.



Copper dosing enhances nitrification in biofilters treating groundwater

Florian B. Wagner^{1, Δ*}, Peter Borch Nielsen², Vaibhav Diwan¹, Rasmus Boe-Hansen², Barth F. Smets¹, Arnaud Dechesne¹, Hans-Jørgen Albrechtsen¹

¹Department of Environmental Engineering, Building 115, DTU, 2800 Kgs. Lyngby, Denmark

²Krüger A/S, Gladsaxevej 363, 2860 Søborg, Denmark

ΔPresent address: Krüger A/S, Gladsaxevej 363, 2860 Søborg, Denmark

*email corresponding author: fbw@kruger.dk

Nitrification in granular media filters is commonly used to remove ammonium (NH₄⁺) during biological drinking water treatment. However, poor nitrification performance leads to excess ammonium in the finished water. This can result in unwanted nitrification in the distribution system, which can lead to loss of sufficient disinfectant residual (Zhang et al., 2009) and microbial aftergrowth (and thereby oxygen depletion, formation of toxic nitrite, corrosion, and taste and odor problems (van der Kooij, 2000)). In distribution systems without disinfection, residual ammonium is problematic because it prevents biologically stable water (Rittmann and Snoeyink, 1984).

Incomplete nitrification during treatment can be caused by lack of nutrients. Phosphorus for example has been shown to increase ammonium removal (Lytle et al., 2015). However, the nitrifying microorganisms also need other nutrients, such as trace metals, in comparably low amounts. Copper for example is vital for ammonia monooxygenase (Ensign et al., 1993), an essential enzyme which catalyzes the oxidation of ammonia to hydroxylamine, the first step in nitrification. Hence, we hypothesized that incomplete nitrification in biological filters could be caused by a deficiency of copper, and that dosing of the metal at low concentrations could help to overcome the limitations and stimulate the removal of ammonium.

Copper was dosed at ≤ 5 µg/L to the influent of a full-scale rapid sand filter at a groundwater treatment plant (GWTP) on Zealand, Denmark (Wagner et al., 2016 a). The plant had suffered from incomplete ammonium removal for several years. Treatment at the plant consists of simple aeration of the groundwater (through stairs aeration) and subsequent filtration with gravity driven rapid sand filters. Copper was dosed from solid copper rods, employing electrolysis (Albrechtsen et al., 2015; patent pending). Ammonium influent and effluent concentrations before and during dosing were monitored with an ammonium auto analyzer (Hach Lange, AMTAX™ sc). Furthermore, water was sampled over depth of the rapid sand filter and ammonium and nitrite concentrations were analyzed with colorimetric methods.

Copper dosing to the full-scale filter stimulated ammonium removal within only a few days (Fig. 1) and effluent concentrations dropped to <0.02 mg NH_4^+ /L after only 20 days (Wagner et al., 2016 a). Correspondingly, volumetric ammonium removal rates [$\text{g NH}_4^+/\text{m}^3$ filter material/h] increased, thereby increasing the removal capacity.




Figure 1 – Ammonium concentrations in the influent and effluent of a biological rapid sand filter at a full-scale groundwater treatment plant in Denmark. Copper dosing through electrolysis was started on day 0. (Adapted from Wagner et al., 2016 a)

Water sampling over filter depth revealed that ammonium removal activity was shifted upwards in the filter with onset of copper dosing. After 57 days with dosing, the volumetric ammonium removal rate for the top 10 cm of the filter had increased by a factor of almost 14 (Wagner et al., 2016 a). A second filter at the GWTP, which was monitored as a control and which did not receive dosing, did not show a change (neither positive nor negative) in ammonium removal performance.

Copper concentrations in the filter effluent were <1.5 $\mu\text{g Cu/L}$ (Wagner et al., 2016 a) and therefore several orders of magnitude below regulatory limits such as the Lead and Copper Rule (USEPA, 2008) or EU (European Commission, 1998) and WHO (WHO, 2011) guidelines, and negligible compared with copper released from premise plumbing materials.



After our initial findings, we carried out a comprehensive investigation of 10 full-scale groundwater treatment plants (GWTPs) with nitrification problems and different treatment steps, filter design, water chemistry, etc. (Wagner et al., *submitted*). The study aimed at testing if copper dosing could generically stimulate ammonium removal, and at elucidating the effect on the microbial community in the filters. Before copper dosing, nitrification performance of the filters at the GWTPs was poor, and interestingly, regardless of different water chemistry at the sites, filter design, and ammonium loading rates, copper dosing at $\sim 1 \mu\text{g Cu/L}$ stimulated nitrification in all 10 cases (Wagner et al., *submitted*).

Quantitative polymerase chain reaction (qPCR) and Illumina sequencing were used at 3 of the investigated sites to quantify and qualify the effect on the microorganisms in the filters. The analyses revealed that copper dosing did not only increase nitrification activity, but also the relative abundance of nitrifying microorganisms (Wagner et al., 2016 b).

The results from our studies let us conclude that controlled copper dosing can be a powerful tool to efficiently increase nitrification performance of granular media biofilters, stimulating nitrifier activity and abundance. The results have highly practical implications for water utilities operating biological filters. Increased nitrification capacity of biofilters is important and helps to make the filters more robust towards sudden shifts in ammonium loading rate, for example under dynamic operating conditions (Lee et al., 2014).

Acknowledgments

The study was supported by the Water Sector's Technology development Fund (VTUF) through project 'Stimulated biological treatment' (SBB) and by DTU. The authors gratefully acknowledge all water utilities that have contributed to the study - especially acknowledged is help from Jimmi Jørgensen, Anne Esbjørn and Henrik Nicolaisen. The authors furthermore thank Charlotte Jensen and Sonsoles Quinzaños from Krüger Veolia for assistance throughout the project.

References

- Albrechtsen, H.-J., Wagner, F.B., Nielsen, P.B., Boe-Hansen, R., Fischer, E.V., 2015. Apparatus comprising trace element dosage and method for treating raw water in biofilter. Patent application. Patent number: WO2015132283.
- Ensign, S. a, Hyman, M.R., Arp, D.J., 1993. In Vitro Activation of Ammonia Monooxygenase from *Nitrosomonas Europaea* by Copper. *J. Bacteriol.* 175, 1971–1980. doi:10.1128/jb.175.7.1971-1980.1993
- European Commission, 1998. Council Directive 98/83/EC on the quality of water intended for human consumption, Official Journal of the European Communities. doi:2004R0726 - v.7 of 05.06.2013



- Lee, C.O., Boe-Hansen, R., Musovic, S., Smets, B., Albrechtsen, H.J., Binning, P., 2014. Effects of dynamic operating conditions on nitrification in biological rapid sand filters for drinking water treatment. *Water Res.* 64, 226–236. doi:10.1016/j.watres.2014.07.001
- Lytle, D.A., Williams, D., Muhlen, C., Pham, M., Kelty, K., Wildman, M., Lang, G., Wilcox, M., Kohne, M., 2015. The full-scale implementation of an innovative biological ammonia treatment process. *J. Am. Water Works Assoc.* 107, E648–E665. doi:10.5942/jawwa.2015.107.0176
- Rittmann, B.E., Snoeyink, V.L., 1984. Achieving biologically stable drinking water. *J. / Am. Water Work. Assoc.* 76, 106–114.
- USEPA, 2008. Lead and Copper Rule: A Quick Reference Guide. From: <https://nepis.epa.gov/Exe/ZyPDF.cgi?Dockkey=60001N8P.txt>
- van der Kooij, D., 2000. Biological Stability: a Multidimensional Quality Aspect of Treated Water. *Water. Air. Soil Pollut.* 123, 25–34. doi:Doi 10.1023/A:1005288720291
- Wagner, F.B., Nielsen, P.B., Boe-Hansen, R., Albrechtsen, H.J., 2016 a. Copper deficiency can limit nitrification in biological rapid sand filters for drinking water production. *Water Res.* 95, 280–288. doi:10.1016/j.watres.2016.03.025
- Wagner, F.B., Nielsen, P.B., Boe-Hansen, R., Albrechtsen, H.-J., 2016 b. Copper dosing to biological rapid sand filters increases nitrifier activity and abundance, in: *IWA Specialized Conference - Microbial Ecology and Water Engineering & Biofilms*. Copenhagen, Denmark, pp. 102–103.
- Wagner, F.B., Nielsen, P.B., Boe-Hansen, R., Albrechtsen, H.-J., *submitted*. Remediation of incomplete nitrification and capacity increase of biofilters at different drinking water treatment plants through copper dosing.
- WHO, 2011. *World Health Organization Guidelines for drinking-water Quality*, 4th ed. Geneva, Switzerland.
- Zhang, Y., Love, N., Edwards, M., 2009. Nitrification in Drinking Water Systems. *Crit. Rev. Environ. Sci. Technol.* 39, 153–208. doi:10.1080/10643380701631739