Technical assessment of electric heat boosters in low-temperature district heating based on combined heat and power analysis

Cai, Hanmin; You, Shi; Wang, Jiawei; Bindner, Henrik W.; Klyapovskiy, Sergey

Published in:
Energy

Link to article, DOI:
[10.1016/j.energy.2018.02.084](https://doi.org/10.1016/j.energy.2018.02.084)

Publication date:
2018

Document Version
Peer reviewed version

[Link back to DTU Orbit](#)

Citation (APA):
Cai, H., You, S., Wang, J., Bindner, H. W., & Klyapovskiy, S. (2018). Technical assessment of electric heat boosters in low-temperature district heating based on combined heat and power analysis. *Energy*, 150, 938-49. <https://doi.org/10.1016/j.energy.2018.02.084>

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Accepted Manuscript

Technical assessment of electric heat boosters in low-temperature district heating based on combined heat and power analysis

Hanmin Cai, Shi You, Jiawei Wang, Henrik W. Bindner, Sergey Klyapovskiy

PII: S0360-5442(18)30312-8

DOI: [10.1016/j.energy.2018.02.084](https://doi.org/10.1016/j.energy.2018.02.084)

Reference: EGY 12384

To appear in: *Energy*

Received Date: 1 November 2017

Revised Date: 23 January 2018

Accepted Date: 17 February 2018

Please cite this article as: Cai H, You S, Wang J, Bindner HW, Klyapovskiy S, Technical assessment of electric heat boosters in low-temperature district heating based on combined heat and power analysis, *Energy* (2018), doi: 10.1016/j.energy.2018.02.084.

This is a PDF file of an unedited manuscript that has been accepted for publication. As a service to our customers we are providing this early version of the manuscript. The manuscript will undergo copyediting, typesetting, and review of the resulting proof before it is published in its final form. Please note that during the production process errors may be discovered which could affect the content, and all legal disclaimers that apply to the journal pertain.

Technical Assessment of Electric Heat Boosters in Low-Temperature District Heating based on Combined Heat and Power Analysis

Hanmin Cai^a, Shi You^{a,*}, Jiawei Wang^a, Henrik W. Bindner^a, Sergey Klyapovskiy^a

^aTechnical University of Denmark, 2800 Kgs. Lyngby, Denmark

Abstract

This paper provides a technical assessment of electric heat boosters (EHBs) in low-energy districts. The analysis is based on a hypothetical district with 23 terraced single-family houses supplied by both a low-temperature district heating (LTDH) network and a low-voltage network (LVN). Two case studies are provided to show the active role of EHBs in a smart energy system (SES). The first case compares annual heat and power flow analyses for LTDH at five supply temperature levels, focusing on their impacts. The results show that district heating network (DHN) losses can be reduced by 35% if the supply temperature is reduced from 70 °C to 50 °C, but the LVN peak power will have to be increased by up to 2% using heat boosting. The second case further aggregates EHBs to provide a fuel shift (FS) service for the DHN. The results show that while LVN peak power was increased by up to 4.3%, the basic power production and peak boiler usage for DHN could be reduced by as much as 15% and 48%, respectively. In summary, lower supply temperatures and intelligent components can improve system efficiency and turn the DHN into an integrated part of a SES.

Keywords: Smart energy systems; 4GDH; Low-temperature district heating; Electric heat boosters; Fuel shift; Combined heat and power.

1. Introduction

Denmark is aiming at a 100% renewable-based electricity and heating sector by 2035 and a complete transition to a renewable-based energy system by 2050 [1]. Such ambitious targets demand considerable effort involving integration of intermittent renewable sources and energy conservation. In recent years, a large number of renewable energy sources, such as wind power plants, have been connected to the Danish energy system. Meanwhile, energy

*Corresponding author

Email addresses: hacai@elektro.dtu.dk (Hanmin Cai), sy@elektro.dtu.dk (Shi You), jiawang@elektro.dtu.dk (Jiawei Wang), hwbi@elektro.dtu.dk (Henrik W. Bindner), seklya@elektro.dtu.dk (Sergey Klyapovskiy)

Nomenclature			
A	network incidence matrix [-]	Abbreviation	σ standard deviation [-]
A_r	surface area of tank [m ²]	Agg	Aggregator
B	susceptance [Ω^{-1}]	CHP	Combined Heat and Power
B	incidence matrix [-]	DCW	District Cold Water
c	water specific heat [kJ/(kg·°C)]	DH	District Heating
C	conversion matrix [-]	DHN	District Heating Network
d	inner pipe diameter [m]	DHW	Domestic Hot Water
E	energy [MWh]	DHO	District Heating Operator
G	conductance [Ω^{-1}]	EHB	Electric Heat Booster
I	current [A]	EL	Electric Power
L	pipe length [m]	FS	Fuel Shift
$\dot{m}$	mass flow rate [kg/s]	LTDH	Low-Temperature District Heating
M	tank water mass [kg]	LVN	Low-Voltage Network
p	pressure [kPa]	SES	Smart Energy System
P	active power [kW]	SH	Space Heating
Q	reactive power [kVAR]	SF	Simultaneity Factor
S	complex power [kVA]		
t	time period [min]	Greek symbols	
T	temperature [°C]	δ	voltage angle [rad]
u	control decision [-]	Δ	difference [-]
U	heat transfer coefficient [kW/(m ² ·K)]	Φ	thermal power [kW]
V	voltage [V]	λ	friction factor [-]
$\dot{V}_o$	volume flow rate [m ³ /s]	μ	expected value [-]
Y	bus admittance matrix [-]	ρ	density [kg/m ³]
			Subscripts and superscripts
			amb ambient
			cw cold water
			d downstream node
			des desired
			el electric
			est estimated
			g ground
			in incoming
			l pipe index
			max/min maximum/minimum
			m, n bus index
			out out flowing
			q node flow
			quo quota
			r return
			s supply
			serv service pipe
			tk tank
			tap tap water draw
			u upstream node

efficiency measures have been taken in the heating sector as the Danish Building Regulations have set a progressively lower energy consumption framework [2]. These new developments demand a rethinking and redesign of the current energy system, i.e. a smart energy system [3].

Instead of the traditional separate operation of the various energy sectors, what is needed is a smart energy system (SES) approach combining multiple smart grid infrastructures [4]. We need to identify synergies to achieve an optimal solution for each individual sector as well as for the overall energy system [5]. For instance, to achieve the 2035 targets, we need to coordinate the operation of the electricity and heat sectors. More concretely, intermittent wind farm power output is challenging the operation of the Danish power system, which currently relies on neighbouring countries for a large part of its balancing needs. Occasionally, Denmark exports electricity to neighbours at negative prices [6]. As neighbouring countries integrate renewable energy into their own energy systems, more balancing capacity will be needed in the future [7]. Research shows that storage in the electricity sector will be insufficient and more capacity needs to be found in other sectors, such as district heating (DH) [3]. This is a well-developed and efficient heating solution in Scandinavian countries and will operate at lower supply temperature levels as more low-energy buildings are constructed. The concept of low-temperature district heating (LTDH) or 4th generation district heating (4GDH) represents a paradigm shift in DH development and features a low supply temperature and intelligent control of DH system components [4]. The former will provide benefits such as heat loss reduction, easier access to renewable sources, and more efficient waste heat recovery, while the latter will enable DH systems to be

integrated in smart energy systems. Meanwhile DH systems will require more power-to-heat conversions as combined heat and power (CHP) plants play a smaller role in future energy systems due to an increasing renewable share [8].

A lot of research has focused on one or more of the aspects mentioned above, and some has focused on identifying possible synergy across sectors. Mancarella [9] provides a comprehensive overview of existing concepts and the tools needed to do research in multi-energy systems. Li et al. [10] propose using the water in district heating network (DHN) as energy storage for decoupling CHP operation in order to balance wind power fluctuation and reduce curtailment. Cai et al. [11] consider thermal loads as flexible cross-sector resources to assist SES operations and demonstrate coordinated demand response [12]. Some research has focused on the impact of lowering DH supply temperature. Østergaard et al. [13] have shown that the space heating (SH) needs of typical Danish single-family houses can already be satisfied for large parts of the year using LTDH. However, a supply temperature as low as 60 °C is not sufficient to provide domestic hot water (DHW) without increasing the risk of Legionella contamination. Yang et al. [14] list several alternative solutions, while Zvingilaite et al. [15] report that the most economical solution is to use a supplementary electric heater. Park et al. [16] studied a multi-storey building supplied by LTDH with varying temperature levels. They argue that there are optimal supply and return temperatures that minimize the net operation cost. Ommen et al. [17] discovered that the impact of variation in the DH temperature on the coefficient of system performance is different for systems supplied by central HP from those supplied by extraction CHP. Elmegaard et al. [18] suggest that the benefits from reduced heat losses in LTDH networks are not sufficient to make it more competitive than conventional systems due to the high share of DHW in low-energy buildings. Østergaard et al. [19] compare LTDH using booster heat pumps with LTDH using natural gas boilers, suggesting that LTDH with booster heat pumps is the better option. Yang et al. [20] investigated using instantaneous heat exchanger units to prepare DHW and suggest that as the better option for supply temperatures of 50 °C and 65 °C. A few researchers have focused on active control to facilitate the operation of conventional DH systems. For instance, DH load creates thermal peaks [21, 22], which may lead to sub-optimal dispatch of co-generation units, and therefore increase primary energy consumption [23]. The peak thermal load may also mean the network is over-dimensioned. To shave the peak, Johansson et al. [24] deploys agent-based load control in DH substations and reduces peak demand in the DHN through short-term shifting of SH load. However, these literature sources do not consider the additional operational benefits from using active heat boosting equipment in an SES, which may influence the economic outlook.

This paper therefore set out to assess two aspects of 4GDH in an SES context, namely lower supply temperature levels and intelligent control of substations, including heat boosting devices using electricity. Their small investment cost and simple operation mean that heat boosting solutions using supplementary electric heaters are likely to be widely present in an energy system that integrates LTDH. The device is called an electric heat booster (EHB) and will be the focus throughout this paper. Collectively, EHBs can form a significant flexibility portfolio for the system operators. For example, the following sections will consider using EHBs to provide a fuel shift (FS) service to the LTDH network. The term

FS will be explained and formulated mathematically in the next section. To the best of the authors' knowledge, no previous research has either explicitly considered EHBs as flexible cross-sector coupling or designed a service to support LTDH at planning and operation stages.

This paper is organized as follows: The next section presents the methodology, including the modelling of the DHN, low-voltage network (LVN) and EHBs with FS controller design at district level. Section 3 then provides two case studies, in which the impacts of LTDH supply temperature levels are investigated and the FS service is evaluated. Finally, section 4 draws conclusions and makes remarks on future work.

2. Methodology

2.1. System description

To facilitate discussion, an abstract representation of a building's connection to the DHN and LVN is illustrated in Figure 1. In a fully renewable based Danish energy system, electricity will largely come from wind power transmitted across the country, and LTDH will be more dependent on local low temperature renewable sources (such as geothermal energy) and improved waste heat recovery. Substations will use the LTDH network to support the SH load while DHW is prepared using EHBs. The energy flow inside an EHB is shown in Figure 2. Both electric power from the LVN and thermal power from the DHN can be used to heat up tank water. While electric power is dependent on voltage over the EHB, thermal power depends on the flow rate and temperature drop.

Figure 1: EHB is connected to both DHN and LVN

A real-world example of Figure 1 is shown in Figure 3, where an SES lab called "SYS-LAB" has been developed to research synergies across energy sectors from building active components and deploying intelligent control. More specifically, the physical installation of the EHB (shown in Figure 4) contributes to its heat boosting function. Figure 5 shows the architecture of the underlying information and communications technology (ICT) infrastructure that supports both centralized and distributed control. Mathematical models were used to analyse the system described above. These models support the simulation in MATLAB and are described in detail in the rest of this section.

Figure 2: Simplified view of energy flow

Figure 3: SYSLAB - A flexible intelligent laboratory for integrated energy system research. The red dots show the location of components; yellow lines indicate network connections

2.2. DHN modelling

DHN characteristics were modelled in detail to reflect operation constraints, whereas dynamics (such as the temperature distribution along the pipes) were ignored to keep the simulation simple. Moreover, the supply temperature was assumed to be constant throughout the year, and heat transfer delays were also neglected. Hydraulic models are formulated in Equations 1 - 6 and thermal models are provided in Equations 7 - 8. Equation 1, which describes the continuity law for incompressible water flow in a compact form [25], was used to calculate the flow rate in each pipe:

$$\mathbf{A}\dot{\mathbf{m}} = \dot{\mathbf{m}}_q \quad (1)$$

where $\mathbf{A}$ is the network incidence matrix, and $\dot{\mathbf{m}}$ and $\dot{\mathbf{m}}_q$ are vectors of pipe and nodal mass flow rate respectively. Every node connected with a low-energy building is here called a load node. The rate of mass flow discharged to each load node consists of $\dot{m}_{q,SH}$ for SH and

Figure 4: Electric heat booster

$\dot{m}_{q,DHW}$ for DHW preparation, as in Equation 2:

$$\dot{m}_q = \dot{m}_{q,SH} + \dot{m}_{q,DHW} \quad (2)$$

The rate of load node mass flow due to SH is described by Equation 3:

$$\dot{m}_{q,SH} = \frac{\Phi_{SH}}{c(T_{serv} - T_r)} \quad (3)$$

where T_{serv} and T_r are respectively the temperatures of the service pipe and the return pipe at load node, while Φ_{SH} is SH power at the same node.

115 The consumed pump power can be calculated as in Equations 4 - 6 [26]:

$$\Delta p = -\frac{8\lambda L}{d^5 \pi^2 \rho} \cdot \dot{m}^2 \quad (4)$$

$$\Delta p_{pump} = \Delta p_s + \Delta p_r + \Delta p_{min} \quad (5)$$

$$P_{pump} = \frac{\Delta p_{pump}}{\eta_{pump}} \cdot \dot{V}_o \quad (6)$$

120 where P_{pump} is the required pumping electric power, Δp_s and Δp_r are the total pressure drops from the most peripheral substation to the main circulation pump in respectively the supply and return pipes, Δp_{min} is the minimum differential pressure at the most peripheral substation, η_{pump} is the total conversion efficiency for the circulation pump, and $\dot{V}_o$ is the volume flow rate.

Multiple incoming flows at a given node were assumed to be well-mixed so that the temperature of the flow leaving the node can be calculated as in Equation 7 [25]:

$$(\sum \dot{m}_{out})T_{out} = \sum (\dot{m}_{in}T_{in}) \quad (7)$$

Figure 5: Control and communication - enabling smart response from EHBs

where T_{out} is the mixed temperature, $\dot{m}_{out}$ is the mass flow rate leaving the node, $\dot{m}_{in}$ is the mass flow rate entering the node, and T_{in} is the temperature of the incoming flow. The bypass flow at critical nodes was incremented in an iterative process to simulate the bypass valve thermostat control that keeps the temperature drop within 5 °C [27]. The pipe flow rate will be constrained by the velocity limit of the pipes, but must also guarantee the minimum differential pressure required on the end-user side.

The temperature drop along the pipes can be described by Equation 8 [25]:

$$T_{d,l} = T_g + (T_{u,l} - T_g)e^{-\frac{U_l L_l}{\dot{m}_l}} \quad (8)$$

where $T_{d,l}$ and $T_{u,l}$ denote the temperatures at the upstream and the downstream nodes of pipe l , T_g refers to the soil temperature, U_l and L_l denote the heat loss coefficient and the pipe length, and $\dot{m}_l$ denotes the pipe flow rate.

2.3. LVN modelling

The LVN was also modelled to investigate impact of heat boosting and the FS service on the LVN. The load power at each load node varies, so the total power feed-in from the external grid, as well as the power losses, will also vary.

Applying Kirchhoff's Current Law at each bus in the LVN allows a set of nodal equations to be derived and written in a compact form as in Equation 9:

$$\mathbf{I} = \mathbf{YV} \quad (9)$$

where $\mathbf{I}$ denotes the vector of net current injection, $\mathbf{Y}$ is the bus admittance matrix, and $\mathbf{V}$ is the vector of the bus voltage phasor. The complex power at each bus S is expressed in

Equation 10:

$$S_n = P_n + jQ_n = V_n I_n \quad (10)$$

The real and imaginary parts of the complex power, i.e. the active and reactive power at each bus, can be respectively expressed in Equations 11 - 12:

$$P_m = |V_m| \sum_{n=1}^N |V_n| (G_{mn} \cos \delta_{mn} + B_{mn} \sin \delta_{mn}) \quad (11)$$

$$Q_m = |V_m| \sum_{n=1}^N |V_n| (G_{mn} \sin \delta_{mn} - B_{mn} \cos \delta_{mn}) \quad (12)$$

where both active and reactive power at bus n are represented by its voltage magnitude $|V_n|$ and $|V_m|$ of the buses m connected to it, the susceptance of the distribution line is B_{mn} and its conductance is G_{mn} , δ_{mn} is the voltage angle between bus m and n , and N refers to total number of nodes.

We used the Newton-Raphson method to solve the above equations and provide a power flow analysis of the LVN.

2.4. Electric heat booster modelling

The setup used in this research assumed a water tank volume larger than 3 litres is on the secondary side, which requires heat boosting to satisfy the hygiene requirement according to the German Standard W551 [28]. The heat boosting concept is shown in Figure 6a. DH flow exchanges heat with cold tank water through a DH coil placed in the middle of the tank. At the same time, an electrical resistance is present and uses electricity to boost water temperatures up to 55 °C and occasionally to 60 °C. The Danish Code of Practice for Water Supply Installations [29] requires tap water to be between 40 °C and 45 °C depending on its purpose. To keep things simple, 42 °C was used as the tap water temperature. Detailed modelling of Figure 6a adds considerable complexity to controller design. Since the energy consumption is the most important parameter in an integrated energy system context, a simple single-layer water tank model focusing on energy balance was used. A single-layer model treats the water in the tank as a homogeneous layer, ignoring the fluid dynamics of water being drawn, and cold water fed in and heated. Figure 6b shows the power exchange, which is formulated in Equation 13:

$$cMT_{tk} \dot{T}_{tk} = \Phi' - c\dot{m}_{tk}(T_{tk} - T_{cw}) - UAr(T_{tk} - T_{amb}) \quad (13)$$

where Ar is the tank surface area, T_{tk} is the tank water temperature, T_{cw} is the cold water temperature, T_{amb} is the ambient temperature of the EHB, $\dot{m}_{tk}$ is the rate of water drawn from the water tank, and Φ' is the heat power injected into the tank by DH coil Φ or electrical element P :

$$\Phi' = \Phi + P = c\dot{m}_{q,DHW}(T_{serv} - T_r)u + \bar{P}(1 - u) \quad (14)$$

Figure 6: EHB structure and energy balance for the single-layer model

where u is the control decision to use DH coil or the electrical element to heat DHW. T_{cw} was assumed to be 10°C and T_{amb} was assumed to be 18°C , both constant throughout the year. $\bar{P}$ is the rated power of the electric heating element. $\dot{m}_{q,DHW}$ was assumed to be a fixed flow rate of 150l/h. Valve dynamics were ignored. To simplify matters, the return temperature at the substation was assumed to be constant, though in practice it can be manually set by the user. In the simulation, T_r was set to be 30°C less than the supply temperature for all the substations and neglect dynamics inside heat exchangers.

The heat boosting decision variable u in Equation 14 is formulated in Equation 15 by taking into account the heat exchanger temperature loss ΔT .

$$u = \begin{cases} 1, & \text{if } T_{tk} < T_s - \Delta T \\ 0, & \text{otherwise} \end{cases} \quad (15)$$

The control logic formulated above never deployed DH and electric heating at the same time. The tank water temperature set point was assumed to be 55°C with a thermostat dead-band of 1°C . Moreover, the water at the user's tap was obtained by mixing hot water from the tank with cold water. This can be expressed as Equation 16:

$$\dot{m}_{tk} = \min\left\{\frac{42^\circ\text{C} - 10^\circ\text{C}}{T_{tk} - 10^\circ\text{C}}, 1\right\} \times \dot{m}_{tap} \quad (16)$$

where $\dot{m}_{tap}$ is the water drawn at user's tap created using the Danish Standard profile [29]. The whole simulation and control process is summarized in Figure 7.

2.5. Network dimensions and demand profile

The low-energy district of 23 terraced single-family houses considered here was assumed to have been built according to the most recent Danish Building Regulations 2015 (BR15).

Figure 7: Simulation flow chart

These require that annual energy demand for heating, ventilation, cooling and DHW preparation should not exceed the energy performance framework calculated as $30 + 1000/(\text{total heated floor area})\text{kWh/m}^2/\text{y}$ [2].

All the houses were assumed to have a heated floor area of about 140m^2 with 3~4 occupants, which gives an annual total energy demand of 5.2MWh. The network topology was based on the building density of the outskirts of Copenhagen. This makes the network losses, which depend greatly on pipe lengths, more representative. The greenfield design of the dimensions of the DH network takes into account the network topology, design load and simultaneity factor (SF). Details on the methodology and the numerical values of SF can be found in Li and Svendsen (2012) [27]. The network topology, including connections and the length of pipes, was determined by sketching based on a district in the outskirts of Copenhagen using Google map. The network topology is shown in Figure 8. For the DH system, the design load was assumed to be 3kW for SH and 5.2kW for DHW. A 10-bar system with minimum network static pressure of 2 bars was used in the network dimensioning. The pressure drop on the end-user side was assumed to be 50kPa, taking into account the minimum differential pressure and local pressure loss. The network was designed for supply/return temperatures of 50/20 °C, 55/25 °C, 60/30 °C, 65/35 °C, 70/40 °C, and 80/40 °C, but supply/return temperatures of 80/40 °C are not discussed in this paper because they fall outside the definition of LTDH. Pipes were selected from existing commercial products. Network dimension results are summarized in Figure 9 and Table 1. To make valid comparisons, the

210 DH network was assumed to operate at a constant supply temperature level throughout the year with a temperature drop of 30 °C. Figure 9 shows that the network dimensions do not change when the temperature drop is the same. This is because the methodology proposed by Li and Svendsen [27] utilizes differential pressure over critical nodes as the decisive factor for network dimensioning. So the same network dimensions were used for all the analyses.

Figure 8: The low-temperature district heating network with black solid dots denoting load nodes

Table 1: DH network dimensions

Pipe type	Inner diameter [mm]	Roughness [mm]	Length [m]
Alx 32/32	26	0.02	260
Alx 26/26	20	0.02	110
Alx 20/20	15	0.02	100
Alx 16/16	11.6	0.02	75
Alx 14/14	10	0.02	420

215 The LVN shares the same topology as the DHN in Figure 8 and a single-line diagram is shown in Figure 10. The district is connected to the external grid via a 10/0.4kV transformer. Optimal design of the network was not considered. Cables were selected from commercially available products and the dimensions are summarized in Table 2.

220 The low-energy building SH demand profile was simulated using IDA ICE [30]. The SH load is treated here as a fixed base load in DHN. The DHW heating demand was obtained from the EHB model and controller described in section 2.4. The water draw profile was created using Danish Standard [29], which features a large amount of water drawn for showers in the morning and evening. The electricity load was created using a typical Danish residential load profile [31], which gives the base electricity load excluding electric heating. The load diversity was emulated by scaling and shifting the water draw,

Figure 9: Pipe selection results

Table 2: LVN cable dimension

Cable type	Current Value [A]	R [ohm/km]	X [ohm/km]	Length [m]
4x150 AL-M PVIKS	275	0.206	0.073	200
4x95 AL-M PVIKS	215	0.320	0.075	60
4x16 AL PVIK	81	1.91	0.085	135
2x6 CU PVIK	68	3.08	0.092	570

SH demand, and electricity load profiles in accordance with normal distribution $\mathcal{N}(\mu, \sigma^2)$ and uniform distribution $\mathcal{U}(\Delta t_{\min}, \Delta t_{\max})$. Heating loads were then all scaled to correspond to BR15 [2]. It was not necessary to diversify EHB tank size, since commercial products have only a limited number of sizes. We therefore assumed a storage tank of 92 litres for all households. Details found be found in Table 3.

2.6. Fuel-shift controller design

The term FS can be explained as replacing one energy source with another. Using the Energy Hub modelling technique proposed by Geidl and Andersson [32], FS can be formulated as Equation 17 and is illustrated in Figure 11. It can be interpreted as an optimized dispatch of $\mathbf{P}_{\text{in}}$ given the load and a predefined cost function.

$$\mathbf{P}_{\text{out}} = \mathbf{C}\mathbf{P}_{\text{in}} \quad (17)$$

Before designing the controller, practical concerns need to be addressed. EHBs are controlled to shift from one energy source to another, but electric power set points cannot be shared equally between households due to the fixed electric power rating (either 3kW or

Figure 10: Low-voltage network

Table 3: Assumed stochastic parameters for load diversity

Variable	Meaning	Distribution	Parameter
P_{daily}	base electricity load peak	Normal	$\mu = 7\text{kW}, \sigma = 0.7\text{kW}$
$\Delta t_{\text{el,daily}}$	time shift of electricity load	Uniform	$\Delta t_{\text{el,min}} = -1\text{h}, \Delta t_{\text{el,max}} = 2\text{h}$
$\Phi_{\text{SH,daily}}$	SH load peak	Normal	$\mu = 1.8\text{kW}, \sigma = 0.2\text{kW}$
$\Delta t_{\text{SH,daily}}$	time shift of SH load	Normal	$\mu = 0\text{h}, \sigma = 2\text{h}$
$\dot{m}_{\text{tap,daily}}$	peak tap water draw	Normal	$\mu = 10\text{l/min}, \sigma = 0.2\text{l/min}$
$\Delta t_{\text{tap,daily}}$	time shift of water draw	Normal	$\mu = 0\text{h}, \sigma = 3\text{h}$

zero). This means that some EHBs would be supplied by electricity while others would not. Then there is the issue of fairness when coordinating which EHBs should switch from DH to electricity. This is a problem when the price of electricity is much higher than DH, as in Denmark. Moreover, direct control is intrusive. To solve these problems, it was assumed that an entity such as a District Heating Operator (DHO) or Aggregator manages the EHBs. The DHO/Agg would provide heat comfort as a service to consumers, while providing FS to the DHN. This allows the maximum controllability. Any increased electricity cost would be covered by the DHO/Agg.

The FS service would be characterized by the calculation of a power quota based on the heat load desired.

$$\Phi_{\text{quo}} = \max\{\Phi_{\text{des}} - \Phi_{\text{SH}}^{\text{est}} - \Phi_{\text{loss}}^{\text{est}}, 0\} \quad (18)$$

where Φ_{des} is the heat load desired in the DHN, $\Phi_{\text{SH}}^{\text{est}}$ and $\Phi_{\text{loss}}^{\text{est}}$ are respectively the estimated SH load and heat losses in the DHN. The quota Φ_{quo} for DH load for DHW is then broadcast to the EHBs.

The interactions between the DHO/Agg and the EHBs are illustrated in Figure 12. First, the quota calculated using Equation 18 is broadcast to EHBs. The responsive ones will acknowledge the message; otherwise communication is assumed to have been lost. The

Figure 11: FS explained using Energy Hub modelling technique

EHBs then coordinate among themselves according to their priority. This is determined according to the distance of the load nodes from the heat entry point (node 39 in Figure 8). Those further away will be given lower priority, since long distance heat delivery means more losses and longer delivery time. When the EHBs reach a consensus, a final aggregate DH power for DHW will be reported back to DHO/Agg. In this way, occupancy will not be revealed and privacy will not be compromised.

Figure 12: Interaction of DHO/Agg and EHBs in one cycle

3. Case studies

The objectives of the analyses here were twofold. Firstly, we wanted to quantify the impacts of supply temperature level on the operation of LTDH networks and the LVN with a detailed EHB model and controller. Secondly, we wanted to evaluate the design FS service using EHBs as flexible resources.

3.1. Case 1 - the base case

In the base case, EHBs are used only as a heat-boosting solution. Annual simulation results for the whole district are summarized in Table 4. We chose a 5-minute time step, since most water draws are less than 5 minutes and this is enough time for water to flow from the entry point to the furthest node. EL and DH in Table 4 refer to using electricity and district heating as the energy source, while DHW, SH, pumps and losses refer to the reason for the energy usage. DH total refers to the total energy used in the DH network, including heat load, network losses, and pump electricity consumption.

Table 4: Energy usage - the base case

Energy [MWh]	Supply temperature level T_s				
	50 °C	55 °C	60 °C	65 °C	70 °C
EL DHW	32.87	21.01	1.76	0.00	0.00
DH DHW	20.74	32.38	51.36	52.93	52.79
DH SH	65.00	65.00	65.00	65.00	65.00
DH losses	23.56	26.51	29.89	33.00	36.42
DH pumps	0.44	0.73	0.88	0.92	0.96
DH total	109.73	124.61	147.13	151.85	155.18

Table 4 shows that when T_s is reduced from 70 °C to 50 °C, losses are reduced by 35% from 36.42MWh down to 23.56MWh, which approximates to the annual energy consumption of three houses. Moreover, DH is used less for DHW while electricity usage increases due to boosting needs. No control is deployed for SH and the total consumed energy stays the same for all supply temperature levels. The energy balance chart shown in Figure 13 illustrates how the energy in DH is distributed.

Figure 13: DH energy balance chart - the base case

Interestingly, Figure 13 shows that losses comprise roughly 21~24% of total DH energy when T_s is reduced from 70 °C to 50 °C, even though losses are substantially reduced in absolute terms. This can be explained by Figure 14, which shows that DH utilized for DHW is reduced by as much as 61% at the lower supply temperature. With a fixed DHN dimension, when less heat is consumed, there is less pipe flow and higher losses occur. This means that, in percentage terms, the loss reduction benefit is not significant when operating at a lower temperature.

Figure 14: DHW energy source - the base case

Figure 15 shows the load duration curves for selected temperature levels (T_s at 50 °C, 60 °C and 70 °C). If we assume that base heat production can cover the heat load for 80% of the year and the rest will be supplemented by a peak boiler that runs on fossil fuels, the base heat production and fuel usage can be derived from Figure 15.

The LVN power flow analysis result is summarized in Table 5. The increased LVN losses ΔE_{loss} and peak power ΔP_{peak} were calculated by deducting the base electricity load described in section 2.5. With ΔE_{loss} and ΔP_{peak} , the impact of EHBs can be evaluated. In particular, a substantial increase in peak power ΔP_{peak} would require a larger fuse and transformer at the entry of this district. That would be an additional cost that would need to be considered at the planning stage. Table 5 shows that losses due to increased electricity usage could increase by as much as 9%, whereas peak power only increased by about 2%, which means that an upgrade of transformer or fuse is not necessary. The reason for the modest increase in peak power is the difference between electricity and heat load pattern. While standard demand profiles were used in the study, it could be updated with a more detailed consumption pattern analysis obtained from real measurements using a data-driven approach.

Further interpretation of Table 4 and Figure 13 can give interesting results. For instance, while loss reduction and more efficient heat recovery are obvious benefits for the DHN, an increased energy bill is expected as T_s is decreased. Consequently, a trade-off needs to be

Figure 15: Load duration curves for total DH load at selected T_s levels

Table 5: Impacts of EHBs on the LVN - the base case

	Supply temperature level T_s				
	50 °C	55 °C	60 °C	65 °C	70 °C
EL DHW [MWh]	32.87	21.01	1.76	0.00	0.00
LVN ΔE_{loss} [MWh]	4.80	3.05	0.24	0.00	0.00
LVN ΔE_{loss} [%]	9.14	5.81	0.46	0.00	0.00
ΔP_{peak} [kVA]	2.50	3.60	0.00	0.00	0.00
ΔP_{peak} [%]	1.52	2.19	0.00	0.00	0.00

found in terms of T_s . To do so, the numerical relationships between each energy usage and T_s need to be found. Interpolation was used in this research to derive the relationships. Since Table 4 shows no difference between 65 °C and 70 °C other than DH losses, to obtain a good fit, interpolation was only done for temperature levels from 50 °C to 65 °C. The results are summarized in Table 6, where parameters in linear and quadratic interpolation refer to $E = aT_s + b$ and $E = aT_s^2 + bT_s + c$ respectively. Subject to the fit level in terms of root-mean-square error (RMSE), Equation 19 can be obtained.

Table 6: Numerical relationships between energy usage and T_s

	Linear interpolation			Quadratic interpolation			
	a	b	RMSE	a	b	c	RMSE
EL DHW [MWh]	-2.36	149.45	7.51	0.10	-13.97	480.22	5.56
DH losses [MWh]	0.63	-8.22	0.18	0.00	0.45	-2.98	0.16
DH total [MWh]	2.98	-37.88	7.63	-0.10	14.66	-370.62	5.69

$$\begin{aligned}
 E_{el}(T_s) &= 0.1T_s^2 - 13.97T_s + 480.22 \\
 E_{loss}(T_s) &= 0.63T_s - 8.22 \\
 E_{dh}(T_s) &= -0.1T_s^2 + 14.66T_s - 370.62
 \end{aligned}
 \tag{19}$$

3.2. Case 2 - fuel shift

To further improve the benefits of EHBs and exemplify their active roles in a SES, the FS service was first and foremost designed to assist DHN operation. The impacts of FS can then be evaluated by interpreting the results of the annual analysis.

The annual analysis was performed assuming perfect forecasts of SH load and heat loss, and perfect communication and coordination. Impacts on DHN for the case $\Phi_{des} = 20\text{kW}$ are summarized in Table 7, Figure 16 and Figure 17, while the impacts on LVN are summarized in Table 8 and Table 9. Compared to Table 4, Figure 13 and Figure 14, electricity usage is higher while DH energy consumption is lower. Heat loss is slightly higher due to reduced heat load. Moreover, Table 8 implies that EHBs' increased electricity consumption would not need an upgrade in LVN.

Table 7: Energy usage and when $\Phi_{des} = 20\text{kW}$

Energy [MWh]	Supply temperature level T_s				
	50 °C	55 °C	60 °C	65 °C	70 °C
EL DHW	38.68	30.51	17.91	16.75	16.67
DH DHW	14.91	22.85	35.16	36.13	36.07
DH SH	65.00	65.00	65.00	65.00	65.00
DH losses	23.89	26.90	30.41	33.71	37.25
DH pumps	0.13	0.14	0.16	0.17	0.18
DH total	103.93	114.89	130.73	135.00	138.50

New load duration curves were obtained and are summarized in Figure 18, which shows a clear reduction of in peak-load hours. Figure 19 shows values for the reduced base heat power production and peak boiler usage compared with the case without FS. The results show that, with the FS service, base heat power production for the DHN can be reduced by as much as 15%, and for peak boiler usage by as much as 48%.

Reduced peak heat power means that existing network could connect more buildings without an upgrade (such as pipes with wider inner diameters). It also implies that a smaller size of CHP plant could be possible. Moreover, peak boiler usage reduction could contribute to a 100% renewable-based electricity and heating sector by 2035.

The results presented in these two case studies can be used as input for future economic analysis. For example, the reduced base heat power production, losses and peak boiler usage all contribute to reduction of investment and operation cost, while increased electricity consumption represents increased operation cost. Combining with the relationships obtained in Equation 19, an optimal supply temperature that minimizes life cycle cost could be obtained. In-depth economic evaluation lies outside of the scope of this paper.

Figure 16: Energy balance chart with FS and $\Phi_{des} = 20\text{kW}$

Figure 17: DHW energy source with FS and $\Phi_{des} = 20\text{kW}$

In summary, this case study demonstrates that intelligent residential substations with EHBs could contribute to synergy between electricity and heat sectors.

4. Conclusions and future work

Cross-sector flexible resource use of EHBs in low-energy districts was investigated based on combined heat and power analysis. A hypothetical district with 23 terraced single-family houses supplied by both an LTDH network and an LVN was analysed and two case studies were performed. The first case focused on the impact of LTDH supply temperature levels. Comparisons were made for annual heat and power flow analysis results at five different supply temperature levels. Results show that DHN heat losses can be reduced by 35% when

Table 8: Impacts of EHBs on the LVN with FS, $\Phi_{\text{des}} = 20\text{kW}$

	Supply temperature level T_s				
	50 °C	55 °C	60 °C	65 °C	70 °C
EL DHW [MWh]	38.68	30.51	17.91	16.75	16.67
LVN ΔE_{loss} [MWh]	5.81	4.69	3.01	2.87	2.85
LVN ΔE_{loss} [%]	11.07	8.94	5.74	5.46	5.44
ΔP_{peak} [kVA]	7.10	4.90	5.60	5.60	5.60
ΔP_{peak} [%]	4.32	2.98	3.41	3.41	3.41

Table 9: Impacts of EHBs on the LVN - comparing the base case with FS, $\Phi_{\text{des}} = 20\text{kW}$

	Supply temperature level T_s				
	50 °C	55 °C	60 °C	65 °C	70 °C
ΔP_{peak} [%]	1.52	2.19	0.00	0.00	0.00
ΔP_{peak} [%]	4.32	2.98	3.41	3.41	3.41

Figure 18: Impact of fuel shift on load duration curves with $\Phi_{\text{des}} = 20\text{kW}$. Dashed lines are load duration curves without FS, solid lines are those with FS

the supply temperature is reduced from 70 °C to 50 °C, but the LVN peak power will have to be increased by up to 2% using heat boosting. The second case provides the design of an FS service for the DHN. Analysis was carried out at the same five supply temperature levels. Results show that LVN peak power is increased by up to 4.3%, while basic power production for DHN can be reduced by as much as 15% and peak boiler usage by as much as 48%. The reduced heat demand can be taken into account in future network planning. This could make it possible to further reduce network dimensions and losses. The results obtained can also be used as input for economic evaluation. Therefore this study makes an important contribution to the research on 4GDH by demonstrating the usefulnesses of lower

Figure 19: Impact of fuel shift on base production capacity and fuel usage for peak boiler. Results without FS (in blue) and with FS, $\Phi_{\text{des}} = 20\text{kW}$ (in red)

supply temperature and intelligent residential substations.

Several aspects of this work could be improved and extended. Steady-state analysis of a DHN does not give a perfect representation of the real DH system. Dynamics, such as heat transfer delays, could be added in the future to enable simulation of the dynamic operation of a DHN and exploit its storage capacity to absorb excess wind power. Moreover, heat pump boosters might be more cost-efficient in multi-family buildings due to their lower operation cost. A better mix of technologies could be achieved. Lastly, the fuel shift service described here is an LVN passive response to the needs of the DHN. In an integrated energy system, network operation challenges for both electricity and district heating networks need to be addressed. The difference is that there are power-to-heat devices available in residential substations, but no heat-to-power conversion devices on the end-user side. This means there is no single solution that can address both challenges.

As a part of the Danish Energy Technology Development and Demonstration Programme, the concepts and solutions developed in this paper will be demonstrated in the Nordhavn area in Copenhagen, Denmark with some modifications. 24 houses have volunteered to participate and all have been equipped with the DH substations mentioned in this paper. Laboratory tests have shown EHBs are capable of switching between FS and non-FS modes. A large-scale experiment is expected to be rolled out. 23 houses will be aggregated to provide the FS service and one house will be left out for comparison.

5. Acknowledgement

This research was part of a project which is funded by the Danish EUDP (Energy Technology Development and Demonstration Programme). Project title: EnergyLab Nordhavn - Smart components in integrated energy systems, project number: 64015-0055.

References

- [1] The Danish Government, The Danish Climate Policy Plan Towards a low carbon society (2013).
- [2] The Danish Transport and Construction Agency, Danish Building Regulations 2015 (BR15), Copenhagen.
- 385 [3] H. Lund, P. A. Østergaard, D. Connolly, B. V. Mathiesen, Smart energy and smart energy systems, *Energy* 137 (2017) 556–565.
- [4] H. Lund, S. Werner, R. Wiltshire, S. Svendsen, J. E. Thorsen, F. Hvelplund, B. V. Mathiesen, 4th Generation District Heating (4GDH): Integrating smart thermal grids into future sustainable energy systems, *Energy* 68 (2014) 1–11.
- 390 [5] H. Lund, Renewable energy systems: a smart energy systems approach to the choice and modeling of 100% renewable solutions, Academic Press, 2014.
- [6] Nord Pool Spot, Elspot prices.
URL <http://www.nordpoolspot.com/>
- 395 [7] F. Hvelplund, P. A. Østergaard, N. I. Meyer, Incentives and barriers for wind power expansion and system integration in Denmark, *Energy Policy* 107 (2017) 573–584.
- [8] B. Bach, J. Werling, T. Ommen, M. Münster, J. M. Morales, B. Elmegaard, Integration of large-scale heat pumps in the district heating systems of Greater Copenhagen, *Energy* 107 (2016) 321–334.
- [9] P. Mancarella, MES (multi-energy systems): An overview of concepts and evaluation models, *Energy* 65 (2014) 1–17.
- 400 [10] Z. Li, W. Wu, M. Shahidehpour, J. Wang, B. Zhang, Combined heat and power dispatch considering pipeline energy storage of district heating network, *IEEE Transactions on Sustainable Energy* 7 (1) (2016) 12–22.
- [11] H. Cai, S. You, H. W. Bindner, S. Klyapovskiy, Load Situation Awareness Design for Integration in Multi-Energy System, in: *Energy Internet (ICEI)*, IEEE International Conference on, IEEE, 2017, pp. 42–47.
- 405 [12] H. Cai, S. You, H. W. Bindner, S. Klyapovskiy, X. Yang, R. Li, Optimal scheduling for electric heat booster under day-ahead electricity and heat pricing, in: *52nd International Universities Power Engineering Conference (UPEC)*, 2017, pp. 1–4.
- [13] D. S. Østergaard, S. Svendsen, Theoretical overview of heating power and necessary heating supply temperatures in typical Danish single-family houses from the 1900s, *Energy and Buildings* 126 (2016) 375–383.
- 410 [14] X. Yang, H. Li, S. Svendsen, Alternative solutions for inhibiting Legionella in domestic hot water systems based on low-temperature district heating, *Building Services Engineering Research and Technology* 37 (4) (2016) 468–478.
- 415 [15] E. Zvingilaite, T. S. Ommen, B. Elmegaard, M. L. Franck, Low temperature district heating consumer unit with micro heat pump for domestic hot water preparation, in: *13th International Symposium on District Heating and Cooling*, 2012, pp. 136–143.
- [16] B.-S. Park, M. Imran, I.-Y. Hoon, M. Usman, Thermo-economic optimization of secondary distribution network of low temperature district heating network under local conditions of South Korea, *Applied Thermal Engineering* 126 (2017) 117–133.
- 420 [17] T. Ommen, J. E. Thorsen, W. B. Markussen, B. Elmegaard, Performance of ultra low temperature district heating systems with utility plant and booster heat pumps, *Energy* 137 (2017) 544–555.
- [18] B. Elmegaard, T. S. Ommen, M. Markussen, J. Iversen, Integration of space heating and hot water supply in low temperature district heating, *Energy and Buildings* 124 (2016) 255–264.
- 425 [19] P. A. Østergaard, A. N. Andersen, Booster heat pumps and central heat pumps in district heating, *Applied Energy* 184 (2016) 1374–1388.
- [20] X. Yang, H. Li, S. Svendsen, Energy, economy and exergy evaluations of the solutions for supplying domestic hot water from low-temperature district heating in Denmark, *Energy Conversion and Management* 122 (2016) 142–152.
- 430 [21] H. Gadd, S. Werner, Heat load patterns in district heating substations, *Applied energy* 108 (2013) 176–183.

- [22] K. Ahmed, P. Pylsy, J. Kurnitski, Hourly consumption profiles of domestic hot water for different occupant groups in dwellings, *Solar Energy* 137 (2016) 516–530.
- [23] E. Guelpa, G. Barbero, A. Sciacovelli, V. Verda, Peak-shaving in district heating systems through optimal management of the thermal request of buildings, *Energy* 137 (2017) 706–714.
- [24] C. Johansson, F. Wernstedt, P. Davidsson, Deployment of agent based load control in district heating systems, in: *First International Workshop on Agent Technologies for Energy Systems*, Canada, 2010.
- [25] X. Liu, J. Wu, N. Jenkins, A. Bagdanavicius, Combined analysis of electricity and heat networks, *Applied Energy* 162 (2016) 1238–1250.
- [26] S. Frederiksen, S. Werner, *District heating and cooling*, Studentlitteratur, 2013.
- [27] H. Li, S. Svendsen, Energy and exergy analysis of low temperature district heating network, *Energy* 45 (1) (2012) 237–246.
- [28] DVGW W 551:2004-04, Deutscher Verein des Gas- und Wasserfaches eV (German Technical and Scientific Association for Gas and Water), Code of Practice, Drinking water heating and drinking water piping systems.
- [29] DS 439:2009, Danish Standards, Code of Practice for Water Supply Installations.
- [30] H. Pieper, T. Ommen, W. B. Markussen, B. Elmegaard, Optimal usage of low temperature heat sources to supply district heating by heat pumps, in: *30th International Conference on Efficiency, Cost, Optimization, Simulation and Environmental Impact of Energy Systems*, 2017.
- [31] Danish Electricity Consumption Panels, Reports, Profiles 2012 (in Danish).
URL <http://www.elforbrugspanel.dk/Pages/Rapportering.aspx>
- [32] M. Geidl, G. Andersson, Optimal power flow of multiple energy carriers, *IEEE Transactions on Power Systems* 22 (1) (2007) 145–155.

Highlights:

- Comprehensive model of heat and power network flow for steady-state simulation.
- Analysis of the performance of a low-energy district in 5-minute intervals.
- Detailed electric heat booster model and controller design in a real-world context.
- Design of fuel shift service for the district heating sector to optimize operation.
- Analysis of the advantages of lower supply temperatures and smart components.