



Long term measured and simulated performance of a combined solar district heating plant with flat plate collectors and parabolic trough collectors in series

Tian, Zhiyong; Perers, Bengt; Furbo, Simon; Fan, Jianhua; Zourellis, Andreas

Publication date:
2018

Document Version
Peer reviewed version

[Link back to DTU Orbit](#)

Citation (APA):

Tian, Z., Perers, B., Furbo, S., Fan, J., & Zourellis, A. (2018). *Long term measured and simulated performance of a combined solar district heating plant with flat plate collectors and parabolic trough collectors in series.* Abstract from 5th International Solar District Heating Conference, Graz, Austria.

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Long term measured and simulated performance of a combined solar district heating plant with flat plate collectors and parabolic trough collectors in series

Zhiyong Tian¹, Bengt Perers¹, Simon Furbo¹, Jianhua Fan¹, Andreas Zourellis²

¹, Department of Civil Engineering, Technical University of Denmark, Nordvej
Building 119, Kgs. Lyngby, 2800, Denmark, 0045-52781629, zhiytia@byg.dtu.dk

², Aalborg CSP A/S, Aalborg, Denmark, azo@aalborgcsp.com

TOPIC: Advanced concepts and components- monitoring results

SUMMARY

Large scale solar heating plants develop fast in Europe, especially in Denmark. Most solar collectors used in previous solar heating plants are flat plate collectors. Flat plate collectors have relatively low efficiency at high temperature levels, such as 70 - 95 °C, which is the supply temperature of district heating networks. Parabolic trough collectors keep a high efficiency at the high temperature level. To maximize the advantages of flat plate collectors and parabolic trough collectors, a novel combined solar heating plant with flat plate collectors and parabolic trough collectors in series has been constructed in Taars, Denmark. The flat plate collectors preheat the return water from the district heating networks to about 75°C, then the parabolic trough collectors heat the preheated water from the flat plate collector field to the required supply temperature of the district heating network. The thermal performance of the combined plant was measured from September, 2015. More than 2 years' thermal performance will be presented in this paper.

Key-words: Taars solar heating plant, parabolic trough collector, flat plate collector, thermal performance

1. Introduction

The number of large solar heating plants in Denmark has increased strongly during the last couples of years. Most solar collectors in the solar heating plants are flat plate collectors. The feasibility of parabolic trough collectors in solar heating plants has been investigated for Danish conditions [1]. A combined solar heating plant with a 5960 m² flat plate collector field and a 4032 m² parabolic trough collector field has been in operation in Taars since August 2015 [2], see Figs.1-2. The flat plate collectors preheat the return water from the district heating network to about 75°C, then the parabolic trough collectors heat the preheated water from the flat plate collector field to the required supply temperature of the district heating network.



Fig.1. Overview of the flat plate and parabolic trough collector fields in Taars solar heating plant [2].




Fig.2. Schematic illustration of Taars solar heating plant.

2. Methods

The inlet temperature, outlet temperature, flow rate etc. of the parabolic trough collector field and the flat plate collector field have been measured. Daily and monthly thermal performances of the parabolic trough collector field and the flat plate collector fields are determined based on the measured data. A Trnsys model has been validated by the measurements [3].

3. Results and conclusions




Fig.3. Thermal performances of flat plate collector field and parabolic trough collector field.

Fig.3. shows both measured and simulated performances of the flat plate collector field and parabolic trough collector field. Simulated and measured performances from September 2015 to February 2017 have a good agreement. More measurements and calculations of the thermal performances of both fields will be presented in the paper.

References

- [1] B. Perers, S. Furbo, and J. Dragsted, "Thermal performance of concentrating tracking solar collectors," *DTU Report*, vol. 292, no. August, 2013.
- [2] Aalborg CSP A/S, "Aalborg CSP," <http://www.aalborgcsp.com/>, 2017. [Online]. Available: July.2017.
- [3] Z. Tian, B. Perers, S. Furbo, and J. Fan, "Analysis and validation of a quasi-dynamic model for a solar collector field with flat plate collectors and parabolic trough collectors in series for district heating," *Energy*, Sep. 2017.