Novel Energisation Method for Offshore Wind Farms Connected to HVdc via Diode Rectifiers

Saborío-Romano, Oscar; Bidadfar, Ali; Sakamuri, Jayachandra Naidu; Göksu, Ömer; Cutululis, Nicolaos Antonio

Published in:
Proceedings of the 45th Annual Conference of the IEEE Industrial Electronics Society (IECON 2019)

Link to article, DOI:
[10.36227/techrxiv.10002782.v1](https://doi.org/10.36227/techrxiv.10002782.v1)
[10.1109/IECON.2019.8927580](https://doi.org/10.1109/IECON.2019.8927580)

Publication date:
2020

Document Version
Peer reviewed version

[Link back to DTU Orbit](#)

Citation (APA):
Saborío-Romano, O., Bidadfar, A., Sakamuri, J. N., Göksu, Ö., & Cutululis, N. A. (2020). Novel Energisation Method for Offshore Wind Farms Connected to HVdc via Diode Rectifiers. In *Proceedings of the 45th Annual Conference of the IEEE Industrial Electronics Society (IECON 2019)* (pp. 4837-4841). [LD-026611] IEEE. <https://doi.org/10.36227/techrxiv.10002782.v1>, <https://doi.org/10.1109/IECON.2019.8927580>

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Novel Energisation Method for Offshore Wind Farms Connected to HVdc via Diode Rectifiers

Oscar Saborío-Romano^{ID}, Ali Bidadfar^{ID}, Jayachandra N. Sakamuri^{ID}, Ömer Göksu^{ID}, Nicolaos A. Cutululis^{ID}

Department of Wind Energy
Technical University of Denmark
Risø Campus, Roskilde, Denmark
Email: osro@dtu.dk

Abstract—Recently put forward as a feasible alternative for connecting OWFs to HVdc networks, diode rectifiers (DRs) have elicited growing interest from both academia and industry. Energisation of such OWFs is, however, not straightforward. The present study constitutes a proof of concept for the application of a novel energisation method to the case of an OWF connected to HVdc via DRs. The proposed method provides a robust and reliable alternative with minimal additional hardware, i.e. short additional dc cables connecting the dc bus bar of the *energising* WT to the HVdc link, and corresponding dc disconnectors at the cable terminals and at the DR dc terminals. This can be easily extended to more WTs in the OWF, increasing reliability by providing redundancy. The simulation results indicate that the proposed method is a suitable alternative for energising OWFs connected to HVdc via DRs.

Index Terms—Diode-rectifier-based HVdc transmission, energisation, grid-forming wind turbine control, offshore wind energy integration

I. INTRODUCTION

Further exploitation of Europe’s offshore wind resources entails the development of electrical infrastructure interconnecting offshore wind farms (OWFs) and onshore networks. Thus far, most OWFs are connected via HVac, and only a few export their production through HVdc [1]. The amount of HVdc-connected OWFs, however, is widely expected to increase, as the distance from shore and OWF size increase and the associated costs decrease [2], [3].

Since first presented in 1997 [4], HVdc transmission technology making use of voltage source (forced-/self-commutated) converters (VSCs), based on insulated-gate bipolar transistors, has experienced great development. Such HVdc transmission solutions still have higher losses and overall costs than the more common, mature ones employing (phase-controlled) line-commutated converters, based on thyristors (in a current source converter topology), which are largely used for bulk power transmission [3], [5]. However, VSC-based HVdc transmission (VSC-HVdc) offers advantages such as independent control of active and reactive power, smaller footprints, fast reversibility of active power flow, and the (grid-forming) capability to form ac networks, i.e. to control their ac-side voltage magnitude and frequency (which allows them to operate without the need of a strong AC grid) [4]. Because of such advantages, the use of VSC-based offshore HVdc terminals has enabled the development of HVdc-connected OWFs with

the prevailing grid-following approach to controlling wind turbines (WTs), in which WTs rely on other (grid-forming) units (e.g. VSC-based offshore HVdc terminals) forming their ac network [6].

Recently put forward as a feasible alternative for connecting OWFs to HVdc networks, (uncontrolled, line-commutated) diode rectifiers (DRs) have elicited growing interest from both academia and industry [7]–[14]. DR-based offshore HVdc terminals offer advantages such as lower costs, smaller footprints, higher efficiency and higher reliability [9], [13]. As passive devices, however, they are inherently devoid of the grid-forming capability of VSCs. As a consequence, WTs have been suggested as viable candidates to take over such duty. This entails fundamentally different WT and WF controls, changing their control principle from that of grid-following units to that of grid-forming units [7], [12].

A. Wind Farm Energisation

WTs and WFs have auxiliary systems (loads) that need electricity most of the time, even when the WTs are not generating electricity. Such loads can consist of pitch and yaw motors, oil pumps, air conditioning, dehumidifiers, navigation lights, and measurement, control, protection, communication and safety systems, among others. When WTs generate electricity, a portion of their output is used to supply the energy required by the WF auxiliary loads and offshore ac network. Auxiliary power must otherwise be supplied from local auxiliary energy sources, e.g. batteries or diesel generators or from the networks connected to the WFs [1]. This is the case, for example, when there is no aerodynamic power available from the wind, i.e. the wind speed is below the cut-in wind speed or above the cut-out wind speed of the WTs.

The use of VSC-based offshore HVdc terminals allows remote OWFs to draw the required auxiliary power from the HVdc networks connected to them. This, however, is not possible for OWFs connected to HVdc via DRs or thyristor-based LCCs, as power flows through the former only towards the shore and the latter require a strong (energised) ac network connected to them. Such OWFs thus need to be energised by other means. This is also the case for OWFs connected to HVdc networks via VSCs, when such offshore converters are not operational.

Fig. 1. Overview of the studied system; red: additional equipment introduced by the proposed energisation method, grey: alternatives in literature for providing the auxiliary power from onshore ac networks

Different solutions have been proposed for energising OWFs connected to HVdc via DRs [10], [11], [14]. Solutions for providing the auxiliary power from onshore ac networks are represented in gray in Fig. 1. The use of local auxiliary energy sources or the connection to neighbouring energised offshore ac networks, e.g. other OWFs, have been proposed in [11]. The latter has been considered in several subsequent studies [15], [16].

Additional connections between the OWFs and the onshore ac networks have also been considered. The use of an additional LVdc link has been proposed in [11], which requires additional VSC-based power conversion terminals. Moreover, an additional MVac *umbilical* cable interconnecting the onshore and offshore ac networks have been introduced in [11]–[14]. Such umbilical cables have been considered in several subsequent studies [15], [17]–[21], and have been assumed to be disconnected during normal operation, i.e. their use has been restricted to the energisation of the corresponding OWFs. Other solutions avoid the need for additional long submarine cables by introducing additional power conversion equipment offshore to effectively bypass the DRs during energisation [10], [11].

In quest of increasing reliability and lowering costs and environmental impact, a new energisation method has been proposed in [22] for OWFs connected to dc networks. The present study constitutes a proof of concept for the application of such method [22] to the case of an OWF connected to an onshore ac network through an HVdc link having a DR-based offshore terminal and a full-bridge-VSC-based onshore terminal. During energisation, the auxiliary power is provided by the onshore ac network through the dc bus bar of one of the WTs. The method only requires short additional dc cables connecting such *energising* WT dc bus bar to the HVdc link,

and corresponding dc disconnectors at the cable terminals and at the DR dc terminals, highlighted in red in Figs. 1 and 2.

The rest of the paper is organised as follows. In Section II, the investigated system is described and the main control algorithms are detailed. In Section III, the considered case is described, and corresponding simulation results are presented and discussed. Finally, concluding remarks are made in Section IV.

II. MODELLING AND CONTROL

Fig. 1 shows an overview of the studied system. The system is based on that described in [15], [18] and consists of one of three 400 MW OWFs connected to an onshore ac network by means of a 200 km long 1200 MW ± 320 kV monopolar HVdc link. Balanced/symmetric operation is assumed. The offshore HVdc terminal: one of three diode rectifier platforms (one per OWF), depicted in Fig. 1, consists of two (uncontrolled, line-commutated) diode-based 12-pulse rectifiers (DRs) connected in series, with corresponding reactive power compensation and filter bank on their ac side.

Fig. 2. k th wind turbine front-end (line-side) network; red: additional equipment introduced by the proposed energisation method

Fig. 4. Simulation results: (a) voltage at the onshore and offshore ends of the HVdc link, E_I and E_R , respectively; (b) HVdc link current; (c) rms voltage at the ac terminals of the energising and non-energising (equivalent) WTs, U_1 and U_{2-50} , respectively, at the ac terminals of the energising WT FEC, $U_{W,1}$, and at its filter capacitor, $U_{T,1}$; (d) output rms currents of the energising WT, I_1 , and of its FEC filter, $I_{T,1}$, and active and reactive components of the latter, $I_{Td,1}$ and $-I_{Tq,1}$, respectively; (e) offshore ac network frequency; (f) active power flowing out of the onshore terminal, $P_{I,dc}$, into the offshore diode rectifier platform, $P_{R,dc}$, out of the energising WT, P_1 , and into the non-energising (equivalent) WT, $-P_{2-50}$; (g) reactive power flowing out of the energising WT FEC, $Q_{W,1}$, out of the energising WT FEC filter, $Q_{T,1}$, out of the energising WT, Q_1 , and into the non-energising (equivalent) WT, $-Q_{2-50}$.

A. Stage 0: Initial Conditions

Initially, the WTs, offshore ac network and HVdc link are de-energised, the voltage set points, E_R^* , U_0 , are set to 0, and all ac circuit breakers and dc disconnectors shown in Figs. 1 and 2 are open.

B. Stage 1: WT dc Bus Bar Energisation

At $t = 0$ s, the dc disconnectors S_{WT} and $S_{dc,1}$ are closed, effectively connecting the WT₁ dc bus bar to the HVdc link, $E_I \approx E_R$. Between $t = 1$ s and $t = 6.39$ s, the onshore terminal energises the HVdc link and WT₁ dc bus bar as the direct voltage set point, E_R^* , is increased from 0 to the WT dc bus bar nominal voltage (approximately 5.39 kV), as shown in Fig. 4a. Such rate of increase in the direct voltage (i.e. 1 kV/s) requires a temporary charging current of up to 33.1 A, as depicted in Fig. 4b.

C. Stage 2: Offshore ac Network Energisation

WT₁ main ac circuit breaker, S_1 , is closed at $t = 9$ s, and the corresponding FEC then energises the offshore ac network, establishing its voltage and frequency, as the offshore ac network voltage set point, U_0 , is increased from 0 to 1 pu between $t = 10$ s and $t = 11$ s, as illustrated by Figs. 4c and 4e. In doing so, it draws about 422 kW from the onshore terminal, as depicted by Fig. 4f, which stands for the no-load losses of the studied system. As shown in Figs. 4a and 4b, the corresponding increase in dc current causes a temporary drop in the WT₁ dc bus bar voltage, $E_I \approx E_R$, of about 205 V, i.e. 3.80 % of its nominal value. Moreover, it causes a voltage drop in the HVdc link of about 259 V $\approx$ 4.58 % in steady state.

D. Stage 3: Auxiliary Load Energisation

Finally, ac circuit breakers $S_{a,1}$ and $S_{a,2-50}$ are closed at $t = 15$ s, and the auxiliary loads are energised, as shown most notably in Fig. 4f. As depicted by Figs. 4a and 4b, the corresponding increase in dc current causes a temporary drop in $E_I \approx E_R$, of about 840 V, i.e. 15.6 % of its nominal value. Furthermore, it causes a voltage drop in the HVdc link of about 780 V $\approx$ 12.7 % in steady state.

E. Further Comments

As illustrated by Figs. 4d, 4f and 4g, reactive (output) current, $-I_{Tq,1}$, constitutes most of the energising WT FEC filter output current, $I_{T,1}$, in steady state. The corresponding 3.81 MVar are needed mainly to energise the (equivalent) WT transformers. The active (output) current, $I_{Td,1}$, is required to cover the OWF auxiliary loads and active power losses, which constitute 10 % and 5.11 %, respectively, of the energising WT's nominal power.

The onshore terminal controller calculates the voltage drop in the HVdc link using the measured I_{dc} and estimated HVdc link resistance, $\hat{R}_{dc}$, and compensates for it by increasing E_I accordingly, maintaining E_R close to its reference value, as depicted in Figs. 4a and 4b. WT₁ FEC grid-forming controls

maintain f at 50 Hz ($\omega_0 = 1$ pu) and regulate U_{T1} to follow U_0 , as depicted by Figs. 4c and 4e.

As illustrated by Fig. 4d, less than half of the energising WT's nominal rms current is needed to energise the studied OWF with the proposed method. Moreover, it requires an HVdc link current of less than 225 A, i.e. less than 12 % of its nominal current, as shown in Fig. 4b, leaving enough HVdc link current capacity to energise the other two 400 MW OWFs in the same way. In the studied system, such current constitutes the necessary capacity of the additional dc auxiliary supply cables, introduced in the proposed energisation method to interconnect the (also introduced) dc auxiliary supply terminals of the energising WT and of the DR platform. Such capacity can in turn determine the current limit for the corresponding protections.

IV. CONCLUSIONS

The simulation results indicate that the proposed method is a suitable alternative for energising OWFs connected to HVdc via DRs. With the considered WT converter voltage level, the necessary auxiliary power can be provided to the studied OWF while leaving enough HVdc link current capacity to energise the other OWFs in the same way. The method provides a robust and reliable alternative with minimal additional hardware, i.e. short additional dc cables connecting the dc bus bar of the *energising* WT to the HVdc link, and corresponding dc disconnectors at the cable terminals and at the DR dc terminals. This can be easily extended to more WTs in the OWF, increasing reliability by providing redundancy.

ACKNOWLEDGEMENT

The authors gratefully acknowledge the contributions of Lorenzo Zeni and Poul E. Sørensen to the discussions leading up to this work. This work has received funding from the European Union's Horizon 2020 research and innovation programme under grant agreement No 691714.

REFERENCES

- [1] CIGRÉ Working Group B3.36, "Special Considerations for AC Collector Systems and Substations Associated with HVDC-Connected Wind Power Plants," Paris, France, Technical Brochure 612, Mar. 2015.
- [2] P. Bresesti, W. L. Kling, R. L. Hendriks, and R. Vailati, "HVDC Connection of Offshore Wind Farms to the Transmission System," *IEEE Transactions on Energy Conversion*, vol. 22, no. 1, pp. 37–43, Feb. 2007.
- [3] D. van Hertem, O. Gomis-Bellmunt, and J. Liang, Eds., *HVDC Grids: For Offshore and Supergrid of the Future*. Hoboken, NJ, United States: John Wiley & Sons, Mar. 2016.
- [4] ABB, "HVDC Light: It's time to connect," Tech. Rep., Mar. 2013. [Online]. Available: <http://new.abb.com/docs/default-source/ewea-doc/hvdc-light.pdf>.
- [5] CIGRÉ Working Group B4.37, "VSC Transmission," Paris, France, Technical Brochure 269, Apr. 2005.
- [6] CIGRÉ Working Group B4.55, "HVDC Connection of Offshore wind power plant," Paris, France, Technical Brochure 619, May 2015.
- [7] R. M. Blasco-Giménez, S. C. Añó-Villalba, J. Rodríguez-D'Erlee, F. Morant-Anglada, and S. I. Bernal-Pérez, "Distributed Voltage and Frequency Control of Offshore Wind Farms Connected With a Diode-Based HVdc Link," *IEEE Transactions on Power Electronics*, vol. 25, no. 12, pp. 3095–3105, Dec. 2010.
- [8] R. M. Blasco-Giménez, S. C. Añó-Villalba, J. Rodríguez-D'Erlee, S. I. Bernal-Pérez, and F. Morant-Anglada, "Diode-Based HVdc Link for the Connection of Large Offshore Wind Farms," *IEEE Transactions on Energy Conversion*, vol. 26, no. 2, pp. 615–626, Mar. 2011.
- [9] S. I. Bernal-Pérez, S. C. Añó-Villalba, R. M. Blasco-Giménez, and J. Rodríguez-D'Erlee, "Efficiency and Fault Ride-Through Performance of a Diode-Rectifier- and VSC-Inverter-Based HVDC Link for Offshore Wind Farms," *IEEE Transactions on Industrial Electronics*, vol. 60, no. 6, pp. 2401–2409, Jun. 2013.
- [10] E. V. Larsen, "Electric power transmission system for wind turbine and wind turbine farm and method for operating same," United States Patent Application Publication US 2011/0140511 A1, 16th Jun. 2011.
- [11] H. J. Knaak, P. Menke, T. Schröck, R. Schuster, and T. Westerweller, "Wind farm connection having a diode rectifier," International Patent Application Publication WO 2014/131454 A1, 4th Sep. 2014.
- [12] T. Christ, S. Seman, and R. Zurowski, "Investigation of DC Converter Nonlinear Interaction with Offshore Wind Power Park System," in *Proceedings of the 2015 EWEA Offshore Conference*, Copenhagen, Denmark, 10th–12th Mar. 2015.
- [13] P. Menke, R. Zurowski, T. Christ, S. Seman, G. Giering, T. Hammer, W. Zink, F. Hacker, D. Imamovic, J. Thisted, P. Brogan, and N. Goldenbaum, "2nd Generation DC Grid Access for Large Scale Offshore Wind Farms," in *Proceedings of the 14th Wind Integration Workshop*, Brussels, Belgium, 20th–22nd Oct. 2015.
- [14] J. Dorn, D. Ergin, T. Hammer, H. J. Knaak, P. Menke, J. Møller, R. Schuster, H. Stiesdal, and J. Thisted, "Converter station with diode rectifier," United States Patent Application Publication US 2016/0013653 A1, 14th Jan. 2016.
- [15] PROMOTioN, "Deliverable 3.1: Detailed functional requirements to WPPs," Project Deliverable, Dec. 2016. [Online]. Available: https://www.promotion-offshore.net/fileadmin/PDFs/D3.1_PROMOTioN_Deliverable_3.1_Detailed_functional_requirements_to_WPPs.pdf.
- [16] —, "Deliverable 2.3: Report on simulation results and benchmark," Project Deliverable, 2019, unpublished.
- [17] C. Prignitz, H. G. Eckel, S. Achenbach, F. Augsburg, and A. Schön, "FixReF: A control strategy for offshore wind farms with different wind turbine types and diode rectifier HVDC transmission," in *Proceedings of the IEEE 7th International Symposium on Power Electronics for Distributed Generation Systems (PEDG 2016)*, Vancouver, BC, Canada, 27th–30th Jun. 2016.
- [18] PROMOTioN, "Deliverable 3.2: Specifications of the control strategies and the simulation test cases," Project Deliverable, Mar. 2017. [Online]. Available: https://www.promotion-offshore.net/fileadmin/PDFs/D3.2_Specifications_Control_strategies_and_simulation_test_cases.pdf.
- [19] C. Neumann, H.-G. Eckel, S. Achenbach, and F. Augsburg, "Auxiliary Power Supply in a FixReF Controlled Offshore Wind Power Plant with Diode Rectifier HVDC Transmission," in *Proceedings of the 16th Wind Integration Workshop*, Berlin, Germany, 25th–27th Oct. 2017.
- [20] PROMOTioN, "Deliverable 3.4: Results on control strategies of WPPs connected to DR-HVDC," Project Deliverable, Jan. 2018. [Online]. Available: https://www.promotion-offshore.net/fileadmin/PDFs/D3.4_PROMOTioN_Results_on_control_strategies_of_WPPs_connected_to_DR-HVDC.pdf.
- [21] R. Ramachandran, S. Poullain, A. Benchaib, S. Bacha, and B. Francois, "AC Grid Forming by Coordinated Control of Offshore Wind Farm connected to Diode Rectifier based HVDC Link – Review and Assessment of Solutions," in *Proceedings of the 20th European Conference on Power Electronics and Applications (EPE 2018 – ECCE Europe)*, Riga, Latvia, 17th–21st Sep. 2018.
- [22] A. Bidadfar, O. Saborío-Romano, P. E. Sørensen, N. A. Cutululis, M. Altin, and Ö. Göksu, "System and method for energising an AC network of an offshore wind farm," European Patent Application EP 18204886.8, 7th Nov. 2018.
- [23] E. Muljadi, S. Pasupulati, A. Ellis, and D. Kosterov, "Method of Equivalencing for a Large Wind Power Plant with Multiple Turbine Representation," in *Proceedings of the IEEE PES 2008 General Meeting*, Pittsburgh, PA, United States, 20th–24th Jul. 2008.
- [24] A. Yazdani, "Control of An Islanded Distributed Energy Resource Unit with Load Compensating Feed-Forward," in *Proceedings of the IEEE PES 2008 General Meeting*, Pittsburgh, PA, United States, 20th–24th Jul. 2008.