Advanced integrated control of large-scale wind power plants and wind turbines

Giebel, Gregor; Larsen, Gunner; Natarajan, Anand; Meyers, Johan; Bossanyi, Ervin; Merz, Karl

Publication date:
2019

Document Version
Publisher's PDF, also known as Version of record

Citation (APA):
Giebel, G., Larsen, G., Natarajan, A., Meyers, J., Bossanyi, E., & Merz, K. (2019). *Advanced integrated control of large-scale wind power plants and wind turbines*. Poster session presented at WindEurope Conference and Exhibition 2019, Bilbao, Spain.

PO.077

TotalControl

Advanced integrated control of large-scale wind power plants and wind turbines

Gregor Giebel, Gunner Larsen, Anand Natarajan, Johan Meyers, Ervin Bossanyi, Karl Merz

DTU Wind Energy, KU Leuven, DNV GL, SINTEF

Abstract

Current state of the art **wind power plant (WPP) controllers** operate wind turbines (WTs) independently as individual machines, thus dispatching the WTs' set points in an equal manner to all of them. To achieve optimal WPP control, three aspects need to be addressed:

- **Maximizing the yield** (power production) balanced against turbine mechanical loading and electricity price
- **Enhancing WPP capability** to provide ancillary services (primary, secondary, and tertiary reserves), and
- **Reducing operating costs** (i.e. reduced fatigue load degradation of WTs and O&M requirement) over the lifetime of the WPP.

The goal of TotalControl is to move the WPP controller design philosophy from *individual* optimization of WT operation to a *coordinated* optimization of the overall WPP performance. The TotalControl project aims to achieve this by developing and validating advanced *integrated* WPP/WT control schemes conditioned on grid demands and wind turbine fatigue damage limits. For developing and testing of the different WPP controllers, a range of high-fidelity and medium-fidelity simulation models are used. These models are already available in the consortium, but will be thoroughly validated against full-scale measurements in the Lillgrund WPP. Due to the complexity and multi-scale nature of WPP flow dynamics, the high-fidelity CFD-based models are very expensive in simulation time, e.g. requiring supercomputing, and therefore not well suited as control design models.

First video released



http://www.totalcontrolproject.eu/dissemination-activities/videos

Wind farm control time scales



TotalControl is built on a **hierarchy of controllers**, each reacting at different time scales and control time steps. At the *slowest control level* the WPP is quasi-statically adapting its WT active and reactive power set points and WT yaw angles, adapting to slowly changing environmental conditions and market elements. A *second control level* is the WT controller, accepting power set points from the quasi-steady control levels.

Finally, a fast WPP controller is considered which responds dynamically to faster events (turbulent gusts, requests for ancillary services, etc.) and uses *feedback from the WTs*. This controller uses model-predictive control for prediction of dynamic wake behavior and impacts on turbine loads. The dynamic WPP controller also contains a direct control level related to the WPP internal power grid.

Project set-up



Lillgrund tests

Vattenfalls Lillgrund wind farm, where a full-scale test will be run, monitored with two synchronized lidars.

Lillgrund image © www.siemens.com/press, Lidar scan pattern from Windscanner.eu.

Levenmouth tests



ORE Catapult's Samsung 7MW prototype turbine at Levenmouth, to be used for turbine control trials.

References

www.TotalControlProject.eu

This project has received funding from the European Union's Horizon 2020 Research and Innovation Programme under grant agreement No. 727680

MEET US AT 1-F41 (DTU), 1-E40 (Siemens Gamesa), or 3-D54 (DNV-GL)!

WindEurope CONFERENCE & EXHIBITION 2019 2-4 APRIL BILBAO

windeurope.org/confex2019

#WindEurope2019

Download the poster