



## Transactive Energy for Aggregated Electric Vehicles to Reduce System Peak Load Considering Network Constraints

Masood, Arsalan; Hu, Junjie; Xin, Ai; Sayed, Ahmed Rabee; Yang, Guangya

*Published in:*  
IEEE Access

*Link to article, DOI:*  
[10.1109/access.2020.2973284](https://doi.org/10.1109/access.2020.2973284)

*Publication date:*  
2020

*Document Version*  
Publisher's PDF, also known as Version of record

[Link back to DTU Orbit](#)

*Citation (APA):*  
Masood, A., Hu, J., Xin, A., Sayed, A. R., & Yang, G. (2020). Transactive Energy for Aggregated Electric Vehicles to Reduce System Peak Load Considering Network Constraints. *IEEE Access*, 8, Article 8993811. <https://doi.org/10.1109/access.2020.2973284>

---

### General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Received January 18, 2020, accepted February 7, 2020, date of publication February 11, 2020, date of current version February 20, 2020.

Digital Object Identifier 10.1109/ACCESS.2020.2973284

# Transactive Energy for Aggregated Electric Vehicles to Reduce System Peak Load Considering Network Constraints

ARSALAN MASOOD<sup>1</sup>, JUNJIE HU<sup>1</sup>, (Member, IEEE), AI XIN<sup>1</sup>, (Member, IEEE), AHMED RABEE SAYED<sup>1,2</sup>, AND GUANGYA YANG<sup>3</sup>, (Senior Member, IEEE)

<sup>1</sup>State Key Laboratory for Alternate Electrical Power System with Renewable Energy Sources, North China Electric Power University, Beijing 102206, China

<sup>2</sup>Faculty of Engineering, Cairo University, Giza 12613, Egypt

<sup>3</sup>Department of Electrical Engineering, Technical University of Denmark, 2800 Kongens Lyngby, Denmark

Corresponding author: Junjie Hu (junjiehu@ncepu.edu.cn)

This work was supported by the National Natural Science Foundation of China under Grant 51877078.

**ABSTRACT** Due to the increasing utilization of electric vehicles (EVs), future power grids may face challenges of system peak load that are usually solved by means of grid reinforcements. By providing flexibility, acquired from flexible consumers, such as EVs, the need for grid reinforcements can be avoided or postponed. Therefore, in order to solve the peak load problem, this paper focuses on the provision of flexibility services through the local market. It presents a framework for the participation of aggregated electric vehicles in the local market, considering the operating constraints of the grid. In the proposed framework, aggregators interact in a transactive, market-based manner, with a transactive energy (TE) operator and distribution system operator (DSO) to resolve operational problems. For the market-based operation, a bidding model is proposed and formulated as an optimization problem that minimizes the total cost of DSO for acquiring flexibility services from EVs. The proposed model uses EVs as flexible loads to illustrate the method, and it is tested with case-studies conducted on two IEEE test systems.

**INDEX TERMS** Demand flexibility, distributed energy resources, electric vehicles, transactive energy.

## NOMENCLATURE

### A. Indices

$m, n \in B$	Power buses
$mn \in l$	Power lines from bus $m$ to $n$
$d \in D$	Power demand
$t \in T$	Index of time
$i \in I$	Index of aggregator
$e \in E_i$	Index of electric vehicles under aggregator $i$
$j$	Power bids
$t_s$	Length of each time slot
$u$	Power generation units

### B. Constants

$N_i^E$	Number of EVs under aggregator $i$
$N_J$	Number of bids
$N_T$	Number of time slots

The associate editor coordinating the review of this manuscript and approving it for publication was Pierluigi Siano <sup>1</sup>.

$N_{agg}$	Number of aggregators
$N_B$	Number of buses

### C. Variables

$\Delta p_{i,j,t}$	flexibility bid power at aggregator $i$ , bid $j$ , time $t$
$P_{e,t}^{Ev}$	$ev^{th}$ charging power at time $t$
$P_{u,t}$	output power from a generator at time $t$
$f_{mn,t}$	power flow from bus $m$ to bus $n$ at time $t$
$\theta_{n,t}$	phase angle of bus $n$ at time $t$

### D. Parameters

$\lambda_{e,t}$	Predicted day-ahead electricity price vector
$\varphi_{i,j,t}$	Flexibility bid price for aggregator $i$ , bid $j$ , time $t$
$\overline{P}_e$	Maximum charging rate of individual EV
$E_{cap,e}$	Battery capacity of EV $e$
$\overline{P}_{i,j}$	Maximum power offered for aggregator $i$ in bid $j$

$\overline{F_{mn,t}}$	Maximum Power flow of line mn at time t
$X_{mn}$	Impedance of power line mn
$Pl_{d,t}$	Power load d at time t

## I. INTRODUCTION

With the increasing integration of distributed energy resources (DER), like electric vehicles, the ever-evolving power system needs enhanced and flexible operation [1], especially at the distribution system level, since the increasing penetration of DERs is raising challenges from an operational point of view. For instance, at the distribution level, the network's power quality may face reverse flows, voltage limit violations, and congestion problems. To address these challenges, the distribution system operator (DSO) could decide for reinforcement and extension of grids, which may not be a cost-environment friendly solution, or for an alternate solution like demand response [2], [3] programs, where, the smart grid paradigm enables the employment of demand flexibility at the distribution level.

Demand flexibility (DF) is usually used for a large customer; however small customers are also an efficient resource of flexibility [4]. To provide DF from small customers to the DSO, a new entity called an aggregator (AGR) is used, who represents these customers in electricity markets and is responsible for managing and operating their flexibility [5]. The aim of such markets, at the demand side, is to provide market access to these flexibility providers, and a support tool for the DSO to manage technical complications. To this point, the efforts on the development of appropriate market mechanisms in existing market structures are inadequate, which has impeded the full potential of DF.

To exploit the flexibility potential available at the demand side and to encourage significant involvement of the end-user in electricity markets, policymakers are paying more attention to transactive energy systems and market-based mechanisms [6], [7]. A survey on local energy markets and transactive energy systems is given in [8]. To facilitate the transactions between the buyers and the providers of DF a medium such as a regulated flexibility market is imperative. Furthermore, the new market mechanism must work in coordination with existing electricity markets, to avoid any negative impacts on other markets on account of flexibility activations [9].

In this respect, to manage flexible energy sources optimally, [10], [11] introduced a planning framework for determining the bidding curves and their focus was on price elasticity. In [12] a Universal Smart Energy Framework (USEF) for building smart energy products and services is suggested. The USEF framework aims to maximize the value of DF. Moreover, it follows a market-based coordination mechanism. Approaches examined in the relevant literature to achieve the effective participation of DF in electricity markets mostly revolve around concept development. In [13], [14], a novel market framework is proposed, which facilitates the involvement of demand flexibility in electricity markets. In the work of [15], an optimization problem is proposed

to facilitate the DSO requests on flexibility. The proposed problem is for a novel aggregator named smart energy service provider, responsible for managing all flexible energy sources. It also serves as a platform for flexibility trading in a local electricity market. Similarly, [16] proposed an algorithm for the optimal schedule of the flexible devices in both day-ahead and real-time periods. This work contributes to considering the unpredictability of flexible loads; however, it neglects grid constraints in the optimization process.

For a day-ahead market structure, [17] proposed a framework for a flexibility market called a flexibility clearinghouse. The objective of the market is to promote the integration of small scale DERs as flexibility sources. This market works in parallel to existing markets and aims to assist the DSO in mitigating grid congestions such as overloading and voltage fluctuations. Furthermore, a market mechanism called De-Flex-Market is presented in [18], [19]. It is based on the traffic lights control system and aims to offer flexibility services to the DSO to mitigate capacity constraints and avoid network reinforcements.

It is worth noting that the researches mentioned above, significantly contribute to the concept development and relevant bidding processes. However, despite its importance, the potential of DF to reduce system peak load and relieving network congestions has not been well investigated. Besides, these works have neglected grid power flow constraints, which is crucial to practically model the impact of DF. The methodology presented here builds upon the authors' previous work [20] and further advances towards proposing a pragmatic approach for the application of flexibility services in a local market at the distribution level. The contributions of this work are three-fold:

- 1) A new bidding model is proposed for the EV participation in the local market by considering the interaction between the TE operator, the DSO, and aggregators. The bidding model is formulated as an optimization problem that minimizes the total cost of DSO for acquiring flexibility services from EVs.
- 2) The optimization problem considers power flow constraints along with bidding model constraints. We show that the consideration of these constraints ensures the technically viable solution, and it is vital to model the impact of demand flexibility practically.
- 3) The effectiveness of the proposed model in response to various settings, such as with network constraints, without network constraints, a sensitivity study of aggregator prices and scalability test of the proposed model has been investigated. We highlight the need for considering the network constraints, the adeptness of the model under different prices and scalability of the model for a large test system.

The rest of this study is organized as follows. Section 2 provides the transactive energy system for aggregated electric vehicles, as well as the key actors, are introduced. The optimization problem defined in this paper is detailed in



and the interaction of aggregators with TE operator is described. Second, the DSO's operational objective is presented where a bidding model is formulated as an optimization problem to minimize the cost of DSO for acquiring flexibility service from flexible consumers, to reduce the system peak load.

**A. AGGREGATOR'S OPERATION**

The optimization problem formulated for the charging of aggregated EVs is based on the requirements of EV owners and forecasted energy prices. For the optimal charging process of EVs, several methods can be found in the literature [24]–[26]. In this study, the aggregator optimization problem proposed in [22], [25] is adopted to minimize the charging cost as well as to fulfill the EV owners charging requirements. The optimal charging schedule for EVs is generated by formulating a linear programming-based optimization problem.

The objective function given in (1) reflects the minimization of EVs charging cost and of satisfying the individual EV's energy needs for the period of the next 24 hours. For each aggregator, the solution is introduced similarly

$$\min \sum_{e=1}^{N_e^E} \sum_{t=1}^{N_T} \lambda_{e,t} P_{e,t}^{Ev} t_s \tag{1}$$

subject to

$$SOC_{0,e} \times E_{cap,e} + \sum_{ts=1}^{N_T} P_{e,t}^{Ev} t_s = \overline{SOC}_e \times E_{cap,e} \tag{2}$$

$$0 \leq P_{e,t}^{Ev} \leq \overline{P}_e \tag{3}$$

In (1),  $P_{e,t}^{Ev}$  is the optimization variable for EV charging power and  $\lambda_{e,t}$  is the DA predicted electricity price.

Equation (2) ensures the balance between the charged and requested energy for each EV. Equation (3) limits the charging rate from exceeding the maximum rate of the charger. It is crucial for aggregator(s) to provide charging locations of all schedules to DSO. It is assumed that the aggregators know the charging locations of EVs. The power requirement for each EV under aggregator  $i$  in time interval  $t$  at bus  $l$  is represented as  $P_{i,t,l}^{Ev}$  in (4). Whereas,  $i = 1, \dots, N_{agg}$ ,  $t_s = 1 \dots N_T$  and  $B = 1 \dots N_B$ .

$$P_{i,t,l}^{Ev} = \sum_{e \rightarrow B} P_{e,t,B}^{Ev} \tag{4}$$

The aggregated charging profile of electric vehicles, presented here is used by the DSO to predict the upcoming grid contingencies occurring on the subsequent day of operation. DSO is responsible for avoiding demand peaks in the system. Therefore, in the planning stage, DSO identifies the needs of acquiring flexibility services based on historical data or a time series baseload, assumed to be known. Once the need for acquiring flexibility service is determined, the DSO gathers the requirements of flexibility by identifying the type of flexibility needed, location of resources providing flexibility,

and the required quantity of flexibility [27]. After the identification of requirements, a flexibility call is activated, the DSO recommends the requested quantity of a certain type of flexibility service and all aggregators are informed. Based on the information received from the DSO, the aggregator gathers the available flexibility offers from their flexible consumers to offer ahead-bids, to satisfy the corresponding service of DSO. Ahead bids are offered to TE operator, an independent entity, who chooses the suitable offers from the aggregators and clears the market.

**B. DSO'S OPERATIONAL OBJECTIVE**

The DSO's objective is to buy flexibility and keep the network in a secure state, in response to the network operation violations caused by the charging schedule of aggregators. Therefore, the approach presented here aims to reduce the system peak load by activating the flexibility service requested by DSO in the presented framework. The DSO acquire flexibility services from the EVs to reduce the system peak load to a reasonable extent, by incurring a certain cost of flexibility. The objective function given in (5) reflects the minimization of the DSO's total cost for acquiring the flexibility service. Flexibility cost ( $\varphi$ ) under each bid comes from the flexibility contract [6], [15] between the flexibility providers and aggregators. The time resolution  $t$  is a flexible parameter in the problem; however, the trading period for one hour is considered here which is in accordance with the criteria of many European electricity markets. The TE operator, who receives information from both aggregators and the DSO, is responsible for clearing the market considering the constraints given in (6) - (14), where (6) - (10) represents bidding model equations and (11) - (14) represents network constraints. Note, for optimization variables in the bid, only active power is considered.

$$\min \sum_{t=1}^{N_T} \sum_{i=1}^{N_B} \sum_{j=1}^{N_J} \Delta p_{i,j,t} \varphi_{i,j,t} \tag{5}$$

where in (5)  $\Delta p_{i,j,t}$  represents the quantity (i.e. power needs to be reduced) for each bid and  $\varphi_{i,j,t}$  represents the price for the power reduced in period  $t$ , bid  $j$  for aggregator  $i$ . It should be noted that the objective function given in (1) provides the aggregated charging schedule, which is used to predict the peak demand in the subsequent day of operation, and by doing so identifies the need of acquiring flexibility service. Whereas, the objective function given in (5) minimizes the total cost of DSO for acquiring flexibility service and is solved by TE operator.

**1) BIDDING MODEL**

In this model, EVs are used as a flexible load, which refrains from consuming energy according to an earlier schedule, and aggregators, on behalf of EVs, bid for the flexibility it can offer. The amount of energy refrained from consuming is offered in terms of flexibility bids by the aggregator. Flexibility bids, submitted by aggregators, consist of the quantity




FIGURE 2. Quantities and prices of flexibility.

of the bid, i.e. power to be reduced for that bid  $\Delta p_{i,j,t}$  and its price  $\varphi_{i,j,t}$ . Fig. 2 illustrates the flexibility bid model with blocks of quantities and prices of flexibility based on the flexibility contracts. Bid prices of flexibility providers are sorted from the low-priced (high comfort level) to high-priced (low comfort level) offers.

Fig. 2, exemplifies a flexibility bid structure, which considers the optimal benefits to the connected EVs, i.e., the unserved power demands of EVs are penalized to guarantee the maximum social welfare for EVs. The bid price submitted by the aggregator is the optimal price that is decided by considering the profit for EVs while fulfilling their charging requirements and the profit from activating the flexibility bid to guarantee the comfort and profitability of EVs.

The flexibility contracts stipulate the details of bid power and prices. The range of bid power depends on aggregators' experience [28], whereas, the bid prices depend on several factors. According to [27] the price of offered flexibility can be constituted from activation cost of each flexible load, the operation cost of affiliated DERs, flexibility service reservation cost, and possible penalty cost as well. In practice, the prices are based on the comfort level and operating plans of flexibility providers [15]. Flexible loads with high comfort levels (i.e. less required resources to consumers) offer their flexibility at low prices as compared to the loads with a lower comfort level. Resources offering flexibility at low prices will be activated prior to the ones with high prices that are already fulfilled in the proposed bidding model. Note, that pay-as-bid structure [29] is followed here for flexibility revenues, i.e., optimal bids directly receive their bidding prices.

The bidding equations are given in (6)-(10). The bid power range for each bid offered by aggregators is given in (6-8) and it ensures that the value of load-reduced is not greater than the offered bid. The bid power balance constraint is given in (9) where power reduced for each aggregator is equal to the sum of power reduced in all bids. Equation (10) limits for the shed power for each aggregator.

$$0 \leq \Delta p_{i,j,t} \quad \forall i, j, t \quad (6)$$

$$\Delta p_{i,j,t} \leq \frac{P_{i,j} - P_{i,j-1}}{P_{i,j-1}} \quad \forall i, j, t > 1 \quad (7)$$

$$\Delta p_{i,j,t} \leq \frac{P_{i,1}}{P_{i,1}} \quad \forall i, j, t = 1 \quad (8)$$

$$\Delta p_{i,t} = \sum_{i=1}^{n_i} \Delta p_{i,j,t} \quad \forall i, t \quad (9)$$

$$P_{i,t,l}^{Ev} \geq \Delta p_{i,t} \quad \forall i, t \quad (10)$$

The model presented here advances on earlier studies by taking into account the network constraints. The effectiveness and practicality of the proposed model are shown with the consideration of power flow equations. Due to their complexity, modeling the power flow equations can be problematic. However, to practically model the impact of DF at the distribution side, considering power flow equations in the model is imperative. In addition, considering them will also have a significant impact on the activated bids, as technically infeasible bids will not be activated and hence this will modify the DSO's total cost of flexibility procurement.

## 2) POWER FLOW EQUATIONS

The power flow equations must be taken into account to only activate the technically feasible flexibility bids. Usually, the flexibility markets are operating at the distribution side, and using AC power flow is important due to the sensitivity of bus voltages on the reactive power. However, it introduces computational problems due to the non-linearity of AC power flow equations. Moreover, the presented work considers power flow equations in modeling the impact of DF. Therefore, to show the effectiveness of the proposed model, the DC power flow model, which is commonly used in the literature [30], [31] even for distribution networks [23], is considered, and AC power flow adoption is our future work. The DC power flow model is included in the optimization problem and can be considered as power flow constraints for the objective function given in (5). As a result, the power flow equations modeled in this study are given in (11)-(14). In (11) power balance equation at any node is modeled where  $D(n)$  is a subset of power loads at power bus  $n$ . The phase angle of each bus is limited through (12) and the power flow at each line or the line capacity of the network is reflected through (13). The DC power flow is calculated using (14) from the phase angle difference.

$$P_{u,t} + f_{mn,t} = \sum_{d \in D(n)} Pl_{d,t} + \sum_{i \in I(n)} (P_{i,t,l}^{Ev} - \Delta p_{i,t}) \quad \forall n, t \quad (11)$$

$$-\pi \leq \theta_{n,t} \leq \pi \quad \forall n, t \quad (12)$$

$$F_{mn,t} \leq f_{mn,t} \leq \overline{F_{mn,t}} \quad \forall mn, t \quad (13)$$

$$f_{mn,t} = \frac{\theta_{m,t} - \theta_{n,t}}{X_{mn}} \quad \forall mn, t, (m, n) \in l \quad (14)$$

## IV. CASE STUDY

In this section, the proposed methodology of acquiring the flexibility service for peak load reduction is illustrated with the help of case studies. The aim here is to present the effectiveness of the proposed methodology in the handling of multiple flexibility bids with the minimum cost incurred by the DSO. The optimization problem presented in this study is validated with the help of three case studies. In the first case study, the optimization problem is solved using bidding constraints only. In the second case study, the power flow

TABLE 1. Power requirements for aggregators during peak hours.

AGR	Bus No	No. of EVs	Power (kW) required	Power required by the number of EVs connected to each bus at Hour No.:		
				15	16	17
1	3	2	38.4	5.872	5.954	4.752
	12	3	57.6	8.808	8.931	7.128
	10	1	19.2	2.936	2.977	2.376
2	6	2	38.4	5.872	5.954	4.752
	8	1	19.2	2.936	2.977	2.376




FIGURE 3. EV charging requirement at each bus.

equations are also included with bidding constraints. The third case study, presents the sensitivity study of aggregators prices. In the last case study, the scalability test of the proposed model is presented using a modified IEEE test system.

Two aggregators, AGR1 and AGR2, managing controllable consumption in grid area are considered. The number of EVs managed by AGR1 and AGR2 is 6 and 3, respectively. In the given network, EVs are connected at different locations. The battery capacity for EVs is set to 24kWh, initial battery SOC to 20% and maximum charging power is restricted to 3.7 kW. The optimal schedules for EVs under both aggregators are calculated according to (1).

Table 1 presents the details about the number of EVs connected at each bus, total charging power required by connected EVs for whole charging period and charging power needed by connected EVs during peak hours i.e. hour number 15, 16 and 17. The charging requirement for electric vehicles connected at each bus is given in fig. 3. It can be seen from the figure that hours with high power requirements are at the start of the charging period.

The scheduling period for EVs, considered here is from 14 to 4 and an hourly interval is used. The baseload profile of the system with an aggregated charging schedule, for the day-ahead operation, and actual market prices in €/kWh obtained from the Nord pool market [32] is given in fig. 4. Based on the aggregated charging schedule and baseload profile, the expected load at hours 15 to 17 will cause a peak in demand. It can be addressed by either reinforcing the network or by acquiring flexibility services from customers, i.e. to reduce consumption at peak hours. In this study,




FIGURE 4. Load profile with aggregated EV charging schedule and market prices.

flexibility service is used to handle this peak load during hours 15 to 17.

**A. CASE STUDY I: OVERLOAD MANAGEMENT BY DEMAND FLEXIBILITY WITHOUT CONSIDERING POWER FLOW CONSTRAINTS**

In order to test the proposed model without network constraints, this section provides a case study assuming that the flexibility bid powers, which are based on the different comfort levels of EV owners, are known by the aggregators. Note that the flexibility service prices are independent of actual market prices and depend on competition and contracting agreement of aggregators. Moreover, a small number of electric vehicles are considered here to illustrate the proposed model; however, it is scalable to include a large number of EVs. Power requirements for both aggregators, at hours of peak load, are given in table 1.

After receiving the requested amount of power reduced and offered aggregated bids, the TE operator is responsible for determining the suitable bids and prices, which accounts for required load reduction. According to fig. 4, the hours at which load reduction is required are hours 15, 16 and 17. Hour 15 is considered here to illustrate the effectiveness of the proposed method. Based on the comfort level of EV owners, each aggregator submits its bids with the number of EVs they will refrain from charging at peak hours.

Table 2 presents the aggregated bids (AGRBID) offered by AGRs and the power requirement of each EV under both aggregators for hour 15. In addition, the amount of bid power and, their corresponding prices based on EV owners' comfort level are also shown. It should be noted from the table that the flexibility offered by AGR1 and AGR2 under each bid is in ascending order according to price. High prices reflect the level of customers' sensitivity to alter their charging plans. Moreover, each bid is sorted from the cheapest offer to the most expensive one, and the expensive prices show the unwillingness of the AGR for the flexibility to be activated.

The aggregated bids for both aggregators at each bus includes different blocks of flexibility. AGR1BID1 includes

**TABLE 2.** Power requirement and flexibility offered at Hour 15.


AGRBIDs	Bus No	No. of EVs	At Hour 15	Bid Power	Bid Price
			kW	kW	€/kWh
AGR1	BID1	3	2	1.761	5.45
				1.174	5.72
				0.881	6.19
				2.056	6.41
				2.202	5.63
				0.882	5.75
				1.805	6.42
				2.595	6.77
				1.468	5.72
				1.468	6.12
AGR2	BID1	6	2	2.936	5.29
				2.936	5.92
				2.936	5.53

**TABLE 3.** Power reduced for each aggregator bid in day-ahead operation at peak hours without power flow constraints.


AGRBIDs	Hour 15		Hour 16		Hour 17	
	kW	€	kW	€	kW	€
AGR1BID1	1.7616	9.6	1.786	10.7	1.426	7.0
	0.276	1.58	1.191	7.4	0.301	1.64
AGR1BID2	2.202	12.4	0.870	5.3	0.70	3.34
			0.620	4.1		
AGR1BID3	1.468	8.4	1.489	9.37	1.188	5.5
AGR2BID1	2.936	15.5	2.977	16.9	2.376	11.9
			2.977	17.2	2.376	12.5
AGR2BID2	2.936	16.2	2.977	18.2	2.376	11.8

four blocks of flexibility, BID2 includes five blocks and BID3 includes two blocks of flexibility, whereas, AGR2BID1 and AGRBID2 include two and one blocks of flexibility, respectively. Blocks of flexibility, under each bid, are arranged in a non-decreasing manner based on their prices. Flexible power offered by AGR1 under each bid depends on the comfort level of EV owners. The difference in prices for different blocks of flexibility, as seen in Table 2, can be justified as the precedence of EV owner to change its charging plan. Table 3 summarizes the result of activated blocks from AGRBIDs without power flow constraints, by the TE operator, for peak hours.

The optimal combination of bids activated for load reduction from both aggregators is illustrated in Fig. 5. The flexibility activated in the first bid of AGR1 is 2.0376 kW, where the first block of bid1 is activated in full and from the second block, only a part of the bid is activated as shown in Fig. 5(a). In the second bid, the only first block is activated with the amount of 2.2021 kW as shown in Fig. 5(b), whereas, for the third bid, one block offered in this bid is activated completely corresponding to the amount of 1.4680 kW as shown in Fig. 5(c). Moreover, For AGR2, the first block was activated from bid 1, not selecting the second block, and the bid 2 flexibility offer was activated in full, as shown in Fig. 5(d-e).



**FIGURE 5.** Without Power flow constraints (a-c) bids for AGR1 and (d-e) bids for AGR2.



**FIGURE 6.** Bus system with EV load.

**B. CASE STUDY II: OVERLOAD MANAGEMENT BY DEMAND FLEXIBILITY CONSIDERING POWER FLOW CONSTRAINTS**

Here, the power flow equations are included along with the bidding constraints in the optimization problem. The proposed method is tested on IEEE 13 bus system with two aggregators where the battery capacity, initial SOC and maximum charging power for both aggregators are considered the same. Fig. 6 depicts the topology of the power system used

**TABLE 4. Power reduced for each aggregator bid in day-ahead operation at peak hours with power flow constraints.**


AGRBIDs	Hour 15		Hour 16		Hour 17	
	power kW	cost €	power kW	Cost €	power kW	cost €
AGR1BID1	1.7616	9.6	1.768	10.7	1.426	7.0
AGR1BID2	2.202	12.4	0.871	5.31	0.695	3.32
AGR1BID3	0.776	4.45	1.489	9.4	1.188	5.47
AGR2BID1	2.936	15.6	2.977	16.9	2.376	11.9
AGR2BID2	0.967	5.73	2.977	17.3	2.376	12.5
	2.936	16.3	2.977	18.2	2.376	11.8
	11.58		17.12		12.52	

and the details of the bus system with EV loads are provided in [33].

Each bus is feeding different loads including several DERs, electric vehicles in our study, with a different comfort level. DERs with high comfort levels (less sensitive and can easily provide flexibility) offer flexibility at lower prices as compared to lower comfort level DERs. Similar to the first case study, the number of EVs connected here are 6 for aggregator 1 and 3 for aggregator 2. In the given network, EVs are used for flexibility services and are connected at five different buses. The test system has 8 loads connected at different buses and EVs are connected with buses 3, 6, 8, 10, and 12. EVs connected at bus 3, 10 and 12 are managed by the AGR1 whereas; EVs at bus 6 and 8 are managed by the AGR2. The flexibility power bid and prices are the same as those considered in the previous case study. The TE operator selects the optimal bids for peak load reduction while respecting the network constraints.

With the network constraints, the optimal bids activated to reduce peak load are illustrated in Fig. 7. For AGR1BIDs, the flexibility blocks activated from first, second and third bids amount to 1.7616 kW, 2.2021kW and 0.77674kW, respectively, as shown in Fig. 7(a-c). The first flexibility blocks of both BID1 and BID2 are activated in full, and remaining are not activated as shown in Fig. 7(a) and 7(b), respectively, whereas, flexibility activated from BID3 is only a part of the block as shown in Fig. 7(c). Furthermore, for AGR2BIDs, in BID1, the first block is activated along with some power from the second block with a total amount of 3.9034kW as shown in Fig. 7(d) and, the BID2 were activated in full, as shown in Fig. 7(e).

It should be noted from Fig. 5 and 7 that the amount of flexibility activated under different bids when power flow constraints are included is different when compared with flexibility activated without power flow constraints. Although the total amount of power activated under all bids (i.e. 11.58 kW, 17.12 and 12.52 for Hour 15, 16 and 17, respectively) in both cases is similar, the activated bids and their shed power are different in case of using the power flow constraints. That indicates the importance and effectiveness of considering the power system constraints. Table 4 summarizes the result



**FIGURE 7. With Power flow constraints (a-c) activated bids for AGR1 (d-e) activated bids for AGR2.**

of activated blocks, with power flow constraints, at peak hours.

**C. CASE STUDY III: SENSITIVITY STUDY OF AGGREGATOR PRICES**

In this scenario, we have emphasized on the analysis of the sensitivity study for different aggregator prices. In the first case, the bid prices are assumed based on the discussion given in section III. These prices are used to calculate the total cost incurred by DSO for total power shed at peak hours for each aggregator. In the second case, it is assumed that AGR1 changes its bidding price and bids only 90 % of its original prices. Similarly, in the third case, AGR1 bids 70% of the base price. The effect of this change in strategy can be seen from Table 5, where the total cost incurred by DSO and total power reduced for AGR1 and AGR2 change.

If the prices for AGR1 is changed to 90% from the base price, the total power reduces for AGR1 and AGR2 changes merely, however, a significant change can be observed in the

**TABLE 5.** Change in pricing strategy from one aggregator.

Prices		Total Power reduced kW		Total DSO Cost €	
AGR1	AGR2	AGR1	AGR2	AGR1	AGR2
Base	Base	18.334	22.898	102.17	126.23
90%	Base	18.133	23.099	120.65	96.54
70%	Base	23.82	17.412	93.638	96.51
60%	Base	23.82	17.412	80.53	96.51

total DSO cost for each aggregator. If the price for AGR1 is changed to 70% of its base price, the power reduced and the total cost of DSO for each aggregator changes significantly. Owing to lower prices than AGR2, the complete flexibility offered by AGR1 is selected first whereas the remaining flexibility power is selected from AGR2. If the price is lowered further, the total power reduced does not change as the offered power from AGR1 is selected first however, the price for AGR1 is reduced further.

**D. CASE STUDY IV: SCALABILITY TEST OF THE PROPOSED MODEL**

In this section, we select a modified IEEE 123-Bus power system with 5 aggregators and 340 electric vehicles, connected at different busses, as a largescale test system. The proposed bidding model is used to determine its scalability. The test system topology, parameters, and flexibility power bid and prices are described in further detail in [33]. The system has 124 power lines, 10 power generators, 85 power loads, and 340 electric vehicles connected at 13 different buses. EVs connected at bus 4, 5 and 6 are managed by the AGR1, EVs at bus 19, 20 and 22 are managed by the AGR2, AGR3 manages the EVs connected at bus 41, 43 and 46. AGR4 manages the EVs connected at bus 82, 83 and AGR5 manages the EVs connected at bus 104, 107. The TE operator selects the optimal bids for peak load reduction while respecting the network constraints.

Table 6 summarized the numerical results under different cases, namely, the small system without and with power system constraints, the modified IEEE 123-bus system without and with power system constraints, respectively. The operational cost of DSO, the total power reduced by all aggregators during the flexibility activation, and the total execution time are listed. The total costs of aggregated charging schedules during and after solving the network security violations are also mentioned in the table.

From table 6, for a small test system, consideration of network constraints has caused an increase in the total cost incurred by DSO for acquiring flexibility services. Moreover, the consideration of network constraints also affects the total unserved power, which can be equal or more than the power unserved without considering network constraints. The aggregator’s net cost before bidding is similar for both cases however after the bidding model is executed the aggregator’s net cost has increased for considering network constraints due

**TABLE 6.** Simulation results of bidding model under different system settings.

Case	Total Cost incurred by DSO (€)	Un-served Power (kWh)	Aggregators Net Cost (€)		Computational time (s)
			Before bidding	After bidding*	
#1	212.67	39.35	5.84×103	6.05×103	1.03
#2	228.40	41.22	5.84×103	6.06×103	5.21
#3	1.82×103	337.64	95.88×103	97.70×103	4.79
#4	2.70×103	501.21	95.88×103	98.58×103	22.67

\*the total costs of aggregator including the revenue from the unserved power

to the increase in the DSO flexibility cost. Similarly, for a large test system, the increase in DSO flexibility cost and aggregator net cost after the bidding is more significant when network constraints are considered. For a large test system, the cost incurred by DSO with no network constraints is increased by 49% with network constraints and the net cost of aggregators is increased by 1% as compared to without network constraints. In the end, the computation time (s) for all four cases is presented. With the inclusion of network constraints in the bidding model, the computational time increased. The computational time is influenced more by the large test system than the small test system. However, due to the linearity of the proposed model along with DC power flow equations, the proposed model is executed in a very fast time.

**V. CONCLUSION AND FUTURE WORK**

A market-based control framework is presented to facilitate the interaction of the AGR, the DSO, and the TE operator. In the presented model, the aggregators’ role is to perform two tasks (1) energy profile of aggregated charging schedule (2) interaction with the TE operator in case of need for activating flexibility service. On the other hand, the TE operator is responsible for determining the activated flexibility bids for all aggregators and DSO to reduce system peak load. For this purpose, an optimization problem is formulated that models the total cost incurred by DSO while respecting the network constraints. To illustrate the effectiveness of the proposed methodology numerical simulations has been conducted on two test systems. The results show that the proposed bidding model optimally provides the decisions for the TE operator, who coordinates the decision with the DSO and flexibility providers. Consideration of power system constraints provides different solutions to the TE, which indicates the effectiveness of the proposed model to activate only the technical feasible flexibility bids. In addition, the sensitivity of aggregators’ prices has been discussed to show the adeptness and optimality of the model. Finally, computational efficiency analysis has been validated by a modified IEEE 123-Bus system interacted with five aggregators to deliver power for 340 EVs. The results show that the overall framework can be solved in less time, as the model is based on linear programming.

Future work includes the consideration of EV driving patterns, battery degradation for a more accurate model, considering the impact of EV load on voltage constraints, therefore, adoption of the AC-power flow model and understanding the impact of activating flexibility in real-time operation.

## REFERENCES

- [1] J. Villar, R. Bessa, and M. Matos, "Flexibility products and markets: Literature review," *Electr. Power Syst. Res.*, vol. 154, pp. 329–340, Jan. 2018.
- [2] W.-T. Li, C. Yuen, N. U. Hassan, W. Tushar, C.-K. Wen, K. L. Wood, K. Hu, and X. Liu, "Demand response management for residential smart grid: From theory to practice," *IEEE Access*, vol. 3, pp. 2431–2440, 2015.
- [3] P. Siano and D. Sarno, "Assessing the benefits of residential demand response in a real time distribution energy market," *Appl. Energy*, vol. 161, pp. 533–551, Jan. 2016.
- [4] A. Vijay and A. Hawkes, "Demand side flexibility from residential heating to absorb surplus renewables in low carbon futures," *Renew. Energy*, vol. 138, pp. 598–609, Aug. 2019.
- [5] N. G. Paterakis, O. Erdinc, and J. P. S. Catalão, "An overview of Demand Response: Key-elements and international experience," *Renew. Sustain. Energy Rev.*, vol. 69, pp. 871–891, Mar. 2017.
- [6] P. Olivella-Rosell, P. Lloret-Gallego, I. Munné-Collado, R. Villafafila-Robles, A. Sumper, S. Ottesen, J. Rajasekharan, and B. Bremdal, "Local flexibility market design for aggregators providing multiple flexibility services at distribution network level," *Energies*, vol. 11, no. 4, p. 822, Apr. 2018.
- [7] C. Rosen and R. Madlener, "Regulatory options for local reserve energy markets: Implications for prosumers, utilities, and other stakeholders," *Energy J.*, vol. 37, pp. 39–50, May 2016.
- [8] P. Siano, G. De Marco, A. Rolan, and V. Loia, "A survey and evaluation of the potentials of distributed ledger technology for peer-to-peer transactive energy exchanges in local energy markets," *IEEE Systems J.*, vol. 13, no. 3, pp. 3454–3466, Sep. 2019.
- [9] S. Minniti, N. Haque, P. Nguyen, and G. Pemen, "Local markets for flexibility trading: Key stages and enablers," *Energies*, vol. 11, no. 11, p. 3074, Nov. 2018.
- [10] M. Song and M. Amelin, "Price-maker bidding in day-ahead electricity market for a retailer with flexible demands," *IEEE Trans. Power Syst.*, vol. 33, no. 2, pp. 1948–1958, Mar. 2018.
- [11] M. Song and M. Amelin, "Purchase bidding strategy for a retailer with flexible demands in day-ahead electricity market," *IEEE Trans. Power Syst.*, vol. 32, no. 3, pp. 1839–1850, May 2017.
- [12] (2015). Universal Smart Energy Framework (USEF): The Framework Explained, USEF Foundation, Arnhem, The Netherlands. Accessed: Dec. 25, 2019. [Online]. Available: [http://www.globalsmartgridfederation.org/wp-content/uploads/2016/10/USEF\\_TheFrameworkExplained-18nov15.pdf](http://www.globalsmartgridfederation.org/wp-content/uploads/2016/10/USEF_TheFrameworkExplained-18nov15.pdf)
- [13] D. Papadaskalopoulos and G. Strbac, "Decentralized participation of flexible demand in electricity markets—Part I: Market mechanism," *IEEE Trans. Power Syst.*, vol. 28, no. 4, pp. 3658–3666, Nov. 2013.
- [14] D. Papadaskalopoulos, G. Strbac, P. Mancarella, M. Aunedi, and V. Stanojevic, "Decentralized participation of flexible demand in electricity markets—Part II: Application with electric vehicles and heat pump systems," *IEEE Trans. Power Syst.*, vol. 28, no. 4, pp. 3667–3674, Nov. 2013.
- [15] P. Olivella-Rosell, E. Bullich-Massagué, M. Aragüés-Peñalba, A. Sumper, S. Ø. Ottesen, J.-A. Vidal-Clos, and R. Villafafila-Robles, "Optimization problem for meeting distribution system operator requests in local flexibility markets with distributed energy resources," *Appl. Energy*, vol. 210, pp. 881–895, Jan. 2018.
- [16] M. Diekerhof, F. Peterssen, and A. Monti, "Hierarchical distributed robust optimization for demand response services," *IEEE Trans. Smart Grid*, vol. 9, no. 6, pp. 6018–6029, Nov. 2018.
- [17] K. Heussen, D. E. M. Bondy, J. Hu, O. Gehrke, and L. H. Hansen, "A clearinghouse concept for distribution-level flexibility services," in *Proc. IEEE PES IGT Europe*, Oct. 2013, pp. 1–5.
- [18] *Decentralized Flexibility Market: A Market-Based Solution for Organizing*, Bundesverband Neuer Energieanbieter, Berlin, Germany, 2015, pp. 1–5.
- [19] *Decentralized Flexibility Market 2.0*, Bundesverband Neuer Energieanbieter, Berlin, Germany, 2016, pp. 1–12.
- [20] A. Masood, A. Xin, J. Hu, S. Salman, A. R. Sayed, and M. U. Jan, "FLECH services to solve grid congestion," in *Proc. 2nd IEEE Conf. Energy Internet Energy Syst. Integr. (EI)*, Oct. 2018, pp. 1–5.
- [21] O. Sundstrom and C. Binding, "Flexible charging optimization for electric vehicles considering distribution grid constraints," *IEEE Trans. Smart Grid*, vol. 3, no. 1, pp. 26–37, Mar. 2012.
- [22] J. Hu, G. Yang, H. W. Bindner, and Y. Xue, "Application of network-constrained transactive control to electric vehicle charging for secure grid operation," *IEEE Trans. Sustain. Energy*, vol. 8, no. 2, pp. 505–515, Apr. 2017.
- [23] H. Mohsenian-Rad and A. Davoudi, "Towards building an optimal demand response framework for DC distribution networks," *IEEE Trans. Smart Grid*, vol. 5, no. 5, pp. 2626–2634, Sep. 2014.
- [24] M. F. Shaaban, A. A. Eajal, and E. F. El-Saadany, "Coordinated charging of plug-in hybrid electric vehicles in smart hybrid AC/DC distribution systems," *Renew. Energy*, vol. 82, pp. 92–99, Oct. 2015.
- [25] J. Hu, S. You, M. Lind, and J. Ostergaard, "Coordinated charging of electric vehicles for congestion prevention in the distribution grid," *IEEE Trans. Smart Grid*, vol. 5, no. 2, pp. 703–711, Mar. 2014.
- [26] W. Jiang and Y. Zhen, "A real-time EV charging scheduling for parking lots with PV system and energy store system," *IEEE Access*, vol. 7, pp. 86184–86193, 2019.
- [27] C. Zhang, Y. Ding, N. C. Nordentoft, P. Pinson, and J. Østergaard, "FLECH: A Danish market solution for DSO congestion management through DER flexibility services," *J. Mod. Power Syst. Clean Energy*, vol. 2, no. 2, pp. 126–133, Jun. 2014.
- [28] S. S. Torbaghan, N. Blaauwbroek, D. Kuiken, M. Gibescu, M. Hajighasemi, P. Nguyen, G. J. M. Smit, M. Roggenkamp, and J. Hurink, "A market-based framework for demand side flexibility scheduling and dispatching," *Sustain. Energy, Grids Netw.*, vol. 14, pp. 47–61, Jun. 2018.
- [29] P. D. Río, "Designing auctions for renewable electricity support. Best practices from around the world," *Energy Sustain. Develop.*, vol. 41, pp. 1–13, Dec. 2017.
- [30] B. Stott, J. Jardim, and O. Alsac, "DC power flow revisited," *IEEE Trans. Power Syst.*, vol. 24, no. 3, pp. 1290–1300, Aug. 2009.
- [31] A. R. Sayed, C. Wang, and T. Bi, "Resilient operational strategies for power systems considering the interactions with natural gas systems," *Appl. Energy*, vol. 241, pp. 548–566, May 2019.
- [32] *Nord Pool*. Accessed: Oct. 30, 2019. [Online]. Available: <https://www.nordpoolgroup.com/>
- [33] *Personal Website for Data Sheet*. Accessed: Jan. 5, 2020. [Online]. Available: <https://sites.google.com/view/arsalanmasood/home>



**ARSALAN MASOOD** received the M.S. degree from the Department of Electrical Engineering, COMSATS University Islamabad, Islamabad, Pakistan, in 2016. He is currently pursuing the Ph.D. degree with the School of Electrical and Electronic Engineering, North China Electric Power University, Beijing, China. His research interests include distributed energy resource integration with a focus on electric vehicles, DER flexibilities, and electricity markets.



**JUNJIE HU** (Member, IEEE) received the M.Sc. degree in control theory and control engineering from Tongji University, China, in 2010, and the Ph.D. degree in electrical engineering from the Technical University of Denmark, Denmark, in 2014. He was a Postdoctoral Researcher with the Department of Electrical Engineering, Technical University of Denmark. He is currently an Associate Professor with the School of Electrical and Electronic Engineering, North China Electric Power University. His current research interests include distributed energy resources energy management, transactive energy, prosumers energy management, and multienergy system optimization.




**AI XIN** (Member, IEEE) received the B.S. degree from the Nanjing Institute of Technology, Nanjing, China (now Southeast University), the M.S. degree from the China Electric Power Research Institute, Beijing, China, and the Ph.D. degree from North China Electric Power University (NCEPU), Beijing, in 1985, 1988, and 1999, respectively, all in electrical engineering. He was a Senior Research Scholar with Brunel University, London, U.K., in 2003. He was the Director of the Institute

of Power Systems, where he was engaged in research and teaching on power system and automation. He is currently a Professor and a Doctoral Tutor with the School of Electrical and Electronic Engineering, NCEPU. His current research interests include power system analysis and control, and transactive energy.



**AHMED RABEE SAYED** received the B.Sc. and M.Sc. degrees in electrical engineering from Cairo University, Giza, Egypt, in 2013 and 2016, respectively. He is currently pursuing the Ph.D. degree with the School of Electrical and Electronic Engineering, North China Electric Power University, Beijing, China. He has been with the Department of Electrical Power and Machines Engineering, Cairo University, as an Associate Lecturer, since 2016. His current research interests include the

economic and secure operation of integrated energy systems, renewable energy integration, and electricity markets.



**GUANGYA YANG** (Senior Member, IEEE) received the B.E., M.E., and Ph.D. degrees in electric power system, in 2002, 2005, and 2008, respectively. He is currently an Associate Professor with the Center for Electric Power and Energy, Department of Electrical Engineering, Technical University of Denmark, Kongens Lyngby, Denmark. Since 2009, he has been with the Technical University of Denmark as a Postdoctoral Researcher and has been leading several industrial collaborative projects in Denmark in the field of monitoring, operation, and protection of renewable energy systems. His research interests include renewable energy integration, smart grids, and cyber-physical energy systems.

His research interests include renewable energy integration, smart grids, and cyber-physical energy systems.

...