Performance of Recent Optimization Algorithms and Its Comparison to State-of-the-Art Differential Evolution and Its Variants for the Economic Optimization of Cooling Tower

Patel, Vivek K.; Raja, Bansi D.; Savsani, Vimal J.; Desai, Nishith B.

Published in:
Archives of Computational Methods in Engineering

Link to article, DOI:
[10.1007/s11831-021-09529-2](https://doi.org/10.1007/s11831-021-09529-2)

Publication date:
2021

Document Version
Peer reviewed version

[Link back to DTU Orbit](#)

Citation (APA):
Patel, V. K., Raja, B. D., Savsani, V. J., & Desai, N. B. (2021). Performance of Recent Optimization Algorithms and Its Comparison to State-of-the-Art Differential Evolution and Its Variants for the Economic Optimization of Cooling Tower. *Archives of Computational Methods in Engineering*, 28, 4523–4535.
<https://doi.org/10.1007/s11831-021-09529-2>

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Performance of recent optimization algorithms and its comparison to state-of-the-art Differential evolution and its variants for the economic optimization of cooling tower

Vivek K. Patel*

Department of Mechanical Engineering

School of Technology, Pandit Deendayal Petroleum University, Gandhinagar, Gujarat, India

E-mail: vivekp@sot.pdpu.ac.in

Bansi D. Raja

Department of Mechanical Engineering,

Indus University, Ahmedabad, Gujarat, India

E-mail: bansi14.raja@gmail.com

Vimal J. Savsani

Department of Engineering,

Canadore College, North Bay, ON, Canada

E-mail: vimal.savsani@canadorecollege.ca

Nishith B. Desai

Department of Mechanical Engineering,

Technical University of Denmark, 2800 Kongens Lyngby, Denmark

E-mail : nbdes@mek.dtu.dk

* Corresponding author

Abstract

Present work explores the quantitative and qualitative performance investigation of nine recently developed optimization algorithm along with state-of-the-art differential evolution and its variants for the economic optimization of cooling tower. Quantitative performance of the competitive algorithms evaluated based on the best solution, mean solution, success rate, and standard deviation results. Qualitative performance comparison of competitive algorithms obtained through statistical analysis of the obtained results. Statistical analysis is carried out with two different scenarios to identify the qualitative performance of recently developed algorithms alone and in the presence of state-of-the-art differential evolution and its variants. The effect of different constraint handling methods on the performance of the competitive algorithms is identified and presented. The behaviour of all competitive algorithms is verified for sensitiveness of constraints. Finally, the convergence behaviour of the competitive algorithm in obtaining the minimum total cost solutions is also obtainable and discussed.

Key words

Optimization algorithms; Comparative performance; Statistical analysis; Convergence comparison; Constraint handling methods

1. Introduction

In the last demi-decade, researchers proposed variety of evolutionary optimization algorithms for addressing the optimization problems associated with different field of science and engineering. These algorithms are inspired from the various natural phenomenon such as social behaviour of swarms, biology evolution, laws of nature, laws of chemical or physics etc. These algorithms were experimented on the various constraint and unconstrained

benchmark functions by the developers to prove the effectiveness of their algorithms. At later stage, these algorithms also applied for the optimization of different engineering and science application by the researchers across glob. In addition to that modified and hybrid versions of these algorithms are also proposed by the researchers and experiment on the various real life optimization problem. Performance of the modified and hybrid version of these algorithms seems to be improved as compared to the basic version.

Few such evolutionary algorithms developed in the recent past are Squirrel search algorithm (SSA) [1], Harris hawks optimization algorithm (HHO) [2], Marine Predators Algorithm (MPA) [3], Grey wolf optimizer (GWO) [4], Equilibrium optimizer (EO) [5], Sailfish Optimizer (SFO) [6], Spotted hyena optimizer (SHO) [7], Henry gas solubility optimization (HGSO) [8], Pathfinder algorithm (PFA) [9], Salp swarm (SS) algorithm [10], Cuckoo search algorithm (CSA) [11], Heat transfer search (HTS) [12], Water wave optimization (WWO) [13], Yin-Yang-pair Optimization [14], Ant lion optimizer (ALO) [15], Artificial flora (AF) algorithm [16], Sine-cosine algorithm (SCA) [17], Dragonfly algorithm (DA) [18], Electro-search (ES) algorithm [19], Mouth brooding fish (MBF) [20] etc. The researcher proposed these algorithms with the aim of enhancing the performance of evolutionary computation. The literature survey reveal that these algorithms applied for the optimization of various engineering application belonging to mechanical, civil, electrical, chemical, computer and other allied branches.

For the assessment of the evolutionary optimization algorithm, a competition known as “Congress on Evolutionary Computation” (CEC) is organised almost every year [21]. A common platform provided in CEC to experiment and compares the results of various evolutionary algorithms to identify the winner algorithm. However, it can be observed from the literature survey that majority of the evolutionary algorithms developed in the last demi-decade were not a winner algorithm of the CEC competition. In fact, majority of these

algorithms even not participated in this competition. On the other hand, these algorithms applied successfully on various real life optimization problems. The state-of-the-art evolutionary optimization algorithms such as Differential evolution (DE) [22] and its variants like Self adaptive DE (SaDE) [23], linear population size reduction DE (L-SHADE) [24] etc. quite often win the CEC competition. However, the literature reveal the quite few study involving the comparative performance of these state-of-the-art optimization algorithms and various recently developed algorithms for the optimization of engineering applications.

Cooling towers are one of the important energy conservation equipment used in power plant. Cooling tower is used to cool the condenser water of the power plant. In general, the cost effective design of cooling tower can be achieved by optimizing its operating variables [25]. These variables includes continuous, discrete, and integer characteristic. Additionally, the optimized geometry should satisfy various constraints having linear and nonlinear characteristic. The optimization problem of cooling tower is multi-model in nature. Further, the numbers as well as types of variables and constraints are also change with the type of cooling tower. Application of few established algorithms like GA, DE, PSO, and ABC for the economic optimization of cooling tower is available in literature. For instant, Singh and Das [26, 27] adapted genetic algorithm (GA) for the parameter optimization of the cooling tower. Rao and Patel [28] implemented artificial bee colony (ABC) algorithm for the optimization of mechanical draft cooling tower. Ozcan et al. [29] put an effort to optimize the cost of air cooling system of a cooling tower through Particle swarm optimization (PSO) and DE algorithms. On the other side, majority of evolutionary algorithms developed in the last demi decades yet not explore for the cooling tower optimization. Hence, the comparative performance of such recently developed algorithms with state-to-art algorithm yet not observed in the literature.

In the proposed work, nine recently developed optimization algorithms are investigated and their performances are measured with respect to state-of-the art DE, SaDE, and L-SHADE. The main purpose of the present work are (i) to evaluate effectiveness of recently developed algorithms such as EO, SFO, SSA, SHO, HHO, MPA, PFA, MBF, and HGSO along with state-of-art DE, SaDE, and L-SHADE for the economic optimization of cooling tower (ii) performance comparison of the considered recently developed algorithm with state-of-art DE and its variant (iii) evaluate the effect of different constraint handling methods on the performance of comparative algorithms (iv) identify the behaviour of all competitive algorithms for sensitiveness of constraints. (v) assess the convergence performance of the competitive algorithms. Ability of each algorithm is demonstrated by attempting the case study of mechanical draft counter flow wet cooling tower. The organisation of the remaining paper includes brief description of recently developed and state-of-the-art metaheuristic (Section 2); objection function formulation and constraints description (Section 3); attempt case study and result-discussion (Section 4); and finally the conclusion of the present investigation describe in section 5.

2. Recently developed and state-of-the-art optimization algorithms

This section presents the brief description of the recently developed metaheuristic along with state-of-the-art DE, SaDE, and L-SHADE experimented in this work. The principal aspect of each algorithm is present in this section. The readers can get the detail description and working of the particular algorithms from the mention references.

2.1 Spotted hyena optimizer

Dhiman and Kumar [7] proposed the spotted hyena optimizer (SHO) algorithm. The SHO inspired from the intelligent behaviour of spotted hyena and mimic the collaborative hunting behaviour of spotted hyenas. The hunting behaviour of the spotted hyena consists of

three basic steps and so as the SHO algorithm. These three steps of the SHO algorithm mimic the searching, encircling, and attacking prey behaviour of the spotted hyena.

2.2 Mouth brooding fish algorithm

Jahani and Chizari [20] proposed the mouth brooding fish (MBF) algorithm. The MBF is swarm intelligence based metaheuristic. The MBF algorithm inspire from the movement of one of the underwater creature ‘mouth brooding fish’. The MBF algorithm simulates the intelligent behaviour of the mouth brooding fish to protect their offspring. This intelligent behaviour includes movement, dispersion and protection of mouth brooding Fish.

2.3 Squirrel search algorithm

Jain et al. [1] proposed the squirrel search algorithm (SSA). The SSA inspired from the intelligent foraging behaviour of southern flying squirrels. The SSA mimics the food searching, storage and utilization ability of the flying squirrel exhibit in the different climate throughout their lifecycle. The SSA mathematically modelled the dynamic foraging strategy and gliding mechanism of flying squirrels.

2.4 Sailfish optimizer

Sailfish Optimizer (SFO) is a population oriented metaheuristic algorithm proposed by Shadravan et al. [6]. The SFO algorithm inspired from the group hunting behaviour of sailfish. The SFO algorithm simulated the search, attack-alternation, hunting and catching prey behaviour of sailfish. The SFO consists of two tips of populations, sailfish population and sardines population.

2.5 Pathfinder algorithm

Yapici and Cetinkaya [9] proposed the pathfinder algorithm (PFA). The PFA imitate cooperative movement of animal group. The algorithm simulates the leadership behaviour and social interaction of the animal group in search of food area or prey. Every individual in

the animal group changes their position and follow the pathfinder during the process of food search.

2.6 Harris hawks optimization

Heidari et al. [2] presented harris hawks optimization (HHO) algorithm. The HHO algorithm inspired from the supportive behaviour and chasing style of Harris' hawks bird of prey. In nature, several harris hawks pounce and chase prey from different direction considering the escaping pattern of prey. The HHO algorithm simulates the seven skill strategy of harris hawks to hunt and capture a prey.

2.7 Henry gas solubility optimization

Hashim et al. [8] proposed henry gas solubility optimization (HGSO) algorithm. The HGSO is a physics law based algorithm that imitates Henry's law of gas solubility. The Henry's law correlate amount of gas dissolved in a given volume of liquid at constant temperature. The HGSO algorithm simulates the same huddling behaviour of gas mathematically to form optimization algorithm.

2.8 Marine predator algorithm

Faramarzi et al. [3] proposed marine predator algorithm (MPA). The MPA algorithm inspired from the foraging strategy of marine predators. The marine predator exhibit two policies namely Lévy and Brownian motion for foraging. The foraging process of the marine predators is based on the three conditions depending on the velocity ratio of the predator and prey. Likewise, the MPA algorithm is also working in three phases.

2.9 Equilibrium optimizer

The Equilibrium optimizer (EO) algorithm, proposed by Faramarzi et al. [5], is a metaheuristic inspired by the conservation of mass theory. The EO algorithm simulates the mass balance principles applied to any control volume in order to evaluate the unknown concentration of a constituent. The search mechanism of the EO algorithm depends on the

three important term know as equilibrium concentration (belonging to equilibrium pool), concentration difference, and generation rate.

2.10 Differential evolution algorithm

Storn and Price [22] proposed differential evolution (DE) algorithm. The algorithm works with control parameters namely crossover, mutation, and selection operator. The algorithm performs the exploration of the search space through mutation operation and exploitation through selection operation. Further, the DE algorithm employed greedy selection operator for the fast convergence rate.

2.11 Self-adaptive differential evolution

Qin and Suganthan [23] incorporate the self-adaptation strategy in the DE algorithm and proposed self-adaptive differential evolution (SaDE) algorithm. The learning strategy and control parameter of DE algorithm are self-adapted in the SaDE variant based on the previous learning experience. This behaviour of SaDE algorithm makes it highly consistent and produces promising results on variety of problems having different characteristics.

2.12 Linear population size reduction differential evolution

Linear population size reduction differential evolution (L-SHADE) is an improved version of success-history based adaptive differential evolution (SHADE) algorithm proposed by Tanabe and Fukunaga [24]. L-SHADE used linear population size reduction to reduce the population linearly with function evaluation. The population size reduction strategy enhances the performance of L-SHADE very effectively. The L-SHADE had been successfully applied to various CEC benchmark problems.

3. Objective function formulation and constraints description

Typically the cooling tower is used to cool the condensing water in the power plant. Majority, mechanical draft cooling towers are used for such purpose. Present work focused

on the economic optimization of cooling tower. Minimization of total annual cost (C_{tot}) is treated as objective function for the economic optimization. Total annual cost of the cooling tower composed of two components namely annualized capital cost (C_{cap}) and operating cost (C_{op}). The annualized capital cost of the cooling tower composed of fixed cost (C_f) and incremental cost. The incremental cost of the cooling tower depends on the fill volume and air mass flow rate. Considering the above mention parameters, annualized capital cost of the cooling tower is obtained through below equation [25, 30],

$$C_{cap} = C_f + [(C_{fv} * A_{fi} * L_{fi}) + (C_{ma} * m_a)] \quad (1)$$

Where, C_f is the fixed cost, C_{fv} is the incremental cost of cooling tower per unit volume, and C_{ma} is the incremental cost per unit mass flow rate of air. A_{fi} the tower fill area, L_{fi} is the fill height of the cooling tower and m_a is the mass flow rate of the air.

Likewise, the operating cost of the cooling tower depends on the pumping power and makeup water cost and obtained through below equation [25, 30],

$$C_{op} = (P * C_e + m_{mw} * C_w) * Y_{hr} \quad (2)$$

Where, C_e and C_w is the cost of the electricity and makeup water cost. Also, P is the pumping power, m_{mw} is the makeup water requirement, and Y_{hr} is the yearly operating hours.

Based on the capital cost and operating cost, the total annual cost is obtained by [30, 12],

$$C_{tot} = a_{cc} * C_{cap} + C_{oc} \quad (3)$$

Where, a_{cc} is the annualised factor. The details mathematical formulation of each of the above terms can be found in Appendix.

Further, the economical optimized geometry of cooling tower should satisfy all the associated design constraints. To ensure that constraints are satisfied during the optimization, adaptive penalty method is used in the present work. In fact, various constraints handling

method experimented in the proposed work to identify its effect on the optimization algorithms. So, the objective function for the cooling tower optimization is presented as,

$$\text{Minimize } f(x) = C_{tot} + \sum_{j=1}^m z_j \bar{g}_j(x) \quad (4)$$

Where, the second term specifies the adaptive penalty function and defined as,

$$z_j = |\bar{C}_{tot}| + \frac{\bar{g}_j(x)}{\sum_{j=1}^m [\bar{g}_j(x)]^2} \quad (5)$$

Where, $\bar{g}_j(x)$ are the associate constraints of the cooling tower.

The above mention objective function for cooling tower subjected to following constraints.

3.1 Temperature constraints

Ideally the minimum outlet water temperature from the cooling tower is the atmospheric air wet bulb temperature ($WBT_{air,in}$). However, the cooling water outlet temperature ($T_{water,out}$) is always more than the wet bulb temperature of atmospheric air. In the present work, this temperature difference is considered as 2.8°C or more than it.

$$T_{water,out} - WBT_{air,in} \geq 2.8 \quad (6)$$

Likewise, the cooling water outlet temperature should be less than the hot process fluid temperature (T_{pf}) of the condenser where the cooling water used. In the present work, this temperature difference should be more than 5°C.

$$T_{pf} - T_{water,out} \geq 5 \quad (7)$$

Also, to ensure proper heat transfer, the water stream should be cooled and temperature of air stream should be increases in the cooling tower.

$$T_{water,in} - T_{water,out} \geq 0 \quad (8)$$

$$T_{air,out} - T_{air,in} \geq 0 \quad (9)$$

Where, T_{water} and T_{air} is the water and air temperature while subscript *in* and *out* stand for inlet and outlet condition respectively.

3.2 Merkel number constraint

Merkel number (Me) represents the driving force required for proper heat transfer between air and water at any section of cooling tower. The Merkel number depends on the water temperature and air enthalpy at any given section. In the proposed work, to ensure the proper driving force for the heat transfer, the Merkel number should be 5 or more than it.

$$Me = \int_{T_{water,out}}^{T_{water,in}} \frac{c_{pw} dT_{water}}{h_{sa} - h_a} \geq 5 \quad (10)$$

Where, h_a is the enthalpy of air and h_{sa} is the enthalpy of saturated air. c_{pw} denotes the specific heat of water.

3.3 Tower fill area constraint

Tower fill area (A_{fi}) represent the area packed by the fill material to enhance the heat transfer between air and water. However, the pressure drop of air and water increases with the fill area which further increases the operating cost. In the present work, the tower fill area should be 10 m² or less than it.

$$A_{fi} \leq 10 \quad (11)$$

3.4 Pressure drop constraint

The major pressure drop in the cooling tower is due to fill material (ΔP_{fi}). The other miscellaneous pressure drop (ΔP_{misc}) includes loss due to air entry and exit, drift eliminators, water distributing arrangement etc. In the proposed work, the total pressure drop (ΔP_t) of the cooling tower should not more than 230 Pa.

$$\Delta P_t = (\Delta P_{fi} + \Delta P_{misc}) \leq 230 \quad (12)$$

4. Case study and results-discussion

A case study of mechanical draft counter flow cooling tower is attempted in the proposed work to assess the performance comparison of recently developed metaheuristic such as EO, SFO, SSA, SHO, HHO, MPA, PFA, MBF, HGSO with state-of-the-art differential evolution and its variants. All the algorithms executed with common platform on the considered case study. Further, to get a more insight on performance comparison, the recently developed algorithm assess with and without presence of stat-of-art differential evolution and its variants.

4.1 Case study

A mechanical draft cooling tower need to design based on economic optimization. Fig. 1 represents the schematic of one such cooling tower [25]. The proposed cooling tower should fulfil the heat duty of 3.4 MW. The hot cooling water from the condenser enters into the cooling tower at 50⁰C. The desired outlet temperature of the water from cooling tower is 25⁰C. The atmospheric air enters into cooling tower at 22⁰C. The wet bulb temperature of the air is 12⁰C. Inlet temperature of the hot process fluid in condenser is 65⁰C which should be cooled to 30⁰C by using cooling water from the cooling tower.

The economic optimization of cooling tower depends on the different geometric and operating parameters. Three such variables which combine the effect of geometric and operating parameters such as tower fill area, mass of water, and mass of air are considered in the present work. The lower and upper bound of these variables along with the other economic parameters required to evaluate the total cost of the cooling tower are shown in Table 1. Further, the optimized geometry of cooling tower should satisfy the temperature, pressure drop, fill area, and Merkel number constrains mentioned previously.

4.2 Results and discussion

All the algorithms considered in this work are executed with population size of 50 and 100000 maximum function evaluation. The control parameters of each algorithm are mention in Table 2. Further, each algorithm executed 100 times on the consider case study of cooling tower to analyse its comparative performance. Moreover, 0.01% variation from the minimum cost value is considered for obtaining the success rate of each competitive algorithm.

The quantitative performance comparison of each considered algorithm for cooling tower optimization is shown in Table 3. The results are displayed in the form of best value, worst value, and mean value along with the success rate, and standard deviation obtained from the 100 run of each competitive algorithm. In this comparative result, best value is the minimum value obtained by the particular algorithm. Mean value is the average value of objective function over 100 independent run of the particular algorithm and used to judge its average performance.

The comparative result indicates that SHO, SSA, HHO, EO, DE and both its variants (i.e. SaDE, L-SHADE) produces the identical solution in terms of minimum cost and leads towards the economically optimized design of cooling tower. However, the average performance of DE, SaDE, and L-SHADE are better than other comparative algorithm. The SSA and EO algorithm follows the DE and its variants in terms of average performance. Likewise, with 97 and 98% success rate, the DE and its variants perform superior than other approaches in terms of success rate comparison. The SSA, EO, HHO, and SHO algorithm also produces success rate more than 90%. In terms of standard deviation, again DE and its variants performed better with less spread out of the solutions followed by the EO and SSA. Thus, the quantitative performance of DE and its variants dominant the other recently developed algorithms in almost all the comparison criteria.

The qualitative performance of the considered algorithms is evaluated by implementing the statistical analysis of the comparative results. The statistical analysis is performed with two different scenarios. In first scenario, the results of recently developed algorithms are considered only. In second scenario the results of DE, SaDE, and L-SHADE are considered along with the recently developed algorithms. Further, the ranking of the competitive algorithms are also given based on its statistical performance. The statistical performance of the competitive algorithms is evaluated by executing the Friedman test [31] on the obtained results.

Table 4 presents the result of Friedman rank test for first scenario. For better insight and interpretation, the normalized value of Friedman test is also presented in Table 4. The normalized value of Friedman test is used to obtain the rank of the algorithms. The normalized value '1' shows the best performing algorithm. The algorithms having normalized value away from '1' indicates that its performance is degraded as compared to best algorithm. Further, the graphical presentation of Friedman rank test is also shown in Fig. 2. One can observe from the results that SSA obtained 1st rank followed by the EO and HHO algorithm. Likewise, Table 5 presents the result of Friedman rank test for second scenario while its graphical presentation is shown in Fig. 3. It can observe from the results that L-SHADE obtained 1st rank followed by the SaDE and DE algorithm. Further, there were significant difference in normalized value of considered recently developed algorithm and DE & its variants. Thus, DE, SaDE, and L-SHADE outperform the considered recently developed algorithms for cooling tower optimization problem.

The present work of cooling tower optimization deals with various operating and geometric constraints. These constraints are taken care by constraint handling method. So, different constraints handling methods are experimented to identify its effect on the performance of the each competitive algorithm. Five different constraint handling methods

[32] namely static penalty, adaptive penalty, ϵ -constraint, stochastic ranking, and superiority of feasible solutions method are experimented with the each of the competitive algorithm. Here also, the stopping criteria of the algorithm is set as 100000 function evaluation and 100 runs of all algorithm executed with each constrained handling method. The results obtained by each algorithm with different constraint handling methods are presented in Table 6. The results are presented in terms of best and mean value along with the standard deviation obtained in 100 runs. The result shows that DE, SaDE, and L-SHADE perform better than the other algorithms with each of the constraint handling methods considered in this work. Further, the performance of adaptive penalty, stochastic ranking, and ϵ -Constraint method is almost similar with all the competitive algorithms for the cooling tower optimization.

The optimized design variables of cooling tower along with the total cost and the constraints value obtained using the L-SHADE is presented in Table 7. Results show that all the constraints are satisfied in the optimized design. Further, Fig. 4 shows the convergence performance of each competitive algorithm in obtaining minimum total cost design. The detail convergence behaviour of each competitive algorithm at the interval of specific number of function evaluations are shown in Fig. 5. It can be observed from Fig. 4 and 5 that the DE, SaDE, and L_SHADE converge within about 10000-15000 function evaluation. Other competitive algorithms converge within about 25000-50000 maximum function evaluations to their respective objective function value. Thus, convergence performance of the DE and its variants is better than rest of the approaches.

Finally, the behaviour of all competitive algorithms is verified for sensitiveness of constraints. Tower fill area and Merkel number constraints are considered for this investigation as both constraints are sensitive for economic cooling tower design. Five different value of tower fill area (9.6 m^2 , 9.8 m^2 , 10 m^2 , 10.2 m^2 , and 10.4 m^2) and Merkel number (4.5, 4.75, 5, 5.25, and 5.5) are considered during the experimentation. The

considered algorithms experimented 100 times for each constraint and average result obtained through the 100 independent runs presented to evaluate comparative performance. Table 8 and Table 9 show the performance of considered algorithms for various fill area and Merkel number constraints respectively. It can be observed from the results that DE, SaDE, and L-SHADE respond better than other competitive algorithms for constraints variation. Accordingly, the performance of DE, SaDE, and L-SHADE dominates the other approaches and produces the economically optimized cooling tower design in different scenario.

5. Conclusion

Solving applied problem of economic optimization is considered as a real test for the optimization algorithms. The present work demonstrates the performance comparison of nine recently developed algorithms such as EO, SFO, SSA, SHO, HHO, MPA, PFA, MBF, and HGSO with state-of-the-art DE, SaDE, and L-SHADE for the economic optimization of cooling tower. Quantitative results show that DE, SaDE, and L-SHADE are better than recently developed algorithms considered in the present work followed by SSA and EO algorithms. The qualitative performance comparison of the obtained results also shows the dominance of DE and its variants. The L-SHADE achieves the 1st rank followed by SaDE and DE. Further, the various constraint handling methods investigated with the considered algorithms and results show that adaptive penalty, stochastic ranking and ε -constraint methods work equally well for the economic optimization. Convergence behaviour of DE, SaDE and L-SHADE algorithms are better than the other competitive algorithms in obtaining the optimum solution. Finally, DE and its variants respond better than other competitive algorithms for sensitiveness of constraints and dominate the other approaches of the present work.

References

- [1] M. Jain, V. Singh, A. Rani, A novel nature-inspired algorithm for optimization: Squirrel search algorithm, *Swarm and evolutionary computation* 44 (2019) 148-175.
- [2] A.A. Heidari, S. Mirjalili, H. Faris, I. Aljarah, M. Mafarja, H. Chen, Harris hawks optimization: Algorithm and applications, *Future Generation Computer Systems* 97 (2019) 849-872.
- [3] A. Faramarzi, M. Heidarinejad, S. Mirjalili, A.H. Gandomi, Marine Predators Algorithm: A Nature-inspired Metaheuristic, *Expert Systems with Applications* 152 (2020) 113377
- [4] S. Mirjalili, S.M. Mirjalili, A. Lewis, Grey wolf optimizer. *Advances in Engineering Software* 69 (2014) 46-61.
- [5] A. Faramarzi, M. Heidarinejad, B. Stephens, S. Mirjalili, Equilibrium optimizer: A novel optimization algorithm, *Knowledge-Based Systems* 191 (2020) 105190.
- [6] S. Shadravan, H.R. Naji, V.K. Bardsiri, The Sailfish Optimizer: A novel nature-inspired metaheuristic algorithm for solving constrained engineering optimization problems, *Engineering Applications of Artificial Intelligence* 80 (2019) 20-34.
- [7] G. Dhiman, V. Kumar, Spotted hyena optimizer: a novel bio-inspired based metaheuristic technique for engineering applications, *Advances in Engineering Software* 114 (2017) 48-70.
- [8] F.A. Hashim, E.H. Houssein, M.S. Mabrouk, W. Al-Atabany, S. Mirjalili, Henry gas solubility optimization: A novel physics-based algorithm, *Future Generation Computer Systems* 101 (2019) 646-667.
- [9] H. Yapici, N. Cetinkaya, A new meta-heuristic optimizer: Pathfinder algorithm, *Applied Soft Computing* 78 (2019) 545-568.
- [10] S. Mirjalili, A.H. Gandomi, S.Z. Mirjalili, S. Saremi, H. Faris, S.M. Mirjalili, Salp Swarm Algorithm: A bio-inspired optimizer for engineering design problems. *Advances in Engineering Software* 114 (2017) 163-191

- [11] X.S. Yang, S. Deb, Engineering optimization by cuckoo search, *International Journal of Mathematical Modelling and Numerical Optimisation*, 1 (2010) 330-343.
- [12] V.K. Patel, V.J. Savsani, Heat Transfer Search (HTS): a novel optimization algorithm, *Information Sciences* 324 (2015) 217-246
- [13] Y.J. Zheng, Water wave optimization: a new nature-inspired metaheuristic, *Computers & Operations Research* 55 (2015) 1-11
- [14] V. Punnnathanam, P. Kotecha, Yin-yang-pair optimization: A novel lightweight optimization algorithm, *Engineering Applications of Artificial Intelligence* 54 (2016) 62-79
- [15] S. Mirjalili, The ant lion optimizer, *Advances in Engineering Software* 83 (2015) 80-98
- [16] L. Cheng, X.H. Wu, Y. Wang, Artificial flora (af) optimization algorithm, *Applied Sciences* 8 (2018) 329
- [17] S. Mirjalili, SCA: a sine cosine algorithm for solving optimization problems, *Knowlegde-Based Systems* 96 (2016) 120-133
- [18] S. Mirjalili, Dragonfly algorithm: a new meta-heuristic optimization technique for solving single-objective, discrete, and multi-objective problems, *Neural Computing & Applications* 27 (2016) 1053-1073
- [19] A. Tabari, A. Ahmad, A new optimization method: Electro-Search algorithm, *Computers & Chemical Engineering* 103 (2017) 1-11
- [20] E. Jahani, M. Chizari, Tackling global optimization problems with a novel algorithm–Mouth Brooding Fish algorithm, *Applied Soft Computing* 62 (2018) 987-1002.
- [21] https://www.ntu.edu.sg/home/epnsugan/index_files/cec-benchmarking.htm
- [22] R. Storn, K. Price, Differential evolution – a simple and efficient heuristic for global optimization over continuous spaces, *Journal of Global Optimization* 11 (1997) 341–359.
- [23] A.K. Qin, P.N. Suganthan, Self-adaptive differential evolution algorithm for numerical optimization, In *IEEE congress on evolutionary computation*, 2005, pp. 1785-1791.

- [24] R. Tanabe, A.S. Fukunaga, Improving the search performance of SHADE using linear population size reduction, In IEEE congress on evolutionary computation (CEC), 2014, pp. 1658-1665.
- [25] V.K. Patel, V.J. Savsani, M.A. Tawhid, Thermal System Optimization: A Population-Based Metaheuristic Approach, Springer, Switzerland, 2019.
- [26] K. Singh, R. Das, An experimental and multi-objective optimization study of a forced draft cooling tower with different fills, Energy Conversion and Management 111 (2016) 417-30.
- [27] K. Singh, R. Das, Multi Parameter Estimation in an Induced Draft Cooling Tower Using Genetic Algorithm, In Proceedings of the ASME 2016 International Mechanical Engineering Congress and Exposition, Phoenix, Arizona, USA, 2016, pp. 1–17.
- [28] R.V. Rao, V.K. Patel, Optimization of mechanical draft counter flow wet-cooling tower using artificial bee colony algorithm, Energy Conversion and Management 52 (2011) 2611-2622.
- [29] H. Ozcan, K. Ozdemir, H. Ciloglu, Optimum cost of an air cooling system by using differential evolution and particle swarm algorithms, Energy and buildings 65 (2013) 93-100.
- [30] M. Kintner-Meyer, A.F. Emery, Cost-optimal design for cooling towers. ASHRAE Journal 37 (1995) 46–55
- [31] D. Joaquín, G. Salvador, M. Daniel, H. Francisco, A practical tutorial on the use of non parametric statistical tests as a methodology for comparing evolutionary and swarm intelligence algorithms, Swarm and evolutionary computation 1 (2011) 3-18
- [32] R. Mallipeddi, P.N. Suganthan, Ensemble of Constraint Handling Techniques. IEEE Transactions on Evolutionary Computation, 14 (2010) 561-579.

Table 1: Lower and upper limit of design variables and economic parameters

Geometric parameters	Lower limit	Upper limit
Water to air mass ratio, $\frac{m_w}{m_a}$	1	10
Mass velocity of water, $\frac{m_w}{A_{fi}}$	1	10
Mass velocity of air, $\frac{m_a}{A_{fi}}$	1	4.25
Capital cost factor, a_{cc}	0.2983/year	
Operating time, Y_{hr}	8150 hr/year	
Electricity cost, C_e	0.085 \$/kWh	
Make-up water cost, C_w	52.83×10^6 \$/kg	
Fixed cost, C_f	31185 \$	
Incremental cost per unit mass flow, C_{ma}	1097.5 \$/kg.s ⁻¹	

Table 2: Control parameters of the competitive algorithms

SHO algorithm

$$\vec{h} = [5, 0], \vec{M} = [0.5, 1]$$

MBF algorithm

$$SP = 0.5, D_{is} = 1.5, P_{dis} = 0.5, SP_{damp} = 0.85$$

SSA algorithm

$$N_{fs} = 4, G_c = 1.9, P_{dp} = 0.1$$

SFO algorithm

$$A = 4, \varepsilon = 0.001$$

PFA algorithm

$$\alpha = 1.2, \beta = 1.4$$

HHO algorithm,

$$E_0 = [-1, 1], \beta = 1.5$$

HGSO algorithm,

$$M_1 = 0.1, M_2 = 0.2, \alpha = 1, \beta = 1, K = 1$$

MPA algorithm,

$$P = 0.5, FADs = 0.2$$

EO algorithm

$$GP = 0.5, \lambda = [0, 1], a_1 = 2, a_2 = 1$$

DE algorithm

$$CR = 0.5, F = 0.5$$

SaDE algorithm

$$CR \ \& \ F = \text{Self adapted}$$

L-SHADE algorithm

$$p = 0.11, H = 6, r^{arc} = 2.6$$

Table 3: Performance comparison of various algorithms

Algorithms	Best value	Worst value	Mean value	Standard deviation	Success rate
SHO	61857.78	61926.22	61867.92	1.55E+01	90
MBF	61863.15	61972.26	61876.6	2.67E+01	81
SSA	61857.78	61926.22	61862.76	1.46E+01	94
SFO	61858.04	61926.22	61869.69	1.93E+01	89
PFA	61861.23	61941.56	61874.04	2.02E+01	82
HHO	61857.78	61926.22	61866.71	1.56E+01	91
HGSO	61863.9	61972.26	61878.37	2.90E+01	79
MPA	61858.23	61926.22	61871.35	1.54E+01	85
EO	61857.78	61926.22	61864.56	1.47E+01	92
DE	61857.78	61864.2	61859.45	1.83E+00	97
SaDE	61857.78	61864.2	61859.16	1.36E+00	97
L-SHADE	61857.78	61864.2	61858.97	1.16E+00	98

Table 4: Statistical result of the comparative algorithms excluding DE and its variants

Algorithms	Freidman Value	Normalized Value	Rank of the algorithm
SHO	19	0.52632	4
MBF	40.5	0.24691	8
SSA	10	1	1
SFO	23	0.43478	6
PFA	35	0.28571	7
HHO	18	0.55556	3
HGSO	44.5	0.22472	9
MPA	22	0.45455	5
EO	13	0.76923	2

Table 5: Statistical result of the comparative algorithms including DE, SaDE, and L-SHADE

Algorithms	Freidman Value	Normalized Value	Rank of the algorithm
SHO	31.5	0.66666	7
MBF	46.5	0.45161	11
SSA	28.5	0.73684	4
SFO	33.5	0.62686	9
PFA	43	0.48837	10
HHO	32.5	0.64615	8
HGSO	48.5	0.43299	12
MPA	30.5	0.68852	6
EO	29.5	0.71186	5
DE	23.5	0.89361	3
SaDE	21.5	0.97674	2
L-SHADE	21	1	1

Table 6: Comparative results with various constraint handling methods

Algorithms		Static Penalty	Superiority of Feasible Solutions	Stochastic Ranking	ϵ -Constraint	Adaptive Penalty
SHO	Best	61859.14	61858.83	61857.78	61858.83	61857.78
	Mean	61871.23	61869.63	61867.31	61868.73	61867.92
	SD	1.81E+01	1.71E+01	1.54E+01	1.61E+01	1.55E+01
MBF	Best	61864.22	61863.9	61863.36	61863.36	61863.15
	Mean	61879.83	61878.51	61877.32	61877.82	61876.6
	SD	2.80E+01	2.75E+01	2.67E+01	2.69E+01	2.67E+01
SSA	Best	61857.78	61857.78	61857.78	61857.78	61857.78
	Mean	61863.93	61863.27	61862.51	61863.13	61862.76
	SD	1.52E+01	1.48E+01	1.39E+01	1.32E+01	1.46E+01
SFO	Best	61859.14	61858.83	61858.34	61858.34	61858.04
	Mean	61874.72	61873.36	61870.85	61871.32	61869.69
	SD	2.20E+01	2.11E+01	1.99E+01	2.03E+01	1.93E+01
PFA	Best	61863.15	61862.44	61861.79	61861.79	61861.23
	Mean	61878.24	61876.66	61875.11	61875.82	61874.04
	SD	2.33E+01	2.23E+01	2.08E+01	2.13E+01	2.02E+01
HHO	Best	61858.23	61858.23	61857.78	61857.78	61857.78
	Mean	61868.75	61867.86	61866.93	61867.63	61866.71
	SD	1.72E+01	1.68E+01	1.51E+01	1.54E+01	1.56E+01
HGSO	Best	61864.22	61864.22	61863.9	61863.9	61863.9
	Mean	61882.04	61880.53	61879.21	61879.46	61878.37
	SD	3.10E+01	3.00E+01	2.93E+01	2.95E+01	2.90E+01
MPA	Best	61861.23	61860.72	61858.92	61858.92	61858.23
	Mean	61875.07	61873.12	61872.08	61872.77	61871.35
	SD	1.91E+01	1.79E+01	1.60E+01	1.61E+01	1.54E+01

EO	Best	61857.78	61857.78	61857.78	61857.78	61857.78
	Mean	61865.83	61865.12	61864.91	61864.19	61864.56
	SD	1.62E+01	1.56E+01	1.51E+01	1.41E+01	1.47E+01
DE	Best	61858.23	61857.78	61857.78	61857.78	61857.78
	Mean	61861.83	61860.32	61859.88	61860.26	61859.45
	SD	4.32E+00	3.07E+00	2.17E+00	2.96E+00	1.83E+00
SaDE	Best	61858.23	61857.78	61857.78	61857.78	61857.78
	Mean	61860.63	61859.97	61859.62	61859.94	61859.16
	SD	2.91E+00	1.96E+00	1.65E+00	1.87E+00	1.36E+00
L-SHADE	Best	61858.23	61857.78	61857.78	61857.78	61857.78
	Mean	61860.14	61859.48	61859.04	61859.18	61858.97
	SD	2.54E+00	1.77E+00	1.21E+00	1.43E+00	1.16E+00

Table 7: Economically optimized geometry of cooling tower

Design Parameters	Optimized value
Mass flow rate of water, (kg/s)	32.49
Mass flow rate of air, (kg/s)	17.45
Water-to-air mass ratio	1.861
Mass velocity of water, (kg/m ² s)	3.249
Mass velocity of air, (kg/m ² s)	1.746
Fill length of tower, (m)	3.93
Tower fill area, (m ²)	10
Merkel number	5
Total Pressure drop, (Pa)	229.75
Total annual cost, (\$/year)	61857.78

Table 8: Behaviour of competitive algorithms in respond to fill area constraints

Algorithms	Total annual cost, (\$/year)				
	$A_{fi} = 9.6$	$A_{fi} = 9.8$	$A_{fi} = 10$	$A_{fi} = 10.2$	$A_{fi} = 10.4$
SHO	61948.21	61903.54	61867.92	61847.17	61835.83
MBF	61952.43	61910.89	61876.6	61852.21	61840.74
SSA	61945.24	61896.68	61862.76	61842.59	61833.28
SFO	61947.12	61901.22	61869.69	61849.11	61837.79
PFA	61951.22	61910.47	61874.04	61851.89	61840.06
HHO	61946.76	61898.65	61866.71	61845.66	61834.93
HGSO	61955.88	61911.12	61878.37	61853.42	61842.41
MPA	61949.11	61906.59	61871.35	61850.44	61838.32
EO	61946.63	61897.68	61864.56	61843.45	61834.39
DE	61939.47	61892.12	61858.45	61838.92	61826.83
SaDE	61938.12	61891.88	61858.16	61837.19	61825.31
L-SHADE	61937.23	61891.18	61857.97	61836.43	61824.12

Table 9: Behaviour of competitive algorithms in respond to Merkel number constraints

Algorithms	Total annual cost, (\$/year)				
	$Me = 4.5$	$Me = 4.75$	$Me = 5$	$Me = 5.25$	$Me = 5.5$
SHO	59190.22	60543.11	61867.92	63374.12	64839.92
MBF	59194.68	60547.79	61876.6	63381.34	64845.22
SSA	59188.93	60539.24	61862.76	63369.28	64835.37
SFO	59192.08	60544.53	61869.69	63377.48	64842.13
PFA	59193.36	60546.91	61874.04	63379.84	64844.77
HHO	59188.29	60541.07	61866.71	63372.88	64838.15
HGSO	59195.18	60549.85	61878.37	63382.09	64848.32
MPA	59192.87	60545.61	61871.35	63378.76	64843.91
EO	59187.79	60539.74	61864.56	63369.57	64836.14
DE	59183.84	60531.32	61858.45	63362.13	64827.96
SaDE	59181.95	60529.87	61858.16	63360.89	64826.34
L-SHADE	59180.63	60528.94	61857.97	63359.63	64824.27

Fig 1: Geometry of mechanical draft counter flow cooling tower

Fig. 2: Statistical result without considering DE, SaDE, and L-SHADE

Fig. 3: Statistical result with DE, SaDE, and L-SHADE

Fig. 4: Overall convergence comparison of comparative algorithms

Fig. 5: Convergence behaviour of each competitive algorithm at the interval of (a) 5000 (b) 10000 (c) 15000 and (d) 20000 function evaluations

Appendix:

Modelling equations for Mechanical draft cooling tower

Equations	Remarks
$Q = m_w c_{pw} (T_{water,in} - T_{water,out}) = m_a (h_{a,out} - h_{a,in})$	Heat transfer from water to air stream
$Me = \int_{T_{water,out}}^{T_{water,in}} \frac{c_{pw} dT_{water}}{h_{sa} - h_a} = 0.25 c_{pw} (T_{water,in} - T_{water,out}) \sum_{i=1}^{i=4} \frac{1}{\Delta h_i}$	Required Merkel number
$\Delta h_i = h_{sa,i} - h_{a,i}, \quad \text{where, } i = 1, 2 \dots 4$	Local enthalpy difference of air
$\Delta h_{a,i} = \Delta h_{a,i} + \frac{m_w c_{pw}}{m_a} (T_{water,in} - T_{water,out}), \quad i = 1, 2 \dots 4$	Air enthalpy as per Chebyshev point
$T_{water,i} = T_{water,out} + TCH_i (T_{water,in} - T_{water,out}), \quad i = 1, 2 \dots 4$	Water temperature as per Chebyshev point
$h_{sa,i} = -6.388 + 0.865 T_{water,i} + 15.715 \exp(0.05439 T_{water,i}), \quad i = 1, 2 \dots 4$	Enthalpy of the saturated air
$Me = \frac{h_d a_{fi} A_{fi} L_{fi}}{m_w}$	Available Merkel number
$\Delta P_{fi} = K_{fi} L_{fi} \frac{m a v_m^2}{2 \rho_m A_{fi}^2}$	Fill matrix pressure drop
$K_{fi} = \left[d_1 \left(\frac{m_w}{A_{fi}} \right)^{d_2} \left(\frac{m_a}{A_{fi}} \right)^{d_3} + d_4 \left(\frac{m_w}{A_{fi}} \right)^{d_5} \left(\frac{m_a}{A_{fi}} \right)^{d_6} \right] L_{fi}$	Loss coefficient correlations
$m a v_m = \frac{m a v_{in} + m a v_{out}}{2}$	Mean flow rate of air-vapor

$$\begin{cases} mav_{in} = m_a + w_{in}m_a \\ mav_{out} = m_a + w_{out}m_a \end{cases}$$

Air-vapor flow rate at fill inlet & outlet

$$\begin{cases} w_{in} = \left(\frac{2501.6 - 2.3263 WBT_{air,in}}{2506 + 1.8577 T_{air,in} - 4.184 WBT_{air,in}} \right) \left(\frac{0.62509 PV_{wbt,in}}{P_{tot} - 1.005 PV_{wbt,in}} \right) \\ \quad - \left(\frac{1.00416 (T_{air,in} - WBT_{air,in})}{2506 + 1.8577 T_{air,in} - 4.184 WBT_{air,in}} \right) \\ w_{out} = \frac{0.62509 PV_{out}}{P_{tot} - 1.005 PV_{out}} \end{cases}$$

Air humidity at inlet & outlet

$$\Delta P_{misc} = K_{mcl} \frac{\rho_{mcl} v_{mcl}^2}{2}$$

Miscellaneous pressure losses

$$P = \frac{mav_{in} \Delta P_t}{\rho_{in} \eta_f}$$

Pumping power

Nomenclature used in Modelling

a_{fi}	area to volume ratio (m^2/m^3)
A_{fi}	cooling tower fill area (m^2)
c_{pw}	specific heat of water (J/kg K)
d_1-d_6	coefficients to estimation K_{fi}
h_a	atmospheric air enthalpy (J/kg)
h_{sa}	saturated air enthalpy (J/kg)
h_d	coefficient of mass transfer ($\text{kg/m}^2 \text{ s}$)
K_{fi}	loss coefficient
L_{fi}	fill height (m)
m_a	air mass flow (kg/s)
m_w	water mass flow rate (kg/s)
mav	air-vapor flow rate (kg/s)
Me	Merkel number
P	pumping power required (W)
PV	vapor pressure (Pa)
Q	cooling duty (W)
T	temperature ($^{\circ}\text{C}$)
TCH	Chebyshev constant
WBT	atmospheric air wet-bulb temperature ($^{\circ}\text{C}$)
w	specific humidity (kg /kg of air)

Greek symbols

Δh	enthalpy difference (J/kg)
ΔP_t	total pressure drop of the system (Pa)
η_f	efficiency of fan

ρ density (kg/m³)

Subscripts

a air

fi fill

in inlet

m mean

mcl miscellaneous

out outlet

t total

w water