

COP Estimations for High-Temperature Heat Pumps using natural refrigerants

Jensen, Jonas Kjær; Padullés I Solé, Roger; Andersen, Martin Pihl

Publication date: 2024

Document Version Publisher's PDF, also known as Version of record

Link back to DTU Orbit

Citation (APA):

Jensen, J. K., Padullés I Solé, R., & Andersen, M. P. (2024). *COP Estimations for High-Temperature Heat Pumps using natural refrigerants*. Poster session presented at High-Temperature Heat Pump Symposium 2024 to Feature Sessions on Natural Refrigerants, Copenhagen, Denmark.

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

• Users may download and print one copy of any publication from the public portal for the purpose of private study or research.

- · You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

COP Estimations for High-Temperature Heat Pumps using natural refrigerants

Jonas Kjær Jensen*, Roger Padullés, Martin Pihl Andersen

A recent study from Andersen et al. [1] established a portfolio of heat pumps that use natural working fluids, capable of operating efficiently over a broad range of high-temperature conditions. The study conducted simulations on a total of **1056 heat pump models under 1124 different temperature conditions,** with up to 150 K of temperature lift. As for the working fluids and heat pump configurations considered in the study, they spanned several hydrocarbons, ammonia, water, carbon dioxide, and many hydrofluoroolefins (HFOs). The configurations included diverse setups such as one-stage, two-stage, and cascade systems, capable of operating both subcritically and transcritically.

A more accurate COP model enhances the efficiency, economic viability, and environmental sustainability of heat pump systems by enabling better system design, performance prediction, and cost-effectiveness analysis. In this work, we utilize the top performing heat pump configurations for each of the temperature conditions simulated by Andersen et al. to fit to various COP estimation methods.



Fixed Lorenz efficiency

$$OP = \eta_{Lor} \cdot \frac{\overline{T}_{sink}}{\overline{T}_{sink} - \overline{T}_{source}}$$

 $\eta_{Lor} = 0.549$

 $R^2 = 0.87$

Widely used as a performance indicator of heat pump and refrigeration cycles, the second law efficiency allows a first approximation for heat pump performance.

$$COP = a \cdot (\bar{T}_{sink} - \bar{T}_{source} + 2 \cdot b)^{c} \cdot (T_{sink out} + b)^{d}$$

b=0d = 0.287

 $R^2 = 0.93$

Originally presented and fitted to 33 market-available HFC and HFO heat pumps that reach up to 100 °C with 80 K of temperature lift. The proposed parameter fit would include the natural refrigerant and a wider range of operating conditions.

Polynomial regression of Lorenz efficiency

 η_{Lo}

 $\begin{aligned} \eta_{Lor} &= a \cdot T_{source,in} + b \cdot \left(T_{sink,out} - T_{source,in}\right) + \\ c \cdot \left(T_{source,out} - T_{source,in}\right) + d \cdot \left(T_{sink,out} - T_{source,in}\right) + e \end{aligned}$

a=0.480802 b = -0.00011c = -0.00847d=0.00129 e=0.00043

 $R^2 = 0.98$

A polynomial fit of the temperatures defining the inputs to the model allow for a closer approximation to the simulated results by including the temperature glide on both sink and source of the heat pump.

8 7 Approximated COP results 0 2 Simulated COP results



High-Temperature **Heat Pump Symposium**

Performance models proposed by Jensen et al. [3]

$-\frac{\left(1+\frac{A+\Delta I_{pp}}{\bar{T}_{sink}}\right)\cdot\eta_{is,c}\cdot(1-B)}{-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1$	$\overline{T}_{sink} - \overline{T}_{source}$	
$-\frac{(T_{source,in} - T_{source,out})}{(T_{source,out})} + 2$	$\overline{T_{sink}}$	R ² =0.99
1 2 2	¹ pp	
$\bar{T}_{sink} - \bar{T}_{source}$		

$$A = a \cdot (T_{sink,out} - T_{source,out} + 2 \cdot \Delta T_{pp}) + b \cdot (T_{sink,out} - T_{sink,in}) + c$$

$$B = d \cdot (T_{sink,out} - T_{source,out} + 2 \cdot \Delta T_{pp}) + e \cdot (T_{sink,out} - T_{sink,in}) + f$$

$$a = -0.402193$$

$$b = 0.966630$$

$$c = -1.824054$$

$$d = -0.0001581$$

$$e = -0.0001581$$

Originally presented to estimate the performance of ammonia and isobutane HTHPs, the proposed formulation by Jensen et al. includes additional parameters such as the isentropic efficiency of the compressor $(\eta_{is,c})$, the driving temperature difference with the refrigerant (ΔT_{pp}) and the heat loss factor of the compressor (f_0) .

The intricacy of this model is justified by its accuracy, establishing it as the most precise COP estimation method.

[1] Andersen et al. "Selection of working fluids and heat pump cycles at high temperatures: Creating a concise technology portfolio" [2] Jesper et al. "Large-scale heat pumps: Uptake and performance modelling of market-available devices" [3] Jensen et al. "Heat pump COP, part 2: Generalized COP estimation of heat pump processes"