



The Total Lifetime Cost of a Magnetic Refrigerator

Bjørk, Rasmus; Bahl, Christian; Nielsen, Kaspar Kirstein

Publication date:
2015

Document Version
Peer reviewed version

[Link back to DTU Orbit](#)

Citation (APA):

Bjørk, R., Bahl, C., & Nielsen, K. K. (2015). *The Total Lifetime Cost of a Magnetic Refrigerator*. Poster session presented at Delft Days on Magnetocalorics 2015, Delft, Netherlands.

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.


The Total Lifetime Cost of a Magnetic Refrigerator

R. Bjørk, C. H. R. Bahl, K. K. Nielsen

¹*Department of Energy Conversion and Storage,
Technical University of Denmark - DTU, Denmark
rabj@dtu.dk*

In this work we consider the total cost of a 25 W average load magnetic refrigerator using commercial grade Gd and a temperature span of 30 K. The price of magnetocaloric material, magnet material and cost of operation are considered. All these effects influence the total cost. Two devices are considered, one which operates at 24.8 W continuously and one which operates at 50 W for 10% of the time and 22W at 90% of the time.

Using a numerical model we calculate the lowest combined total cost of a device with a lifetime of 15 years and find this to be in the range \$150-\$400, depending on the price of the magnetocaloric and magnet material and with the cost being lowest for the 24.8 W continuously operating device. The optimal device parameters are also determined: the optimal magnetic field is about 1.4 T, the particle size is 0.23 mm, the length of the regenerator is 40-50 mm and the utilization is about 0.2, for all device lifetimes and material and magnet prices, while the operating frequency vary as function of device lifetime. The considered performance characteristics are based on the performance of a conventional A⁺⁺⁺ refrigeration unit. In a rough life time cost comparison under the above given assumptions between the AMR device and such a conventional unit we find similar costs, the AMR being slightly cheaper, assuming the cost of the magnet can be recuperated at end of life.



Key Words: Magnetic refrigerator; Cost; Price; Compressor

References R. Bjørk et. al. Submitted to Int. J. Refrig, 2015.