



Comparing superconducting and permanent magnets for magnetic refrigeration

Bjørk, Rasmus; Nielsen, Kaspar Kirstein; Bahl, Christian R.H.; Smith, Anders; Wulff, Anders Christian

Published in:
Book of Abstracts. DTU's Sustain Conference 2015

Publication date:
2015

Document Version
Publisher's PDF, also known as Version of record

[Link back to DTU Orbit](#)

Citation (APA):
Bjørk, R., Nielsen, K. K., Bahl, C. R. H., Smith, A., & Wulff, A. C. (2015). Comparing superconducting and permanent magnets for magnetic refrigeration. In *Book of Abstracts. DTU's Sustain Conference 2015* [E-7] Technical University of Denmark.

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Comparing superconducting and permanent magnets for magnetic refrigeration

R. Bjørk, K. K. Nielsen, C. R. H. Bahl, A. Smith, and A. C. Wulff*

DTU Energy

*Corresponding author email: anwu@dtu.dk

We consider the initial cost of a high temperature superconducting (SC) tape-based solenoid versus a permanent magnet (PM) Halbach cylinder for magnetic refrigeration. Assuming a five liter active magnetic regenerator volume the price of each type of magnet is determined as a function of aspect ratio of the regenerator and desired internal magnetic field. It is shown that in order to produce a 1 T internal field in the regenerator a permanent magnet of several tons is needed or an area of superconducting tape of tens of square meters (see Figure 1). Assuming a cost of the SC tape of 6000 \$/m² and a price of the PM of 100 \$/kg, the superconducting solenoid is shown to be a factor of 1-3 times more expensive than the permanent magnet. However, this factor decreases for increasing field strength (see Figure 2), indicating that the superconducting solenoid could be suitable for high field, large cooling power applications.




Figure 1: The area of the superconducting tape needed to produce a desired internal magnetic field for a given aspect ratio of the regenerator cylinder.




Figure 2: The factor between the price of the superconductor tape per m² and the price of the permanent magnet per kg.