



Fouling of forward osmosis membranes on municipal waste streams

Zarebska, Agata; Hey, Tobias; Jansen, Jes la Cour; Petrinic, Irena; Korenak, Jasmina; Buksek, Hermina; Hélix-Nielsen, Claus

Published in:
Book of Abstracts. DTU's Sustain Conference 2015

Publication date:
2015

Document Version
Publisher's PDF, also known as Version of record

[Link back to DTU Orbit](#)

Citation (APA):
Zarebska, A., Hey, T., Jansen, J. L. C., Petrinic, I., Korenak, J., Buksek, H., & Hélix-Nielsen, C. (2015). Fouling of forward osmosis membranes on municipal waste streams. In *Book of Abstracts. DTU's Sustain Conference 2015* Article W-6 Technical University of Denmark.

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Fouling of forward osmosis membranes on municipal waste streams

Agata Zarebska*¹, Tobias Hey^{2,3}, Jes la Cour Jansen², Irena Petrinic⁴, Jasmina Korenak⁴, Hermina Buksek⁴, Claus Hélix-Nielsen^{1,4}

1: Technical University of Denmark, Department of Environmental Engineering, Miljøvej 113, 2800 Kgs. Lyngby, Denmark,

2: Faculty of Engineering, Lund University, Getingevägen 60, 221 00 Lund, Sweden

3: VA SYD, 201 21 Malmö, Sweden

4: University of Maribor, Faculty of Chemistry and Chemical Engineering Smetanova ulica 17, SLO-2000 Maribor, Slovenia,

*Corresponding author email: agza@env.dtu.dk

ABSTRACT

Water recycling for agricultural and industrial applications offers resource and economic savings. In addition, water recovery can alleviate global water stress which currently exists. Therefore it is of general interest to restore/reclaim water from waste streams. Conventional ways to reclaim water from wastewater such as membrane bioreactors combined with reverse osmosis (RO), or micro/ultrafiltration coupled with RO and sand filtration, or advanced oxidation process are all energy intensive.

In comparison to pressure driven membrane processes, forward osmosis (FO) can operate in the absence of applied hydraulic pressure resulting in a lower fouling propensity and consequently lower need for cleaning. However, FO membranes are not completely resistant to fouling. Therefore it becomes important to identify methods to reduce or if possible eliminate fouling as this will lead to increased FO membrane performance and lifespan thus increasing the economic viability of the FO process. As fouling can occur by a variety of processes including inorganic, organic, and biological processes, fouling characterization becomes a non-trivial task.

The objective of this study is to characterize fouling of FO biomimetic aquaporin membranes used for water recovery from municipal wastewater. Membrane fouling was analyzed using Scanning Electron Microscopy, X-ray Dispersive Spectrometry, Fourier Transform Infrared Spectrometry, Inductively Coupled Plasma Optical Emission Spectrometry, Ion chromatography, contact angle and zeta potential measurements.

Our preliminary experimental results indicate that FO biomimetic aquaporin membranes can tolerate being exposed to municipal waste water and that fouling within the first 20 h operation is not severe. When fouling is observed it appears uneven in character, leading to local surface hydrophilization and overall to more negative surface charge. Taken together our results show that it is feasible to use biomimetic membranes in waste water treatment and the analyses can assist in future optimization of membrane performance.