



Validation of the Revised WAsP Park Model

Rathmann, Ole Steen; Hansen, Brian Ohrbeck; Leon, J.P. Murcia; Hansen, Kurt Schaldemose; Mortensen, Niels Gylling

Publication date:
2017

Document Version
Peer reviewed version

[Link back to DTU Orbit](#)

Citation (APA):
Rathmann, O. S., Hansen, B. O., Leon, J. P. M., Hansen, K. S., & Mortensen, N. G. (2017). *Validation of the Revised WAsP Park Model*. Poster session presented at WindEurope 2017, Amsterdam, Netherlands.

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Validation of the Revised WAsP Park Model

O.S. Rathmann¹, B.O. Hansen¹, J.P. Murcia Leon², K.S. Hansen¹, N.G. Mortensen¹

¹Technical University of Denmark, Department of Wind Energy, 4000 Roskilde, Denmark

²Vestas Power Solutions, 8200 Aarhus, Denmark



PO.120

Abstract

The DTU Wind Energy wind-resource model WAsP contains a wind farm wake model *Park* (*Park1*). This *Park* model has been revised, **Park2**, to improve prediction accuracy in large wind farms, based on sound physical and mathematical principles: consistent wake-modelling and perturbation theory for wake-wake-interaction.

Park2 has been validated and calibrated using a number of off-shore and on-shore wind farms. The calibration has resulted in recommended values for the wake-expansion coefficients of the **Park2** model.

Objectives

Why revise the Park-model?: To some extent the original Park-model [2, 3] is based on empirics to a higher degree than on physics. Also, there have been doubts regarding the applicability to large wind farms.

What should Park2 fulfill?: Park2 should be based on sound physical modelling and on accepted mathematical principles. Park2 should be calibrated and validated against available wind farm operational data.


Methods of Park2

Single-turbine wake: The wake from a single-turbine "i" in a wind-farm is modelled, following the classical approach by N.O.Jensen [1], by a top-hat speed-deficit profile (constant inside, zero outside wake), as a function of the down-wind coordinate x:

$$\Delta V_i(x) = V_i^{inc} \left(1 - \sqrt{1 - C_t^i(V_i^{inc})}\right) \left(\frac{D_i^{rotor}}{D_i^{wake}(x-x_i)}\right)^2, D_i^{wake}(\Delta x) = D_i^{rotor} + 2k\Delta x$$

Combined wakes: speed deficit at turbine j by linear superposition of wakes from turbines upwind of turbine "j", considering partial overlap between wakes and the rotor of turbine "j":

$$V_j^{inc} = U_0 - \sum_i^{up\ turb} \Delta V_i(x_j) \frac{A_{i,j}^{overlap}}{A_j^{rotor}}$$



- U_0 : free wind speed, i.e. hypothetical wind speed had the wind farm not existed
- D_i^{rotor} : rotor diameter of turbine "i"
- D_i^{wake} : diameter of wake from turbine "i"
- x_i : down wind coordinate of turbine "i"
- V_i^{inc} : incident wind speed at turbine "i"
- $C_t^i(V)$: thrust coefficient of turbine "i" as a function of hub-height wind speed.
- k : model wake expansion coefficient
- A_i^{rotor} : rotor area of turbine "i"
- $A_{i,j}^{overlap}$: partial overlapping area of wake "i" on rotor of turbine "j"

Consistent formulation: The wake speed deficit from a single turbine depends only on local incident wind speed V_i^{inc} at the turbine considered (not on free wind speed U_0 as is the case in *Park1*).

Wake combination by perturbation: The speed deficits are considered to be small perturbations, so that linear superposition can be used (2nd and higher order effects of wake mixing can be disregarded).

Wake - surface interaction disregarded: The Park2 model is simple, thus wake interaction with surface is disregarded. The reflection model of the original *Park* model [2,3] was not considered to represent aerodynamics at the surface correctly [4, 5].

Simple terrain effects model: Terrain effects on wakes are disregarded. However, onshore free wind speed U_0 is calculated individually for all turbines incl. terrain effects.


Results: Calibration and Validation – Offshore

Calibration and validation were performed vs. Danish offshore wind farm data sets.

- Horns Rev 1: production data 2005.Jan.01 – 2009.Dec.31
- Nysted: production data 2004.May.24 – 2006.Nov.16
- Lillgrund: production data 2008.Jan.01 – 2012.Dec.31

Calibration

Bayesian calibration [6, 7] was used for the wake expansion coefficient k . Based on filtered wind farm production data (all turbines running) the PDF graphs show the probability distribution of the expansion coefficient k .




Wind farm	μ	σ
Horns Rev 1	0.061	0.005
Nysted	0.057	0.007
Lillgrund	0.064	0.004
All	0.06	0.006
Anholt	0.051	0.006

(Only included for reference)

Validation

Modelled turbine production deficit profile downwind in a wind farm compared to observed data. Examples are presented below.




Observations	Park2					Park1
	$k = 0.05$	$k = 0.06$	$k = 0.07$	$k = 0.08$	$k = 0.09$	$k = 0.10$

Results: Calibration – Onshore

Calibration for onshore wake expansion coefficient k was performed vs. wind farm production calculations by *Park1* with standard parameters, for 14 wind farms.

Creyap 1	Creyap 2	Napier	Jasseines (2 Wind Farms)	La Ventosa	Capel Canyon (5 wind farms)					Vredens-burg	Ras Ghared		
GB	GB	S.AFR.	France		Mexico	GB					S.AFR.	Egypt	
14 x 2MW	22 x 1.3MW	27 x 3.45MW	6 x 2MW	4 x 1.8MW	51 x 2MW	18 x 2MW	6 x 3MW	7 x 2MW	9 x 2MW	4 x 3MW	6 x 0.81MW	34 x 3.6MW	100 x 3.02MW



Error bars: k -values where Park2 production calculation differs +/- 0.15% from Park1.

Result from all on-shore wind farms		
k	μ	0.088
	σ	0.009

Conclusions

Park2 was found to produce predictions at least as close as Park1 to observed offshore wind farm productions. The calibration resulted in recommended wake-expansion coefficient values for both off- and on-shore wind farms.

Windfarm type	Offshore		Onshore	
	μ	σ	μ	σ
k	0.06	0.006	0.09	0.009

References

- N.O.Jensen, A Note on Wind Generator Interaction, *Risø-M-2411. Risø National Laboratory, Roskilde, Denmark, (1983).*
- I.Katic, J.Højstrup, N.O. Jensen, A Simple Model for Cluster Efficiency, *EWEA Conference and Exhibition 7-9-October 1986, Rome, Italy, paper C6. (1986)*
- P.Sanderhoff, Park – Users' Guide, A PC-program for calculation of wind turbine park performance, *Risø-I-668(EN), Risø National Laboratory, Roskilde, Denmark, (1993).*
- Ott, S., Berg, J. and Nielsen, M., Linearized CFD Models for Wakes, *Risø-R-1772(EN), Risø National Laboratory, Roskilde, Denmark, (2011).*
- Ott, S. and Nielsen, M., Developments of the offshore wind turbine wake model Fuga, *DTU Wind Energy E-0046, Danish Technical University, Department of Wind Energy (2014).*
- M.C. Kennedy, A. O'Hagan. Bayesian calibration of computer models, *Journal of the Royal Statistical Society: Series B (Statistical Methodology), 63(3), 425-464. (2001).*
- Murcia, J.P. et al., Uncertainty quantification in wind farm flow models, *PhD thesis, DTU Wind Energy (2017).*

Meet us at booth # F34

