



Tjæreborg Wind Turbine (Esbjerg)

First dynamic inflow measurement

Øye, Stig

Publication date:
1991

Document Version
Early version, also known as pre-print

[Link back to DTU Orbit](#)

Citation (APA):
Øye, S. (1991). *Tjæreborg Wind Turbine (Esbjerg): First dynamic inflow measurement*. AFM notat No. VK-189

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

AFM NOTAT	<u>Subject :</u> TJÆREBORG WIND TURBINE (Esbjerg) First dynamic inflow measurement	
VK - 189	<u>Remarks:</u>	<u>Date/sign.</u> 29.04.91 / SØ
pages : 6	Distribution: Participants in 'Dynamic Inflow'	
Department of Fluid Mechanics, DTH, DK-2800 Lyngby (+45) 45 93 27 11		
<u>Summary :</u> This paper presents the first measured timeseries for the Tjæreborg Wind Turbine during operation with stepwise pitch angle changes.		

1. Measured time series.

The first experiment to investigate the dynamic wake effects from pitch angle changes on the Tjæreborg Wind Turbine was done April 12, 1991. At the time, the equipment to produce automatic pitch steps was not yet available, so the pitch was changed manually by the control system keyboard. However, with this procedure the pitch rate was fixed at only 1 deg/sec. As it was considered a preliminary test only one time series of 10 minutes was recorded. The test conditions were not ideal either as the wind speed was only 7 to 8 m/s.

Page 5 and 6 of this paper show data from the original time series. The flapwise moments are measured at $R = 2.75$ m at all 3 blades. The measured moments have been corrected for zero-point errors by comparing the mean values with calculated values for the mean wind speed derived from the measured mean power and the measured power curve, thereby using the wind turbine as anemometer. This procedure has been shown to be quite accurate in cases where the zero points could be checked by stopping the turbine. When the flapwise moments are compared to calculated aerodynamic moments it should be noted, that the actual moments are reduced by the centrifugal stiffening of the blades. The reduction has been estimated to 9%.

The measured pitch angle shows an offset of 0.5 deg. compared to the ones commanded. The control system and the measurement system obviously disagree, although they both get the signal from the same transducer. At present, it is not known which one is the correct one, so no corrections have been made to the measured values.

2. Calculation of average step response.

In order to extract the most information about the dynamic wake effects from the measured time series, the following averaging procedure has been performed.

First the time trace for the pitch angle is searched for the

times where it crosses upwards through the level of 1.0 deg. The complete time series is then divided into 9 segments of 30 sec. duration each starting 5 sec. before the level crossing. A new time series is constructed as the average of the 9 series in the sense, that the value of each sensor signal at a given time is the average of the 9 individual values from the 9 time series at the same time relative to the pitch angle level crossing. A new sensor signal is calculated as the mean value of the 3 averaged flapwise moments to further reduce the influence of turbulence, wind shear and tower shadow. Finally, a synthetic signal for the main shaft torsion is calculated from the measured torsion of the high speed shaft by multiplication with the gear box speed ratio, as the real main shaft torsion sensor is unreliable.

The above procedure is repeated for the decreasing pitch steps determined as crossing down through 2.0 deg. The resulting averaged time series is then appended to the first, starting at $t = 30$ sec.

The averaged time series are shown on page 3 and 4. They are showing clear indications of dynamic wake effects, but also a surprising large amount of 1P or 3P variations. This is caused by the pitch change repetition frequency being very close to a integer fraction of the rotational frequency. This will be avoided in future experiments by changing the pitch frequency slightly. It is also hoped to improve future results by recording at least 3 consecutive 10 min series at each experiment.







