



Application of chemical oxidation for removal of pharmaceuticals in wastewater effluents

Hey, G.; Ledin, A.; la Cour Jansen, J.; Hörsing, M.; Antoniou, Maria; Spiliotopoulou, Aikaterini; Andersen, Henrik Rasmus

Published in:
Book of Abstracts

Publication date:
2012

Document Version
Publisher's PDF, also known as Version of record

[Link back to DTU Orbit](#)

Citation (APA):
Hey, G., Ledin, A., la Cour Jansen, J., Hörsing, M., Antoniou, M., Spiliotopoulou, A., & Andersen, H. R. (2012). Application of chemical oxidation for removal of pharmaceuticals in wastewater effluents. In *Book of Abstracts: IWA Regional Conference on Wastewater Purification & Reuse* IWA Publishing. <http://www.wwpr2012.gr/>

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Application of chemical oxidation for pharmaceuticals removal in wastewater effluents

G. Hey, PhD Student; A. Ledin, Professor; J. la Cour Jansen, Professor; Maritha Hörsing, Postdoc -Water and Environmental Engineering, Department of Chemical Engineering, Lund University

R. Grabic, Postdoc; J. Fick, Assistant Professor; M. Tysklind, Professor -Department of Chemistry, Umeå University

M. Antoniou, Postdoc; A. Spiliotopoulou, Researcher; H.R. Andersen, Associate Professor, Department of Environmental Engineering, Technical University of Denmark

Contact: Gerly Hey, Department of Chemical Engineering, Lund University, Getingevägen 60, 221 00 Lund, Sweden; Tel. +462228998; Email: gerly.moradas@chemeng.lth.se

Executive Summary

This study was conducted to evaluate the potential of the chemical oxidation processes chlorine dioxide (ClO_2) and ozone (O_3) as tertiary treatment step to remove trace active pharmaceutical ingredients (APIs) in Swedish municipal wastewater treatment plants (WWTPs). Wastewater effluents of varying organic load (COD \sim 30-90 mg/L) were collected from different WWTPs in Sweden to represent different types of biological treatment. Batch experiments were carried out employing ClO_2 (0-20 mg/L) and O_3 (0-12 mg/L) to treat biologically treated wastewater spiked with approx. 1 $\mu\text{g/L}$ mixed APIs. Additionally, treatment with peroxone ($\text{O}_3/\text{H}_2\text{O}_2$) is carried out to enhance API oxidation rate by non-selective hydroxyl radicals. Some of the APIs investigated are shown in Fig. 1 and 2. From the ClO_2 treatment, API removal varied from no significant removal at the highest ClO_2 dose to more than 90% removal with 0.5 mg/L of the oxidant. The low COD effluent exhibited most of the APIs removed at 5 mg/L ClO_2 dose while a significant increase in API removal from the high COD effluent after treatment with 8 mg/L ClO_2 .

Shown in Fig. 1, treatment with ClO_2 of low COD effluent removes diclofenac by $>90\%$ at low oxidant dose of 1.25 mg/L while in high COD effluent around 3 mg/L ClO_2 is needed to reach 90% removal. Repaglinide is also removed at low ClO_2 dose. In comparison to ozonation, the same degree of removal of these APIs is reached but with much higher ozone dose. On the other hand, citalopram and trimetoprim in low COD effluent (Fig. 2) can be removed by ozonation at lower dose than ClO_2 . Ozonation significantly enhanced the removal of most APIs including carbamazepine, metoprolol, flutamid, bupropion and beclomethasone (Fig. 2). In addition, ozonation allows removal of ibuprofen in low COD wastewater but at higher oxidant dose.

This study illustrates that treatment of wastewater containing trace pharmaceuticals is possible with either chlorine dioxide or ozone as additional treatment step depending on the target pollutant and taking into consideration the economic aspect of the process. For small-scale WWTPs, ClO_2 treatment could be an option when ozonation is too expensive and complicated to operate.




Fig. 1. Comparison of API removal by ClO_2 in low (left bar graph) and high COD (right bar graph) effluents.




Fig. 2. Comparison of API removal by O_3 in low (left bar graph) and high COD (right bar graph) effluents.